

Fuel Gas Testing Certification

Florida Fuel Gas Code 5th Edition

2014

Policy and Procedure

When a single gas appliance is added, a single gas appliance is relocated, or a LPG tank is changed or relocated on an operating fuel gas system and the total developed length of new gas piping does not exceed 20' the 1st rough-in inspection and pressure test may be waived provided the follow are accomplished:

1. All piping and venting must be visible for final inspection except wall and ceiling penetrations. Under ground piping must have a 3" minimum site tube at mid-run.
2. Gas Contractor must perform a test of all new piping in accordance with FGC2007 section 406.1 through 406.4.2 and certify it to Pinellas County BDRS below.
3. The contractor agrees that at the discretion of the Fuel Gas Inspector any concealed portion of the work will be uncovered and/or a pressure test may be required to be applied to the new portion of piping.

Permit Number _____ Project Address _____

License Holder _____ License Number _____

I certify that the above policy and procedure were completed for this gas installation and that gas system and appliances are free of leakage.

Print Name _____ Signature _____

Certification may be made by the license holder or an authorized representative.

Date _____

Methods to submit completed form:

1. Fax to 727-464-5021
2. Email to building@pinellascounty.org
3. Provide to Fuel Gas Inspector on jobsite