

**SUBMIT  
BID TO:**

Pinellas County Board of County Commissioners  
Purchasing Department  
400 South Ft. Harrison, Sixth Floor  
Clearwater, Florida 33756

**INVITATION TO BID**

**PINELLAS COUNTY  
BOARD OF COUNTY COMMISSIONERS**

**BID TITLE: SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION  
FOR FACILITY MANAGEMENT AND COUNTY WIDE  
NON MANDATORY PRE-BID CONFERENCE:**

**DATE/TIME:** 10:00 AM on Tuesday, January 31, 2006 in the Purchasing Conference Room,  
5<sup>th</sup> Floor Annex Building, 400 South Ft. Harrison Avenue, Clearwater, FL.

**BID NO.:** 045-789-B (RC)

[www.pinellascounty.org](http://www.pinellascounty.org)



**BID SUBMITTAL IS DUE: February 16, 2006 at 3:00 P.M. AND MAY  
NOT BE WITHDRAWN FOR 60 DAYS AFTER SUCH DATE AND TIME**

**DEADLINE FOR WRITTEN QUESTIONS: February 7, 2006 by 3:00  
P.M.**

**CONTACT PERSON: RICK CASAMO, CPPB**

**EMAIL ADDRESS: [rcasamo@co.pinellas.fl.us](mailto:rcasamo@co.pinellas.fl.us)**

**PHONE: 727-464-3155 FAX 727/464-3925**

**ISSUE DATE**

**JANUARY 13, 2006**

**COMMISSIONERS**

**KENNETH T. WELCH - CHAIRMAN  
RONNIE DUNCAN - VICE CHAIRMAN  
CALVIN D. HARRIS  
SUSAN LATVALA  
JOHN MORRONI  
KAREN WILLIAMS SEEL  
ROBERT B. STEWART**

**THE MISSION OF PINELLAS COUNTY**

Pinellas County Government is committed to progressive public policy, superior public service, courteous public contact, judicious exercise of authority and sound management of public resources to meet the needs and concerns of our citizens today and tomorrow.

**JOSEPH LAURO,  
CPPO/CPFB  
Director of Purchasing**

**SECTION A****GENERAL CONDITIONS OF INVITATION TO BID****1. PREPARATION OF BID:**

Bid will be prepared in accordance with the following:

- (a) Our enclosed Bid Proposal Form is to be used in submitting your bid.
- (b) All information required by the Bid form shall be furnished. The bidder shall print or type his name and manually sign the schedule and each continuation sheet on which an entry is made.
- (c) Unit prices shall be shown and where there is an error in extension of price, the unit price shall govern.
- (d) Alternate bids will not be considered unless authorized by the Invitation to Bid.
- (e) Proposed delivery time must be shown and shall include Sundays and holidays.
- (f) Bidders will not include federal taxes nor State of Florida sales, excise, and use taxes in bid prices, as the County is exempt from payment of such taxes. An exemption certificate will be signed where applicable upon request.
- (g) Bidders shall thoroughly examine the drawings, specifications, schedule, instructions and all other contract documents.
- (h) Bidders shall make all investigations necessary to thoroughly inform themselves regarding plant and facilities for delivery of material and equipment as required by the bid conditions. Plea of ignorance by the bidder of conditions that exist or that may hereafter exist as a result of failure or omission on the part of the bidder to make the necessary examinations and investigations, or failure to fulfill in every detail the requirements of the contract documents, will not be accepted as a basis for varying the requirements of the County or the compensation to the vendor.
- (i) Bidders are advised that all County Contracts are subject to all legal requirements provided for in the Purchasing Ordinance and/or State and Federal Statutes.

**2. DESCRIPTION OF SUPPLIES:**

- (a) Any manufacturer's names, trade names, brand name, or catalog numbers used in specifications are for the purpose of describing and establishing general quality levels. SUCH REFERENCES ARE NOT INTENDED

## SECTION A - GENERAL CONDITIONS - CONTINUED

(b) TO BE RESTRICTIVE. Bids will be considered for all brands which meet the quality of the specifications listed for any items.

- (b) Bidders are required to state exactly what they intend to furnish, otherwise they shall be required to furnish the items as specified.
- (c) Bidders will submit, with their proposal, data necessary to evaluate and determine the quality of the item(s) they are bidding.

3. **SUBMISSION OF BID:**

- (a) Bids or proposals shall be submitted utilizing recycled paper copied on both sides' wherever possible. Failure to comply could result in the bid or proposal being rejected.
- (b) Bid and changes thereto shall be enclosed in sealed envelopes addressed to the Purchasing Department, Pinellas County. The name and address of the bidder, the date and hour of the bid submittal and the material or service bid on shall be placed on the outside of the envelope.
- (c) Bid must be submitted on the forms furnished. Electronic/facsimile bids will not be considered. The County reserves the right to modify the Bid Proposal by electronic/facsimile notice provided such notice is received prior to the time and date set for the bid submittal.

4. **REJECTION OF BID:**

- (a) The County may reject a bid if:
  1. The bidder misstates or conceals any material fact in the bid.
  2. The bid does not strictly conform to the law or requirements of bid.
  3. The bid is conditional, except that the bidder may qualify his bid for acceptance by the County on an "all or none" basis, or a "low item" basis. An "all or none" basis bid must include all items upon which the bid was invited.
- (b) The County may, however, reject all bids whenever it is deemed in the best interest of the County to do so, and may reject any part of a bid unless the bid has been qualified as provided in 4(a) 3. The County may also waive any minor informalities or irregularities in any bid.

5. **WITHDRAWAL OF BID:**

- (a) Bid may not be withdrawn after the time set for the bid submittal for a period of time as specified.
- (b) Bid may be withdrawn prior to the time set for the bid submittal. Such request must be in writing.

6. **LATE BID OR MODIFICATIONS:**

- (a) Bid and modifications received after the time set for the bid submittal will not be considered.
- (b) Modifications in writing received prior to the time set for the bid submittal will be accepted.

7. **PUBLIC REVIEW AT BID OPENING:** Bids will be opened immediately after the bid submittal date and time (3:00 PM) by the Pinellas County Purchasing Department, 400 South Fort Harrison Avenue, Annex Building, 6th Floor, Clearwater, FL 33756. The public may attend the bid opening, but may not immediately review any bids submitted. The names of respondents and their bids amounts will be read aloud at the time of opening. Pursuant to Florida Statute, Section 119.07(3)(m), all bids submitted shall be subject to review as public records 10 days from opening, or earlier if an intended decision is reached before the ten day period expires.

8. **AWARD OF CONTRACT:**

- (a) The contract will be awarded to the lowest responsive, responsible bidder whose bid, conforming to the Invitation to Bid, is most advantageous to Pinellas County, price and other factors considered. For Invitation to Bid for Sale of Real or Surplus Property, award will be made to the highest and most advantageous bid including price and other factors considered.
- (b) The County reserves the right to accept and award item by item, and/or by group, or in the aggregate, unless the bidder qualifies his bid by specified limitations. Re Par. 4(a) 3.
- (c) If two or more bids received are for the same total amount or unit price, quality and service being equal, the contract shall be awarded to one vendor by drawing lots in public.
- (d) Prices quoted must be FOB Pinellas County with all transportation charges prepaid unless otherwise specified in the Invitation to Bid.
- (e) A written award of acceptance (Purchase Order), mailed or otherwise furnished to the successful bidder, shall result in a binding contract without further action by either party.

## SECTION A - GENERAL CONDITIONS - CONTINUED

9. **BIDS FROM RELATED PARTIES OR MULTIPLE BIDS RECEIVED FROM ONE VENDOR:** Where two (2) or more related parties each submit a bid or proposal or multiple bids are received from one (1) vendor, for any contract, such bids or proposals shall be judged non-responsive. Related parties mean bidders or proposers or the principles thereof, which have a direct or indirect ownership interest in another bidder or proposer for the same contract or in which a parent company or the principles thereof of one (1) bidder or proposer have a direct or indirect ownership interest in another bidder or proposer for the same contract.
10. **LOCAL, STATE, AND FEDERAL COMPLIANCE REQUIREMENTS:** The laws of the State of Florida apply to any purchase made under this Invitation to Bid. Bidders shall comply with all local, state, and federal directives, orders and laws including, but not limited to, Equal Employment Opportunity (EEO), Minority Business Enterprise (MBE), and OSHA.
11. **PROVISION FOR OTHER AGENCIES:** Unless otherwise stipulated by the bidder, the bidder agrees to make available to all Government agencies, departments, and municipalities the bid prices submitted in accordance with said bid terms and conditions therein, should any said governmental entity desire to buy under this proposal. Eligible Users shall mean all state of Florida agencies, the legislative and judicial branches, political subdivisions (counties, local district school boards, community colleges, municipalities, or other public agencies or authorities), which may desire to purchase under the terms and conditions of the contract.
12. **COLLUSION:** The bidder, by affixing his signature to this proposal, agrees to the following: "Bidder certifies that his bid is made without previous understanding, agreement, or connection with any person, firm or corporation making a bid for the same item(s) and is in all respects fair, without outside control, collusion, fraud, or otherwise illegal action".
13. **CONTRACTOR LICENSE REQUIREMENT:** All contractors performing construction and related work in Pinellas County must comply with our regulatory legislation, Chapter 75-489, Laws of Florida, as amended. Failure to have a competency license in a regulated trade will be cause for rejection of any bid and/or contract award.
14. **BID TABULATION INQUIRIES:** Inquiries relating to the results of this bid, prior to the official bid award by the Pinellas County Board of County Commissioners may be made by visiting the Pinellas County Purchasing Office. Telephone inquiries will be acknowledged after fourteen (14) days from the date of the bid opening. IF A TABULATION OF BIDS IS DESIRED, PLEASE ENCLOSE A SELF-ADDRESSED STAMPED ENVELOPE WHEN SUBMITTING BID PROPOSAL. IF MORE CONVENIENT, TABULATIONS ARE AVAILABLE FOR PICK-UP AFTER FINAL AWARD.
15. **MATERIAL SAFETY DATA SHEETS REQUIREMENTS:** If any chemicals, materials, or products containing toxic substances, in accordance with OSHA Hazardous Communications Standards, are contained in the products purchased by the County as a result of this bid, the successful bidder shall provide a Material Safety Data Sheet at the time of each delivery.
16. **RIGHT TO AUDIT:** Pinellas County reserves the privilege of auditing a vendor's records as such records relate to purchases between Pinellas County and said vendor. Such audit privilege is provided for within the text of the Pinellas County Code §2-156 through §2-176(j). Records should be maintained for three (3) years from the date of final payment.
17. **STATEMENT RELATIVE TO "PUBLIC ENTITY CRIMES":** The contractor is directed to the Florida Public Entity Crime Act, §287.133, Florida Statutes, and the County's requirement that the successful bidder comply with it in all respects prior to and during the term of this contract.
18. **MULTIPLE COPIES:** Unless otherwise specified, responses to an Invitation to Bid or Request for Proposal (RFP) should be submitted in duplicate.
19. **COUNTY INDEMNIFICATION:**
- a) The first ten dollars (\$10) of compensation received by the contractor pursuant to this contract represents specific consideration for the following indemnification: contractor shall indemnify, pay the cost of defense, including attorneys' fees, and hold harmless the County from all suits, actions or claims of any character brought on account of any injuries or damages received or sustained by any person, persons or property by or from the said contractor; or by, or in consequence of any neglect in safeguarding the work; or through the use of unacceptable materials in the construction of improvements; or by, or on account of any act or omission, neglect or misconduct of the said contractor; or by, or on account of, any claim or amounts recovered under the "Workers' Compensation Law" or of any other laws, by-laws, ordinance, order or decree, except only such injury or damage as shall have been occasioned by the sole negligence of the County.

<b>SECTION A - GENERAL CONDITIONS - CONTINUED</b>
---

- b. The successful bidder(s) agrees to indemnify the County and hold it harmless from and against all claims, liability, loss, damage or expense, including counsel fees, arising from or by reason of any actual or claimed trademark, patent or copyright infringement or litigation based thereon, with respect to the goods or any part thereof covered by this order, and such obligation shall survive acceptance of the goods and payment thereof by the County.
20. **VARIANCE FROM STANDARD TERMS & CONDITIONS:** All standard terms and conditions stated in Section A apply to this contract except as specifically stated in the subsequent sections of the document, which take precedence over Section A, and should be fully understood by bidders prior to submitting a bid on this requirement.
21. **ADA REQUIREMENT FOR PUBLIC NOTICES:** Persons with disabilities requiring reasonable accommodation to participate in this proceeding/event, should call 727/464-4062 (voice/td) fax 727/464-4157, not later than seven days prior to the proceeding.
22. **"OR EQUAL" DETERMINATION:** Where bidding other than specified, the determination of equivalency will be at the sole discretion of Pinellas County and its specialized personnel.
23. **CERTIFICATE OF INSURANCE:** The contractor must provide a Certificate of Insurance in accordance with Insurance Requirements, Section C, prior to issuance of Purchase Order or commencement of any work hereunder.
24. **PROCUREMENT POLICY FOR RECYCLED MATERIALS:**  
Pinellas County wishes to encourage its bidders to use recycled products in fulfilling contractual obligations to the County and that such a policy will serve as a model for other public entities and private sector companies.

When awarding a purchase of \$5000 or less, or recommending a purchase in excess of \$5000 for products, materials, or services, the Director of Purchasing may allow a preference to a responsive bidder who certifies that their product or material contains the greatest percentage of postconsumer material. If they are bidding on paper products they must certify that their materials and/or products contain at least the content recommended by the EPA guidelines.

On all bids over twenty-five thousand dollars (\$25,000) and formal quotes under twenty-five thousand dollars (\$25,000), or as required by law, the Director of Purchasing shall require vendors to specify which products have recycled materials, what percentage or amount is postconsumer material, and to provide certification of the percentages of recycled materials used in the manufacture of goods and commodities procured by the County.

Price preference is not the preferred practice the County wishes to employ in meeting the goals of this resolution. If a price preference is deemed to serve the best interest of the County and further supports the purchase of recycled materials, the Director of Purchasing will make a recommendation that a price preference be allowed up to an amount not to exceed 10% above the lowest complying bid received.

**DEFINITIONS:**

**Recovered Materials:** Materials that have recycling potential, can be recycled, and have been diverted or removed from the solid waste stream for sale, use or reuse, by separation, collection, or processing.

**Recycled Materials:** Materials that contain recovered materials. This term may include internally generated scrap that is commonly used in industrial or manufacturing processes, waste or scrape purchased from another manufacturer and used in the same or a closely related product.

**Postconsumer Materials:** Materials which have been used by a business or a consumer and have served their intended end use, and have been separated or diverted from the solid waste stream for the purpose of recycling, such as; newspaper, aluminum, glass containers, plastic containers, office paper, corrugated boxes, pallets or other items which can be used in the remanufacturing process.

25. **ASBESTOS MATERIALS:**  
The contractor shall perform all work in compliance with Federal, State and local laws, statutes, rules, regulations and ordinances, including but not limited to the Department of Environmental Protection (DEP)'s asbestos requirements, 40 CFR Part 61, Subpart M, and OSHA Section 29 CFR 1926.58. Additionally, the contractor shall be properly licensed and/or certified for asbestos removal as required under Federal, State and local laws, statutes, rules, regulations and ordinances.

## SECTION A - GENERAL CONDITIONS - CONTINUED

The County shall be responsible for filing all DEP notifications and furnish a copy of the DEP notification and approval for demolition to the successful contractor. The County will furnish a copy of the asbestos survey to the successful bidder. The contractor must keep this copy on site at all times during the actual demolition.

26. **PAYMENT/INVOICES:** The bidder must specify on the Bid Summary form exactly the company name and address which must be the same as invoices submitted for payment as a result of award of this bid. Further, the successful bidder is responsible for immediately notifying the Purchasing Department of any company name change, which would cause invoicing to change from the name used at the time of the original bid. Payment will be made, in arrears, in accordance with Fla. Stat. § 218.70, *et. seq.*, the Florida Prompt Payment Act.
27. **CANCELLATION:**
- (a) Pinellas County reserves the right to cancel this contract without cause by giving thirty (30) days prior notice to the contractor in writing of the intention to cancel or with cause if at any time the contractor fails to fulfill or abide by any of the terms or conditions specified.
  - (b) Failure of the contractor to comply with any of the provisions of this contract shall be considered a material breach of contract and shall be cause for immediate termination of the contract at the discretion of Pinellas County.
  - (c) In the event sufficient budgeted funds are not available for a new fiscal period, the County shall notify the vendor of such occurrence and contract shall terminate on the last day of current fiscal period without penalty or expense to the County.
  - (d) In addition to all other legal remedies available to Pinellas County, Pinellas County reserves the right to cancel and obtain from another source, any items which have not been delivered within the period of time stated in proposal, or if no such time is stated, within a reasonable period of time from the date of order as determined by Pinellas County.
28. **BIDDER CAPABILITY/REFERENCES:** Prior to contract award, any bidder may be required to show that the company has the necessary facilities, equipment, ability and financial resources to perform the work specified in a satisfactory manner and within the time specified. In addition, the company must have experience in work of the same or similar nature, and can provide references, which will satisfy the County. Bidders must furnish a reference list of at least four (4) customers for whom they have performed similar services (SEE SECTION D)
29. **DELIVERY/CLAIMS:** Prices quoted shall be F.O.B. Destination, FREIGHT INCLUDED and unloaded to location(s) within Pinellas County. Actual delivery address(es) shall be identified at time of order. Successful bidder(s) will be responsible for making any and all claims against carriers for missing or damaged items
30. **MATERIAL QUALITY:** All materials purchased and delivered against this contract will be of first quality and not damaged and/or factory seconds. Any materials damaged or not in first quality condition upon receipt will be exchanged within twenty-four (24) hours of notice to the Contractor at no charge to the County.
31. **WRITTEN REQUESTS FOR INTERPRETATIONS/CLARIFICATIONS:** No oral interpretations will be made to any firms as to the meaning of specifications or any other contract documents. All questions pertaining to the terms and conditions or scope of work of this bid/proposal must be sent in writing (mail or fax) to the Purchasing Department and received by the date specified in Section A. Responses to questions may be handled as an addendum if the response would provide clarification to requirements of the bid/proposal. All such addenda shall become part of the contract documents. The County will not be responsible for any other explanation or interpretation of the proposed bid made or given prior to the award of the contract. The Purchasing Department will be unable to respond to questions received after the specified time frame.
32. **ASSIGNMENT/SUBCONTRACTING/CORPORATE ACQUISITIONS AND/OR MERGERS:** The Contractor shall perform this contract. If a bidder intends to subcontract a portion of this work, the bidder must disclose that intent in the bid. No assignment or subcontracting shall be allowed without prior written consent of the County. In the event of a corporate acquisition and/or merger, the Contractor shall provide written notice to the County within thirty (30) business days of Contractor's notice of such action or upon the occurrence of said action, whichever occurs first. The right to terminate this contract, which shall not be unreasonably exercised by the County, shall include, but not be limited to, instances in which a corporate acquisition and/or merger represent a conflict of interest or are contrary to any local, state, or federal laws. Action by the County awarding a bid to a bidder, which has disclosed its intent to assign or subcontract in its response to the ITB, without exception shall constitute approval for purposes of this Agreement.

## SECTION A - GENERAL CONDITIONS - CONTINUED

33. **EXCEPTIONS:** Contractor is advised that if it wishes to take exception to any of the terms contained in this Bid or the attached service agreement it must identify the term and the exception in its response to the Bid. Failure to do so may lead County to declare any such term non-negotiable. Contractor's desire to take exception to a non-negotiable term will not disqualify it from consideration for award.
34. **NON-EXCLUSIVE CONTRACT:** Award of this Contract shall impose no obligation on the County to utilize the vendor for all work of this type, which may develop during the contract period. This is not an exclusive contract. The County specifically reserves the right to concurrently contract with other companies for similar work if it deems such action to be in the County's best interest. In the case of multiple-term contracts, this provision shall apply separately to each term.
35. **LOBBYING:** Lobbying of Evaluation Committee members, Pinellas County Government employees, or elected officials regarding request for proposals, request for qualifications, bids or contracts, during the pendency of bid protest, by the bidder/proposer/protestor or any member of the bidder's/proposer's/protestor's staff, an agent of the bidder/proposer/protestor, or any person employed by any legal entity affiliated with or representing an organization that is responding to the request for proposal, request for qualification, bid or contract, or has a pending bid protest is strictly prohibited either upon advertisement or on a date established by the Board of County Commissioners and shall be prohibited until either an award is final or the protest is finally resolved by the County Administrator or Purchasing Director; provided, however, nothing herein shall prohibit a prospective bidder/proposer from contacting the Purchasing Department to address situations such as clarification and/or questions related to the procurement process. For purposes of this provision lobbying activities shall include but not be limited to, influencing or attempting to influence action or non-action in connection with any request for proposal, request for qualification, bid or contract through direct or indirect oral or written communication or an attempt to obtain goodwill of persons and/or entities specified in this provision. Such actions may cause any request for proposal, request for qualification, bid or contract to be rejected.
36. **ADDITIONAL REQUIREMENTS:** The County reserves the right to request additional goods or services relating to this Agreement from the Contractor. When approved by the County as an amendment to this Agreement and authorized in writing, the Contractor shall provide such additional requirements as may become necessary.
37. **ADD/DELETE LOCATIONS SERVICES:** The County reserves the right to unilaterally add or delete locations/services, either collectively or individually, at the County's sole option, at any time after award has been made as may be deemed necessary or in the best interests of the County. In such case, the contractor(s) will be required to provide services to this contract in accordance with the terms, conditions, and specifications.
38. **PROTEST PROCEDURE:**
- As per Section 2-162 of County Code
1.
    - (a) *Bid/Proposal protests.* Any actual or prospective bidder, proposer, who is allegedly aggrieved in connection with the issuance of a bid/proposal package or pending award of a contract may protest to the director of purchasing. (Ord. No. 94-51, § 5, 6-7-94)
    - (b) *Posting.* The purchasing department shall post the formal award on the departmental website. The formal award shall be publicly posted on the purchasing department's website no less than three full business days after the decision to recommend the award to the bidder/proposer is made.
    - (c) *Requirements to Protest.*
      - (1) If the protest relates to the content of the bid/proposal package, a formal written protest must be filed no later than 5:00 p.m. on the fifth full business day after issuance of the bid/proposal package.
      - (2) If the protest relates to the award of a contract, a formal written protest must be filed no later than 5:00 p.m., on the fifth business day after posting of either the contract award recommendation or the contract award itself. The formal written protest shall identify the protesting party and the solicitation involved; include a clear statement of the grounds on which the protest is based; refer to the statutes, laws, ordinances or other legal authorities which the protesting party deems applicable to such grounds; and specifically request the relief to which the protesting party deems itself entitled by application of such authorities to such grounds.

## SECTION A - GENERAL CONDITIONS - CONCLUDED

(3) A formal written protest is considered filed with the county when the Purchasing Department, County Administrator, or County Commission receives it. Accordingly, a protest is not timely filed unless it is received within the time specified above. Failure to file a formal written protest within the time period specified shall constitute a waiver of the right to protest and result in relinquishment of all rights to protest by the bidder/proposer.

(d) Sole remedy. These procedures shall be the sole remedy for challenging an award of bid. Bidder/proposers are prohibited from attempts to influence, persuade, or promote a bid protest through any other channels or means. Such attempts shall be cause for suspension in accordance with 2-161(b) of this article.

(e) Time Limits. The time limits in which protests must be filed as specified herein may be altered by specific provisions in the Bid/Request for Proposal.

(f) Authority to resolve. The Director of Purchasing shall resolve the protest in a fair and equitable manner and shall render a written decision to the protestant no later than 5:00 p.m. on the fifth business day after the filing thereof.

(g) Review of Purchasing Director's decision.

(1) The protesting party may request a review of the Purchasing Director's decision to the County Administrator by delivering written request for review of the decision to the Director of Purchasing by 5:00 p.m. on the fifth business day after the date of the written decision. The written notice shall include any written or physical materials, objects, statements, and arguments, which the bidder/proposer deems relevant to the issues raised in the request for review.

(2) If it is determined that the solicitation or award is in violation of law or the regulations and internal procedures of the purchasing department, the County Administrator shall immediately cancel or revise the solicitation or award as deem appropriate.

(3) If it is determined that the solicitation or award should be upheld, the County Administrator shall issue a decision in writing stating the reason for the action with a copy furnished to the protesting party and all substantially affected persons or businesses no later than 5:00 p.m., on the fifth full business day. The decision shall be final and conclusive as to the county unless any further action is taken or a party commences action in court.

2. Stay of Procurement During Protests. There shall be no stay of procurement during protests.

### 39. **INTEGRITY OF BID DOCUMENTS**

Bidders shall use the original Bid Form(s) provided by the Purchasing Department and enter information only in the spaces where a response is requested. Bidders may use an attachment as an *addendum* to the Bid Form(s) if sufficient space is not available on the original form for the bidder to enter a complete response. **Any modifications or alterations to the original bid documents by the bidder, whether intentional or otherwise, will constitute grounds for rejection of a bid.** Any such modifications or alterations a bidder wishes to propose must be clearly stated in the bidder's proposal response and presented in the form of an addendum to the original bid documents.

### 40. **PUBLIC EMERGENCIES:**

It is hereby made a part of this bid that before, during, and after a public emergency, disaster, hurricane, tornado, flood, or other acts of God that Pinellas County shall require a "First Priority" for goods and services. It is vital and imperative that the majority of citizens are protected from any emergency situation that threatens public health and safety, as determined by the County. Vendor/contractor agrees to rent/sell/lease all goods and services to the County or governmental entities on a "first priority" basis. The County expects to pay a fair and reasonable price for all products and services rendered or contracted in the event of a disaster, emergency, hurricane, tornado or other acts of God.

<b>SECTION B SPECIAL CONDITIONS</b>
-------------------------------------

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE  
045-789-B (RC)**

1. **INTENT:** In accordance with attached specifications, it is the intent of Pinellas County to establish contracts for **Fire Safety Testing, Inspection and Certification for Facility Management and Fire Extinguisher Inspection, Testing and Certification County Wide**, as and when required.

This is a two-part bid.

PART 'A' addresses fire safety equipment for Facility Management locations.  
PART 'B' is for fire extinguisher inspection, for buildings and automobiles Countywide.

**PART 'A'**

1) Provide fire system inspection, maintenance, testing and certification for buildings under the supervision for General Services, Facility Management. Facility Management is divided into five (5) Sections: South County, Criminal Justice Center, North County, and Mid County and Detention. Each Section consists of one or more locations within that Section. During the term of this contract, Facility Management may be assigned additional locations or locations may be closed, consolidated, sold, or otherwise deleted.

**PART 'B'**

2) Provide fire extinguisher inspection, testing, maintenance and certification for fire extinguishers throughout the entire county. This includes fire extinguishers that are located in buildings within the four sections of Facility Management. Providing a service of this nature will require the awarded contractor to interface with individuals from every County department and at every location. During the term of this contract, the County may acquire additional locations or locations may be closed, consolidated, sold, or otherwise deleted. In addition to structures, several departments have vehicles with fire extinguishers that will also require inspection, maintenance, testing and certification.

2. **QUANTITIES:** Quantities stated are an estimate only and no guarantee is given or implied as to quantities that will be used during the contract period. Estimated quantities are based upon previous use and/or anticipated needs.
3. **PRICING/PERIOD OF CONTRACT:** Unit prices bid of listed items shall be held firm for the duration of the contract. Duration of the contract shall be for a period of thirty-six (36) months from the date of contract award.
4. **OPTION OF RENEWAL:**  
The contract may be extended subject to written notice of agreement from the County and the successful bidder(s) for up to three (3) additional twelve (12) month periods beyond the primary contract period. Contract renewals will allow for price adjustments in an amount not to exceed the average of the Consumer Price Index (CPI) for all Urban Consumers, Not Seasonally Adjusted, for the twelve months prior to renewal, or five percent (5%), whichever is less. This option shall be exercised only if all terms and conditions remain the same and the County Administrator or Director of Purchasing grants approval.

It is the vendor's responsibility to request any pricing adjustment under this provision. For any adjustment to commence on the first day of any exercised option period, the vendor's request for adjustment should be submitted 90 days prior to expiration of the then current contract term or at time of renewal request from the County. The vendor adjustment request should not be in excess of the relevant pricing index change. If no adjustment request is received from the vendor, the County will assume the vendor has agreed that the optional term may be exercised without pricing adjustment. Any adjustment request received after the commencement of a new option period may not be considered.

<b>SECTION B - GENERAL CONDITIONS - CONTINUED</b>
---

**NON MANDATORY PRE-BID CONFERENCE:** A non-mandatory pre-bid meeting and site visit will be held at 10:00 AM on Tuesday, January 31, 2005, in the Purchasing Conference Room, Located on the fifth floor Annex Building, 400 South For Harrison, Clearwater, Florida.

All questions pertaining to the bid or technical specifications will be reviewed at this time. Bid suggestions or modifications may be discussed with County representatives at this meeting and may be considered by representatives as possible addenda to the Invitation to Bid.

6. **BID DEPOSIT WITH PERFORMANCE BOND: DOES NOT APPLY.**
7. **BREACH OF CONTRACT:** Failure of Contractor to perform any of the services required by this contract within ten (10) days of receipt of written demand for performance from the County shall constitute breach of contract.
8. **PERMITS, FEES AND COSTS IMPOSED BY PINELLAS COUNTY TO BE OBTAINED BY AND/OR BORNE BY CONTRACTOR:** Pursuant to section 218.80, Florida Statutes, Pinellas County discloses to the contractors the following permits and fees which will have to be obtained by and will be payable by the contractor who is the successful bidder or proposer.
- A. License Fees:
1. The application fee for the licensure for the following Contractor Classifications (some or all of which may apply to this contract), payable to and through the Pinellas County Construction Licensing Board, is \$125:
    - a. General Contractor
    - b. Building Contractor
    - c. Residential Contractor
    - d. Electrical Contractor
    - e. Plumbing Contractor
    - f. Mechanical Contractor
    - g. Class "A" Air Conditioning Contractor
    - h. Class "B" Air Conditioning Contractor
    - i. Class "C" Air Conditioning Contractor
    - j. Sheet Metal Contractor
    - k. Roofing Contractor
    - l. Aluminum Contractor
    - m. Veneer Specialty Contractor
    - n. Commercial Swimming Pool Contractor
    - o. Residential Pool Contractor
    - p. Swimming Pool Servicing Contractor
    - q. Underground Utility Contractor
    - r. Low Voltage Specialty Contractor
    - s. Communication System Specialty Contractor
    - t. Painting Specialty Contractor
    - u. Alarm Specialty Contractor - Limited
    - v. Marine Specialty Contractor
    - w. Structural Masonry Specialty Contractor
    - x. Flatwork Masonry Specialty Contractor
    - y. Gypsum Drywall Specialty Contractor
    - z. Natural Gas Specialty Contractor
    - aa. Carpentry Specialty Contractor
    - bb. Tile and Marble Specialty Contractor
    - cc. Irrigation Systems Specialty Contractor

N.B. If the contractor and/or any subcontractors are already licensed by the Pinellas County Licensing Board, only the annual renewal fees of \$100.00 per year by each licensed trade is required. If the contractor and/or any subcontractors are licensed by the State of Florida, then only the original and annual renewal registration fee of \$25.00 per year by each licensed trade is required.

<b>SECTION B - GENERAL CONDITIONS - CONTINUED</b>
---

For the Contractor and/or any subcontractors not already licensed by the Pinellas County Construction Licensing Board or the State of Florida for whom licensure is required, an additional testing fee payable to the testing company may be required.

2. IDENTIFY OTHER LICENSES AND APPROPRIATE FEES

- B. Permits and Associated Fees:  
IDENTIFY WHAT PERMITS AND APPROPRIATE FEES OR APPROPRIATE FORMULAE EXPRESSED AS PERCENTAGES FOR COMPUTING FEES.
- 1.
  - 2.
  - 3.
- C. Impact Fees:  
IDENTIFY TYPES OF IMPACT FEES AND APPROPRIATE AMOUNTS
- 1.
  - 2.
  - 3.
- D. Inspection Fees:  
IDENTIFY TYPES OF INSPECTIONS AND APPROPRIATE FEES
- 1.
  - 2.
  - 3.
- E. Other Permits or Fees Required by Pinellas County for the Completion of the Subject Construction:  
IDENTIFY WHAT PERMITS AND APPROPRIATE FEES OR APPROPRIATE FORMULAE EXPRESSED AS PERCENTAGES FOR COMPUTING PERMIT FEES AND OTHER APPLICABLE FEES.
- 1.
  - 2.
  - 3.

The foregoing list of fees apply only to those fees imposed by Pinellas County or imposed by another governmental agency which has assigned or delegated the responsibility for issuance of permits, licenses and conduction of inspections and attendant collection of fees to Pinellas County. The Contractor is responsible for determining if other fees and permits are required by any other Federal, State, or local governmental entity, agency or board.

9. **WORKSITE SANITATION:** At the end of each workday, the contractor shall remove from the premises the daily accumulation of waste materials or rubbish caused by his operations. Safety hazards will be immediately corrected by the contractor. The contractor is also responsible for ensuring that any subcontractor hired by him or his subcontractors totally cleanup the worksite at the completion of the work. If the contractor fails to clean up at the completion of the work, the County may do so and deduct the cost of such cleanup from the contractor's most current invoice. The contractor will not be responsible for cleaning up debris left by the County's employees, the public utilizing other areas in the vicinity of the worksite, or left by other contractors.

## SECTION C - INSURANCE AND INDEMNIFICATION REQUIREMENTS

**I MINIMUM INSURANCE REQUIREMENTS FOR GENERAL LOW RISK CONTRACTS**

- A. Prior to the time Contractor is entitled to commence any part of the project, work or services under this Contract, Contractor shall procure, pay for and maintain at least the following insurance coverage's and limits. Said insurance shall be evidenced by delivery to the County of (1) certificates of insurance executed by the insurers listing coverage's and limits, expiration dates and terms of policies and all endorsements whether or not required by the County, and listing all carriers issuing said policies; and (2) upon request a certified copy of each policy, including all endorsements. The insurance requirements shall remain in effect throughout the term of this Contract. In addition, the County reserves the right to request physical evidence of this coverage by requesting the policy declaration page.
- (1) Worker's Compensation in at least the limits as required by law; Employers' Liability Insurance of not less than \$100,000 for each accident.
  - (2) Comprehensive General Liability Insurance including, but not limited to, Independent, Contractor, Contractual, Premises/Operations, Products/Completed Operation and Personal Injury covering the liability assumed under indemnification provisions of this Contract, with limits of liability for personal injury and/or bodily injury, including death, of not less than \$500,000, each occurrence; and property damage of not less than \$100,000, each occurrence. (Combined Single Limits of not less than \$500,000, each occurrence, will be acceptable unless otherwise stated). Coverage shall be on an "occurrence" basis, and the policy shall include Broad Form Property Damage coverage, and Fire Legal Liability of not less than \$50,000 per occurrence, unless otherwise stated by exception herein.
  - (3) Comprehensive Automobile and Truck liability covering owned, hired and non-owned vehicles with minimum limits of \$500,000 each occurrence, for bodily injury including death, and property damage of not less than \$100,000, each occurrence. (Combined Single Limits of not less than \$500,000, each occurrence, will be acceptable unless otherwise stated). Coverage shall be on an "occurrence" basis, such insurance to include coverage for loading and unloading hazards.
  - (4) Professional Liability Insurance (including Errors and Omissions) with minimum limits of \$500,000 per occurrence, if occurrence form is available; or claims made form with "tail coverage" extending three (3) years beyond completion and acceptance of the PROJECT with proof of "tail coverage" to be submitted with the invoice for final payment. In lieu of "tail coverage", CONSULTANT may submit annually to the COUNTY a current Certificate of Insurance proving claims made insurance remains in force throughout the same three (3) year period.
  - (5) \$500,000.00 combined single limits, personal injury and/or bodily injury, including death, and property damage liability insurance as an excess of the primary coverage required above.
- B. Each insurance policy shall include the following conditions by endorsement to the policy:
- (1) Each policy shall require that thirty (30) days prior to expiration, cancellation, non-renewal or any material change in coverage's or limits, a notice thereof shall be given to County by certified mail to: Pinellas County Purchasing Department, 400 S. Ft. Harrison Avenue, 6th Floor, Clearwater, Florida 33756. Contractor shall also notify County, in a like manner, within twenty-four (24) hours after receipt, of any notices of expiration, cancellation, non-renewal or material change in coverage received by said Contractor from its insurer; and nothing contained herein shall absolve Contractor of this requirement to provide notice.

**SECTION C - INSURANCE AND INDEMNIFICATION REQUIREMENTS**

- (2) Companies issuing the insurance policy, or policies, shall have no recourse against County for payment of premiums or assessments for any deductibles which all are at the sole responsibility and risk of Contractor.
  - (3) The term "County" or "Pinellas County" shall include all Authorities, Boards, Bureaus, Commissions, Divisions, Departments and offices of County and individual members, employees thereof in their official capacities, and/or while acting on behalf of Pinellas County.
  - (4) Pinellas County, Board of County Commissioners shall be endorsed to the required policy or policies as an additional insured.  
The policy clause "Other Insurance" shall not apply to any insurance coverage currently held by County to any such future coverage, or to County's Self-Insured Retention's of whatever nature.
- C. Contractor hereby waives subrogation rights for loss or damage against the County.
- D. Contractor shall ensure that any subcontractors or persons hired by subcontractors maintain the same level of insurance coverage as the contractor.

**II MINIMUM INSURANCE REQUIREMENTS FOR HIGH RISK CONTRACTS OVER \$100,000.00**

- A. For selected high-risk contracts over \$100,000.00 aggregate value, the County may require an insurance certificate, policy declaration page and required endorsements. These required items shall be received by the County after formal Board of County Commissioners award and prior to execution of contract. Failure to provide required insurance documentation may cause your company to forfeit award.
- B. There may be certain projects or services less than \$100,000.00 in aggregate value that would be an exception and must be treated the same way as those services of \$100,000.00 and greater i.e. services involving obvious potentially dangerous conditions. Examples of such services would be any contracts involving construction, alterations, renovations, painting, spraying, roofing, mowing, scaffolding, excavation, demolition, environmentally sensitive work and any other condition that appears to be dangerous in nature.

**SECTION D -VENDOR REFERENCES / FIELD SERVICE PERSONNEL**

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE  
045-789-B (RC)**

THE FOLLOWING INFORMATION IS REQUIRED IN ORDER THAT YOUR BID MAY BE REVIEWED AND PROPERLY EVALUATED.

COMPANY NAME: \_\_\_\_\_

LENGTH OF TIME COMPANY HAS BEEN IN BUSINESS: \_\_\_\_\_

BUSINESS ADDRESS: \_\_\_\_\_

HOW LONG IN PRESENT LOCATION: \_\_\_\_\_

TELEPHONE NUMBER: \_\_\_\_\_

FAX NUMBER: \_\_\_\_\_

TOTAL NUMBER OF CURRENT EMPLOYEES: \_\_\_\_\_ FULL TIME \_\_\_\_\_ PART TIME

NUMBER OF EMPLOYEES YOU PLAN TO USE TO SERVICE THIS CONTRACT: \_\_\_\_\_

LOCAL COMMERCIAL AND/OR GOVERNMENTAL REFERENCES THAT YOU HAVE PREVIOUSLY PERFORMED SIMILAR CONTRACT SERVICES FOR:

1. \_\_\_\_\_  
Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
Telephone/Fax

\_\_\_\_\_  
Contact

3. \_\_\_\_\_  
Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
Telephone/Fax

\_\_\_\_\_  
Contact

2. \_\_\_\_\_  
Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
Telephone/Fax

\_\_\_\_\_  
Contact

4. \_\_\_\_\_  
Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
Telephone/Fax

\_\_\_\_\_  
Contact

This information must be included with the bid. Failure to provide this information may result in the rejection of your bid.

**SECTION D -VENDOR REFERENCES / FIELD SERVICE PERSONNEL - CONTINUED**

**FIELD SERVICE PERSONNEL**

**FIELD SERVICE SUPERVISOR / MANAGER:**

NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

TELEPHONE NUMBER: \_\_\_\_\_ FAX NUMBER: \_\_\_\_\_

CELL PHONE NUMBER: \_\_\_\_\_

YEARS OF EXPERIENCE IN A SUPERVISORY POSITION: \_\_\_\_\_

LICENSES, CERTIFICATIONS AND QUALIFICATIONS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**FIELD SERVICE TECHNICIANS:**

(1) NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

TELEPHONE NUMBER: \_\_\_\_\_ FAX NUMBER: \_\_\_\_\_

CELL PHONE NUMBER: \_\_\_\_\_

YEARS OF EXPERIENCE: \_\_\_\_\_

(2) NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

TELEPHONE NUMBER: \_\_\_\_\_ FAX NUMBER: \_\_\_\_\_

CELL PHONE NUMBER: \_\_\_\_\_

YEARS OF EXPERIENCE: \_\_\_\_\_

This information must be included with the bid. Failure to provide this information may result in the rejection of your bid.

<b>SECTION E - SPECIFICATIONS</b>
-----------------------------------

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE  
045-789-B (RC)**

**SCOPE:**

Pinellas County requires the services of a contractor(s) capable of performing a full line of fire safety inspection, testing, certification, repairs and replacements on all fire safety related equipment for Pinellas County Facility Management locations and fire extinguishers countywide. Services for inspection, testing and certification must be all inclusive. The awarded contractor(s) must be able to provide all the services required to service this contract. **No subcontracting will be allowed on this contract.**

**GENERAL**

Fire safety codes, rules, regulations, and laws are complex and subject to change. The awarded contractor will be responsible for staying current with all fire safety related codes, rules regulations and laws and to take the necessary action to assure that Pinellas County is compliant at all times.

**Bidders must disclose any violations filled by the State Fire Marshal's Office within the past three years along with your bid.** The County will review the violation(s) and determine whether violations are of a nature that would warrant the rejection of the bid as non-responsive. Failure to disclose any violation may result in disqualification.

**Bidders must enclose along with the bid submittal,** copies of permits, licenses, certifications, and any other related documentation, required by law, to confirm that they are legally authorized to perform the necessary testing, inspection, and certification, repairs or replacements to perform this contract.

This contract allows for repairs or replacement of equipment or systems. It cannot be determined if or when a safety system will require repair, replacement or the extent of such repairs. The County reserves the right to determine if it is in the County's best interest to authorize repair and replacements from the awarded contractor or purchase elsewhere.

Repairs of a nominal amount for such items as brackets, O-rings, pull tabs, seats, etc., may be authorized and paid for with a Pinellas County Purchasing Card (P-Card). Fire extinguishers that are commonly available through retail establishments may be purchased from the awarded contractor if it is determined that pricing is fair and reasonable and in the best interest of the County. Any fire extinguisher sold to the County from the Contractor must be certified as a condition of the sale.

**FIELD SERVICE PERSONNEL**

The awarded contractor must provide names, and the means to contact a company field supervisor/manager and a minimum of two field technicians- SEE FORM, PAGE 14. The field supervisor/manager must be able to respond to emergency calls within two hours and be available to respond to emergency situations at all times. Bidders are required to submit the names of personnel and additional information on the FIELD SERVICE INFORMATION sheet in section 'D' , Page 14 of the bid document. The contractor will notify the County of personnel changes.

---

**SECTION E – SPECIFICATIONS PART ‘A’ -CONTINUED**

---

**PART ‘A’****SPECIFICATIONS FOR FIRE SYSTEM INSPECTION, MAINTENANCE, TESTING AND CERTIFICATION FOR GENERAL SERVICES – FACILITY MANAGEMENT****GENERAL:**

These specifications are guidelines for the preparation of responses to Pinellas County’s Requests for Bids to provide **Fire System Inspection, Maintenance, Testing, and Certification**. This includes all parts of the system from the city main. The systems components include, but are not limited to pumps, all valves, back flow preventors, piping, sprinkler heads, stand pipes, all fire detection devices, all alarm warning devices, all fire panels and all systems activated by the fire system; all deluge valves; this is not an all inclusive list. The goal of this contract is to insure that Pinellas County Fire Systems meet all Federal, State and Local Fire codes and regulations. The standard guideline is the National Fire Protection Association and OSHA.

The general purpose of this Request for Bid is for prospective contractors to relate how they will provide the services included herein to all buildings and facilities under the control and maintenance responsibility of General Services, Facility Management. The Contractor receiving the contract will provide reports on the results of the **Fire System Inspection, Testing, Maintenance and Certification**. The reports are to include recommendations for needed modifications, repairs, and procedures that will bring equipment back into the standard limits or improve the equipment efficiency rates.

Building and locations are subject to change and may be added or deleted during the life of the contract as required.

Facility Management is divided into five (5) groups. Each group is represented by a Facility Management Coordinator. The Facility Management Coordinator will be the initial point of contact for all activities relating to Part ‘A’ of this contract. Facility Management Coordinators are:

- Group 1, South County– Keith Royster
- Group 2, Criminal Justice Center – Otto Hughes
- Group 3, North County – Damon Hostetler
- Group 4, Mid County – Richard Dawson
- Group 5, Detention – Elena Weeks / Ray Kosach

Elena Weeks is the also the Contract Manager for Part ‘A’

**UNSPECIFIED WORK:**

If it is determined that repairs are necessary, the contractor will complete the maintenance, place the equipment back into service and notify Facility Manager or his Designee of the suggested repairs. Any needed repairs will require a written estimate to the Facility Management Coordinator, whether the repair is approved or purchased elsewhere at the decision of the County.

Fire hood suppression systems and automatic fire suppression systems are included as unspecified work and will be authorized by the Facility Management Coordinator.

**REPORTING CRITERIA:**

Pinellas County maintains records of all fire safety related activity. The contractor is required to provide all inspections reports in an electronic format within ten (10) calendar days of completion of each assignment to the Group Facility Management Coordinator. The reports will serve as the verification that the work has been completed. The Facility Management Coordinator for each section will use the report as justification to authorize invoices for payment. Contractor shall also maintain a database of inspection reports at contractor facility for auditing purposes. **Contractor should provide sample reports and formats with bid.**

**SECTION E – SPECIFICATIONS PART ‘A’-CONTINUED****SECURITY CLEARANCE**

All employees making visits to or working on any Pinellas County Government building shall be subject to a background investigation by the Pinellas County Sheriff's Office for security clearance. A list of these employees, along with a satisfactory security clearance shall be submitted to the Facility Manager or his Designee Five (5) WORKING DAYS IN ADVANCE OF ANY EMPLOYEE BEGINNING WORK. A valid picture ID (Driver's License) is required.

**ELECTRICAL CONNECTIONS**

UL listed products will be used for electrical connections.

**STORAGE OF CHEMICALS**

No storage of chemicals will be permitted on County premises. The Service Provider shall be wholly responsible for chemical storage, and the delivery of chemicals to each facility. Mixing of chemicals at the site is permitted only in the amount needed for a service. The Service Provider may only bring chemicals on site in 5-gallon containers. The Service Provider shall dispose of all chemical waste and unused chemicals in accordance with all local, state, and federal laws, regulations, ordinances and codes in effect at the work and HAZMAT sites.

**INSPECTION CRITERIA**

**Stand Pipe System Inspection, Testing, and Certification** as per OSHA and the most updated version of the NFPA.

**Fire Panel Inspection, Testing, and Certification** as per OSHA and the most updated version of the NFPA.

**Fire Extinguisher Annual Inspection, Certification, and monthly sign off tags**, as per OSHA and the most updated version of the NFPA.

**PAYMENT SCHEDULE FOR PART ‘A’**

Inspections for equipment listed in Part ‘A’ are required at different intervals. Inspections may be required on a quarterly, semi-annual, annual, or bi-annual basis. Additionally, these inspections may be required at different times. A bi-annual inspection at one Group, may not be required at another Group. Vendors are responsible to visit each site, verify the last date of inspection and price the services accordingly in twelve month intervals. This will allow each Group to budget their annual expenses.

## SECTION E – SPECIFICATIONS PART 'A'-CONTINUED

**PUMPS:** The Contractor will perform all the items outlined below and any other requirements.

		Visual Inspection	Check	Change	Clean	Test	Frequency
<b>Pump System</b>	Lubricate pump bearings			X			Annually
	Check Pump Shaft		X				
	Check accuracy of pressure gauges, (change or re-calibrate when 5% out of calibration)		X	X			Annually
	Check pump coupling alignment		X				Annually
	Flow Test (verify flow meets rating of pump)					X	Annually
	Packing, Replace				X		Once every two years
<b>Mechanical Transmission</b>	Lubricate coupling			X			Annually
	Lubricate right angle gear drive			X			Annually
<b>Electrical System</b>	Exercise isolating switch and circuit breaker					X	Annually
	Trip circuit breaker (if provided)					X	Annually
	Operate manual starting means (electrical)					X	Annually
	Inspect and operate emergency manual starting means (without power)					X	Annually
	Tighten electrical connections as necessary		X				Annually
	Lubricate mechanical moving parts (Excluding starters and relays)		X				Annually
	Calibrate pressure switch settings		X				Annually
	Grease motor bearings				X		Annually
<b>Paint</b>	Scrape and paint pumps and pipes leading to and from IAW OSHA and NFPA				X		Annually
<b>Deluge Valves</b>	Test switch and operation					X	Bi-annually

## SECTION E – SPECIFICATIONS PART 'A' - CONTINUED

**Part 'A' Building and Equipment Profile.**

Facility Management provides this information as a guideline and is not to be used as a complete listing.

<b>Group 1 - South County</b>				
<b>SC1. NCNB Building</b>				
501 1st Avenue North, St. Petersburg, FL 33701				
Manager: Joe Manninen; 727-582-7738				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>		10 Story		
<b>Extinguishers</b>			46	Building A
<b>Service Entrance</b>			20	Building b
<b>Fire Panel</b>	Radio Phonics – Bld. A	Simplex 2001		Bldng B
<b>Zones</b>			34	
<b>Detection Devices</b>			19	Duct
	<b>Smoke</b>		70	
	<b>Heat</b>		4	
	<b>Pull</b>		33	
<b>Pumps</b>			2	
	<b>Location</b>			
	<b>Size</b>	40 hp	1	Main Building
	<b>Size</b>	50 hp	1	Annex Bldng
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			1st & 2nd Floors
	<b>Fire Curtains</b>			7th Floor
	<b>Standpipe &amp; Sprinkler Hoods</b>			1st thru 10th Floors
<b>Alarms</b>				Annex & Main Buildings
	<b>Horns</b>		9	
	<b>Strobes</b>		15	
	<b>Speakers</b>		21	
	<b>Speaker Strobes</b>		43	
<b>Additional</b>				
	<b>Flow Switches</b>		13	10 bldng A, 3 Bldng B
	<b>Standpipes</b>			
	<b>Sprinklerheads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>		2	1 in Bldng A 1 in Bldng B

## SECTION E – SPECIFICATIONS PART 'A' - CONTINUED

**Part 'A' Building and Equipment Profile.**

<b>Group 1 - South County</b>				
<b>SC2. Judicial Building</b>				
545 1st Avenue North, St. Petersburg, FL - Bldngs. A & B				
		Type	Number	Location(s)
<b>Building A</b>		5 Story		
<b>Energy Plant B</b>				
<b>Extinguishers</b>			48	46 Bldng A, 2 Bldng B
<b>Service Entrance</b>	<b>Building A</b>			6th Street, west side of building
	<b>Plant B</b>			N/A
<b>Fire Panel</b>	<b>Building A</b>	Simplex 4002	1	
	<b>Plant B</b>	Notifier	1	
<b>Zones</b>			8	
<b>Detection Devices</b>				8 Bldng A, 1 bldng B
	<b>Smoke</b>		96	
	<b>Heat</b>		59	
	<b>Pull</b>		3	
<b>Pumps</b>			1	Bldng A
	<b>Location</b>			Upper Park
	<b>Size</b>	75 hp		
	<b>Type</b>	Electric		
	<b>Feeds</b>			Standpipe & Sprinklerheads
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		4	3 Bldng A, 1 Bldng B
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			County-owned and needs inclusion for testing

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 1 - South County</b>				
<b>SC3. Traffic Court</b>				
1800 66th Street North, St. Petersburg, FL 33710				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			17	
<b>Service Entrance</b>				
<b>Fire Panel</b>		Siemens MXL Addressable System	1	
<b>Zones</b>			4	
<b>Detection Devices</b>		9		
	<b>Smoke</b>	111		
	<b>Heat</b>	7		
	<b>Pull</b>	14		
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 1 South County</b>				
<b>SC4.</b>				
647 1st Avenue North, St. Petersburg, FL 33701				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>		2 story		
<b>Extinguishers</b>			11	
<b>Service Entrance</b>				
<b>Fire Panel</b>		Pyrotronics CP400	1	
<b>Zones</b>			2	
<b>Detection Devices</b>				
	<b>Smoke</b>		15	
	<b>Heat</b>		5	
	<b>Pull</b>		5	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 1 - South County</b>				
<b>SC5. Weedon Island Education Center</b>				
1800 Weedon Drive NE, St. Petersburg, FL 33702				
Manager:				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			7	
<b>Service Entrance</b>				?
<b>Fire Panel</b>		Firelite		
<b>Zones</b>			6	
<b>Detection Devices</b>			8	
	<b>Smoke</b>		2	
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			
This building has a sprinkler fed system fed from water service pressure, smoke detectors, pull stations, fire extinguishers and a monitored alarm.				

## SECTION E – SPECIFICATIONS PART 'A' - CONTINUED

Part 'A' Building and Equipment Profile.

<b>Group 2 - CJC</b>				
<b>Criminal Justice Center</b>				
14250 49th Street North, Clearwater, FL				
Manager: Joe Manninen				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	a-1,bcdef-4,g-2,h-4			
<b>Extinguishers</b>			137	CO2 1, 2 ½ & 14, Halon 1, #6 & 4
<b>Service Entrance</b>				Front
<b>Fire Panel</b>		Simplex 4100	1	
<b>Zones</b>			7	
<b>Detection Devices</b>			64	Duct
	<b>Smoke</b>		285	
	<b>Heat</b>		4	
	<b>Duct</b>		64	
	<b>Pull</b>		79	
	<b>Sprinkler Monitor</b>		46	
	<b>Waterflow Monitor</b>		18	
	<b>Door Holder</b>		6	
	<b>Drop Down Fire Dr</b>		10	
	<b>Horn/Strobe</b>		240	
<b>Pumps</b>		Mdl 481	1	
	<b>Location</b>			A-Wing Mechanical Room 1st Floor
	<b>Size</b>	6X481X18B	1	Aurora Pentir Pump Group
	<b>Type</b>	481BFH		1500GPH
	<b>Feeds</b>			Standpipe & Sprinkler
	<b>Hydrotest Pressure</b>			262 PSI
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			
	<b>Vehicle</b>	<b>5#</b>	<b>9</b>	
This building has a sprinkler fed system fed from water service pressure, smoke detectors, pull stations, fire extinguishers and a monitored alarm.				

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>Airport Business Center Building # 2</b>				
14255 49th St. N, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			18	
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>	Easco	1	Fed from Water Service Pressure
	<b>Back-up</b>			
	<b>Sprinkler</b>	1/2"	273	
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>		1	

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>5300 Building</b>				
5300 Ulmerton Road, Clearwater, Fl				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			15	
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			Fed from Water Service Pressure
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>Sheriff Tech Services 1</b>				
4801 145th Avenue N., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			10	
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>		6	
	<b>Pull</b>		7	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>	FM 200	1	Fed from Water Service Pressure
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>Sheriff Tech Services 2</b>				
4707 145th Avenue N., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			14	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>			5	Duct
	<b>Smoke</b>		10	
	<b>Heat</b>		4	
	<b>Pull</b>		3	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			Fed from Water Service Pressure
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>Sheriff Tech Services 2</b>				
4645 145th Avenue N., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			10	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Simplex 4001		
<b>Zones</b>			4	
<b>Detection Devices</b>				
	<b>Smoke</b>		27	
	<b>Heat</b>		2	
	<b>Pull</b>		4	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			Fed from Water Service Pressure
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>49th Street Service Center</b>				
14190 Roosevelt Blvd – Supervisor of Elections				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			11	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		MS 9000		
<b>Zones</b>			3	
<b>Detection Devices</b>			5	Duct
	<b>Smoke</b>		19	
	<b>Heat</b>			
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>Record Retention</b>				
14155 49th Street N., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			6	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Edwards		
<b>Zones</b>			6	
<b>Detection Devices</b>				
	<b>Smoke</b>		30	
	<b>Heat</b>			
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			Fed from Water Service Pressure
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>			
<b>Weedon Island Education Center</b>			
14204 46 <sup>th</sup> St. North – Sub - Fleet			
		<b>Type</b>	<b>Number</b>
<b>Building</b>			
<b>Extinguishers</b>			3
<b>Extinguishers</b>			
<b>Service Entrance</b>			
<b>Fire Panel</b>			
<b>Zones</b>			
<b>Detection Devices</b>			
	<b>Smoke</b>		
	<b>Heat</b>		
	<b>Pull</b>		
<b>Pumps</b>			
	<b>Location</b>		
	<b>Size</b>		
	<b>Type</b>		
	<b>Feeds</b>		
	<b>Back-up</b>		
	<b>Sprinkler</b>		
	<b>Fire Curtains</b>		
	<b>Standpipes</b>		
	<b>Sprinkler Hoods</b>		
<b>Alarms</b>			
	<b>Horns</b>		
	<b>Strobes</b>		
	<b>Speakers</b>		
	<b>Speaker Strobes</b>		
<b>Additional Information</b>			
	<b>Tamper Switches</b>		
	<b>Standpipes</b>		
	<b>Sprinkler Heads</b>		
	<b>Hose Connections</b>		
	<b>Backflow Preventers</b>		

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 2 - South County</b>				
<b>K-9</b>				
3410 118th Avenue North				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			2	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		ESTFS 1004G		
<b>Zones</b>			5	
<b>Detection Devices</b>				
	<b>Smoke</b>		5	
	<b>Heat</b>			
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			

## SECTION E – SPECIFICATIONS PART 'A' - CONTINUED

Part 'A' Building and Equipment Profile.

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
315 Court Street				
Manager: Ron Manning				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	<b>6 Story</b>	NCH		Basement, East & West Sides
<b>Extinguishers</b>		?	78	
<b>Extinguishers</b>				
<b>Service Entrance</b>				?
<b>Fire Panel</b>		Simplex 4002	1	
<b>Zones</b>			32	PLUS 4 IN JUDICIAL
<b>Detection Devices</b>			28	Duct
	<b>Smoke</b>		273	
	<b>Heat</b>		45	
	<b>Pull</b>		47	
<b>Pumps</b>			1	
	<b>Location</b>			Basement
	<b>Size</b>	75 hp		
	<b>Type</b>			
	<b>Feeds</b>			Standpipe & Sprinklers
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	YES
	<b>Standpipes</b>		6	
	<b>Sprinkler Heads</b>		612	
	<b>Hose Connections</b>		35	
	<b>Backflow Preventers</b>		1	West on Oak, East in Courtyard

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
400 South Ft. Harrison				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>		6 Story		Annex
<b>Extinguishers</b>			31	4 - Other
<b>Extinguishers</b>				
<b>Service Entrance</b>				SW Side of Building
<b>Fire Panel</b>		Simplex 4002	1	
<b>Zones</b>			24	
<b>Detection Devices</b>			4	Duct
	<b>Smoke</b>		154	
	<b>Heat</b>		19	
	<b>Pull</b>		19	
<b>Pumps</b>			1	
	<b>Location</b>			Room 028
	<b>Size</b>	75 HP		
	<b>Type</b>			
	<b>Feeds</b>			Stand Pipes
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	YES
	<b>Standpipes</b>			YES
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflo Preventer</b>			SW Side of Building

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>324 So. Ft. Harrison</b>				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			22	
<b>Extinguishers</b>				
<b>Service Entrance</b>				Basement North Side
<b>Fire Panel</b>		Simplex 4002	1	
<b>Zones</b>			16	
<b>Detection Devices</b>			9	
	<b>Smoke</b>		64	
	<b>Heat</b>		2	
	<b>Pull</b>		10	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	YES
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventers</b>			West Side Courtyard

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
300 South Garden Ave, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>		ABC	8	1 - Other
<b>Extinguishers</b>				
<b>Service Entrance</b>				?
<b>Fire Panel</b>		ADT		
<b>Zones</b>			4	
<b>Detection Devices</b>				
	<b>Smoke</b>		49	
	<b>Heat</b>		89	
	<b>Pull</b>		5	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
440 Court Street, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			15	
<b>Extinguishers</b>				
<b>Service Entrance</b>				Basement
<b>Fire Panel</b>		Simplex 2004		
<b>Zones</b>			32	
<b>Detection Devices</b>			14	
	<b>Smoke</b>		72	
	<b>Heat</b>		3	
	<b>Pull</b>			
<b>Pumps</b>			1	
	<b>Location</b>			Basement
	<b>Size</b>	40 HP		
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Waterflow Monitor</b>		1	
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
310 Court St. Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			5	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Firelite MS92		
<b>Zones</b>			1	
<b>Detection Devices</b>				
	<b>Smoke</b>		5	
	<b>Heat</b>			
	<b>Pull</b>		4	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			YES
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			YES
	<b>Backflow Preventer</b>			Garage East Central Near Stairwell

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
510 Bay Avenue Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			8	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
512-514 So. Ft. Harrison, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			6	
<b>Extinguishers</b>				
<b>Service Entrance</b>				South Side
<b>Fire Panel</b>		Miniscan 4024		
<b>Zones</b>			4	
<b>Detection Devices</b>			4	
	<b>Smoke</b>			
	<b>Heat</b>		4	
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
520 Oak Street, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			2	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>			?	
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
303 Chestnut Street				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	<b>6 Story</b>			
<b>Extinguishers</b>			2	
<b>Extinguishers</b>			36 SP	
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
311 Osceola Ave, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			2	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
201 Rogers St., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			6	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>		9	
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
631 Chestnut Sr., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			3	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>		6	
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
305 Osceola St. Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			1	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
311 Osceola St., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			1	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
300 So. Ft. Harrison, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			5	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
509 East Avenue, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			37	
<b>Extinguishers</b>				
<b>Service Entrance</b>				SE Corner Rec. Mgt- N side Cabinet Shop
<b>Fire Panel</b>		Notifier/Viking		Address
<b>Zones</b>			4	
<b>Detection Devices</b>			17	
	<b>Smoke</b>		101	
	<b>Heat</b>			
	<b>Pull</b>		25	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	YES
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			Monitor
	<b>Waterflow Monitor</b>		1	YES
	<b>Backflow Preventer</b>			South Side on Turner, North Side on Chestnut

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
333 Chestnut St., Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			10	
<b>Extinguishers</b>				
<b>Service Entrance</b>				SW Corner on Oak, Rm 159
<b>Fire Panel</b>		Edwards		
<b>Zones</b>			15	Duct
<b>Detection Devices</b>				
	<b>Smoke</b>		62	
	<b>Heat</b>		15	
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		29	
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	Yes
	<b>Standpipes</b>			
	<b>Sprinkler Monitor</b>		1	
	<b>Waterflow Monitor</b>		1	
	<b>Backflow Preventer</b>			SW side on Oak

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
3611 Fletch Haven, Tarpon Springs, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			6	
<b>Extinguishers</b>				
<b>Service Entrance</b>				?
<b>Fire Panel</b>		Pytronics		
<b>Zones</b>			8	
<b>Detection Devices</b>				
	<b>Smoke</b>		10	
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	
	<b>Standpipes</b>			
	<b>Sprinkler Monitor</b>		1	
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
3620 Fletch Haven, Tarpon Springs, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			9	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
29582 US 19 North NCSC Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	Main			
<b>Extinguishers</b>			2	
<b>Extinguishers</b>			6	Maintenance Bldng
<b>Service Entrance</b>				
<b>Fire Panel</b>		Miniscan		Main Bldng.
<b>Zones</b>			4	
<b>Detection Devices</b>				
	Smoke		12	
	Heat			
	Pull		6	
<b>Pumps</b>				
	Location			
	Size			
	Type			
	Feeds			
	Back-up			
	Sprinkler			
	Fire Curtains			
	Standpipes			
	Sprinkler Hoods			
<b>Alarms</b>				
	Horns			
	Strobes			
	Speakers			
	Speaker Strobes			
<b>Additional Information</b>				
	Tamper Switches			
	Standpipes			
	Sprinkler Heads			
	Hose Connections			
	Backflow Preventer			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
29582 US 19 North Maintenance Building, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	<b>Maintenance</b>			
<b>Extinguishers</b>			2	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
1425 East Lake Road, Palm Harbor, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			2	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
1500 16th St., Palm Harbor, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>		?	10	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		MS521 OUD & EPC		
<b>Zones</b>			16	
<b>Detection Devices</b>				
	<b>Smoke</b>		16	
	<b>Heat</b>			
	<b>Pull</b>		13	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
3940 Keystone Rd., Tarpon Springs				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>	<b>3 Buildings</b>			
<b>Extinguishers</b>			25	Total
<b>Extinguishers</b>				
<b>Service Entrance</b>				Keystone Rd.
<b>Fire Panel</b>		Edwards		Addressable
<b>Zones</b>			3	
<b>Detection Devices</b>				
	<b>Smoke</b>		18	
	<b>Heat</b>			
	<b>Pull</b>		19	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		35	
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Flow Switches</b>		1	YES
	<b>Standpipes</b>			YES
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			Keystone Rd.

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 3 - North County</b>				
<b>Facility Management North</b>				
1190 Georgia Ave., Palm Harbor, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			10	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
10756 Ulmerton Road, Largo, FL FM Bldg				
Manager: Ron Manning				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers, Bldng.</b>			16	
<b>Extinguishers, Vehic.</b>			6	
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4- Mid County</b>				
<b>Facility Management Mid</b>				
12450 Ulmerton Rd. Animal Services, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			18	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Edwards LSS4/36		
<b>Zones</b>			12	
<b>Detection Devices</b>				
	<b>Smoke</b>		16	11- ion, 5 duct
	<b>Heat</b>		4	
	<b>Pull</b>		15	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>			23	h/st
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
10750 Ulmerton Rd PCSO Bldng 500, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			3	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Firelite 5012		
<b>Zones</b>			2B	
<b>Detection Devices</b>				
	<b>Smoke</b>		7/2 duct	
	<b>Heat</b>			
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>			4	h/st ?
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
10750 Ulmerton Rd. PCSO Bldng 200/300, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			15	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
10750 Ulmerton RD., PSCO Bldng. 400, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			9	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Silent Knight 5207		
<b>Zones</b>			12B	
<b>Detection Devices</b>				
	<b>Smoke</b>		3	
	<b>Heat</b>		11	
	<b>Pull</b>		7	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		7	
	<b>Strobes</b>		1	
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 – Mid County</b>				
<b>Facility Management Mid</b>				
10750 Ulmerton Rd., PSCO Annex Bldng. 100, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			23	
<b>Extinguishers</b>				
<b>Service Entrance</b>				West end of Building
<b>Fire Panel</b>		Silent Knight 5207		
<b>Zones</b>			12	
<b>Detection Devices</b>				
	<b>Smoke</b>		23	
	<b>Heat</b>		27	
	<b>Pull</b>		17	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		18	
	<b>Strobes</b>		16	
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>		4"	
	<b>Sprinkler Heads</b>		160	
	<b>Hose Connections</b>		2	
	<b>Backflow Preventer</b>			4" GEM Mdl F2001

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 – Mid County</b>				
<b>Facility Management Mid</b>				
10900 Ulmerton Road, M.E. Building, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			12	
<b>Extinguishers</b>				
<b>Service Entrance</b>				?
<b>Fire Panel</b>		Notifies 640	?	
<b>Zones</b>				ADDRESSABLE
<b>Detection Devices</b>				
	<b>Smoke</b>		116	
	<b>Heat</b>		1	
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		4	
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>		8"	
	<b>Sprinkler Heads</b>		350+	
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
12175 125th St., N CO-OP, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			15	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Edwards 5712 - 2 stage		
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>		20	
	<b>Heat</b>		2	
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		9	
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
9685 Ulmerton Road Fleet Main Shop				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers, Bldng.</b>			82	
<b>Extinguishers, Vehic.</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>	<b>Body Shop</b>	Grinell 7700FP		
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes - bldng.</b>		8"	
	<b>Standpipes-Body Shop</b>		6"	
	<b>Sprinkler Heads - Bldng</b>		693	
	<b>Sprinkler Heads -Body Shop</b>		133	
	<b>Hose Conn- Bldng</b>		2 EXT	
	<b>Hose Connections - Body Shop</b>		2 EXT	
	<b>Backflow Preventer - Bldng</b>		8"MHV&F	
	<b>Backflow Preventer-Body Shop</b>		6" Ready Riser	

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 4 - Mid County</b>				
<b>Facility Management Mid</b>				
12490 Ulmerton Rd, EMS Building, Largo, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			47	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Cerberus System	3	
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>		153	9 photo, 140 ion, 4 duct
	<b>Heat</b>		39	
	<b>Pull</b>		44	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>		30	
	<b>Strobes</b>		32	
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			Potter Elec. OSYU-A2
	<b>Standpipes</b>		4"	
	<b>Sprinkler Heads</b>		56	
	<b>Hose Connections</b>		2 EXT	
	<b>Backflow Preventer</b>			Viking Mdl D2

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St., Jail A_ Barracks, Clearwater, FL				
Manager: Bob Hollingsworth				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			8	
<b>Extinguishers</b>				
<b>Service Entrance</b>				SE Side of Lobby Ent.
<b>Fire Panel</b>		Simplex	1	
<b>Zones</b>			8	
<b>Detection Devices</b>				
	<b>Smoke</b>		12	
	<b>Heat</b>		6	
	<b>Pull</b>		2	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>			3	
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>		4	
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>		4	
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5- Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N., Jail B-Barracks, Clearwater, Fl				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			8	
<b>Extinguishers</b>				
<b>Service Entrance</b>				SE Side or main Ent.
<b>Fire Panel</b>		Simplex	1	
<b>Zones</b>			8	
<b>Detection Devices</b>				
	<b>Smoke</b>		12	
	<b>Heat</b>		6	
	<b>Pull</b>		2	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49th Street N C Barracks, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			12	
<b>Extinguishers</b>			1	Generator Room
<b>Service Entrance</b>				B-Block NW Hall to Rec Yard
<b>Fire Panel</b>		Firelite 9200		
<b>Zones</b>			12	
<b>Detection Devices</b>				
	<b>Smoke</b>		80	
	<b>Heat</b>		10	
	<b>Pull</b>		6	
<b>Pumps</b>				
	<b>Location</b>			NW Corner Pump Room
	<b>Size</b>	100 HP 1,000 GPM		
	<b>Type</b>			Electric
	<b>Feeds</b>			Sprinkler & Stand Pipe
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St., N., Jail Facility management Bldng				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			10	
<b>Extinguishers</b>				
<b>Service Entrance</b>				South Side of Bldng.
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St., N. Jail FSC, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			6	
<b>Extinguishers</b>			1	Generator Room
<b>Service Entrance</b>				SE Electric Room
<b>Fire Panel</b>		Firelite 9200		
<b>Zones</b>			10	
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49th St. N., Jail F Wing, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>		ABC	41	
<b>Extinguishers</b>			1	K
<b>Service Entrance</b>				Mech. Rm South Loading Dock
<b>Fire Panel</b>		Simplex 2120		
<b>Zones</b>			67	
<b>Detection Devices</b>				
	<b>Smoke</b>		318	
	<b>Heat</b>		10	
	<b>Pull</b>		21	
<b>Pumps</b>			1	
	<b>Location</b>			Mech. Rm. South Loading Dock
	<b>Size</b>	75 HP		
	<b>Type</b>			Electric
	<b>Feeds</b>			Standpipe & Sprinkler
	<b>Back-up</b>			Generator
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49th St. N., Jail Mini I, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			8	
<b>Extinguishers</b>				
<b>Service Entrance</b>				North Mechanic Room
<b>Fire Panel</b>		ADT	1	
<b>Zones</b>			9	
<b>Detection Devices</b>				
	<b>Smoke</b>		12	
	<b>Heat</b>		20	
	<b>Pull</b>		10	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49th St., N. Jail Mini II, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			8	
<b>Extinguishers</b>				
<b>Service Entrance</b>				South Mechanic Room
<b>Fire Panel</b>		Firelite 9200		
<b>Zones</b>			11	
<b>Detection Devices</b>				
	<b>Smoke</b>		18	
	<b>Heat</b>			
	<b>Pull</b>		5	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			?
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, JAIL, MSC Control, Clearwater, FL – Kitchen				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			9	
<b>Extinguishers</b>				
<b>Service Entrance</b>				Boiler Room
<b>Fire Panel</b>		Firelite 9200		
<b>Zones</b>			1 SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		4	
	<b>Heat</b>		12	
	<b>Pull</b>			
<b>Pumps</b>			1	
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

**Group 5 - Detention**

<b>Facility Management Detention</b>				
14400 49 St., N. Jail MSC, Clearwater, FL - Laundry				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>		ABC	6	
<b>Extinguishers</b>			1	K
<b>Service Entrance</b>				Boiler Room – South Side
<b>Fire Panel</b>		Firelite 9200	?	
<b>Zones</b>			9 SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		12	
	<b>Heat</b>		12	
	<b>Pull</b>		1	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, Central, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			81	
<b>Extinguishers</b>				
<b>Service Entrance</b>				North Electric Room
<b>Fire Panel</b>		SMXL Seven		
<b>Zones</b>			20SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		1148	Total Devices
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>			1	Fire Pump Room
	<b>Location</b>			
	<b>Size</b>	100 HP		
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, Towers, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			9	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, Construction Trailer, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			4	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, Communications Maintenance, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			7	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N, Checkpoint, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			1	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>				
<b>Zones</b>				
<b>Detection Devices</b>				
	<b>Smoke</b>			
	<b>Heat</b>			
	<b>Pull</b>			
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14500 49th St. N, Boot Camp, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			14	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Simplex		
<b>Zones</b>			26	
<b>Detection Devices</b>				
	<b>Smoke</b>		40	
	<b>Heat</b>		6	
	<b>Pull</b>		8	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			At Water main

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N., Jail Phase I				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			45	
<b>Extinguishers</b>				
<b>Service Entrance</b>				Phase I Mech. Room
<b>Fire Panel</b>		Notifier 2020	1	
<b>Zones</b>			7 SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		121	
	<b>Heat</b>		35	
	<b>Pull</b>		14	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 TH ST. N., Jail Phase II, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			26	
<b>Extinguishers</b>				
<b>Service Entrance</b>				Phase II Mech. Room
<b>Fire Panel</b>		Simplex	1	
<b>Zones</b>			20	
<b>Detection Devices</b>				
	<b>Smoke</b>		37	
	<b>Heat</b>		35	
	<b>Pull</b>		8	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49 St. N., Wood Shop, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			5	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Firelite 5024		
<b>Zones</b>			5	
<b>Detection Devices</b>				
	<b>Smoke</b>		5	
	<b>Heat</b>		5	
	<b>Pull</b>		4	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14400 49th St. N., Video Visitation				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			4	
<b>Extinguishers</b>				
<b>Service Entrance</b>				
<b>Fire Panel</b>		Firelite 9200		
<b>Zones</b>			1 SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		10	
	<b>Heat</b>		3	
	<b>Pull</b>		3	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

**SECTION E – SPECIFICATIONS PART ‘A’ - CONTINUED**

**Part ‘A’ Building and Equipment Profile.**

<b>Group 5 - Detention</b>				
<b>Facility Management Detention</b>				
14500 49 St. N, Old JDC, Clearwater, FL				
		<b>Type</b>	<b>Number</b>	<b>Location(s)</b>
<b>Building</b>				
<b>Extinguishers</b>			18	
<b>Extinguishers</b>				
<b>Service Entrance</b>				North Mechanic Room
<b>Fire Panel</b>		Firelite 9600		
<b>Zones</b>			1 SLC	
<b>Detection Devices</b>				
	<b>Smoke</b>		20	
	<b>Heat</b>		6	
	<b>Pull</b>		8	
<b>Pumps</b>				
	<b>Location</b>			
	<b>Size</b>			
	<b>Type</b>			
	<b>Feeds</b>			
	<b>Back-up</b>			
	<b>Sprinkler</b>			
	<b>Fire Curtains</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Hoods</b>			
<b>Alarms</b>				
	<b>Horns</b>			
	<b>Strobes</b>			
	<b>Speakers</b>			
	<b>Speaker Strobes</b>			
<b>Additional Information</b>				
	<b>Tamper Switches</b>			
	<b>Standpipes</b>			
	<b>Sprinkler Heads</b>			
	<b>Hose Connections</b>			
	<b>Backflow Preventer</b>			

<b>SECTION E – SPECIFICATIONS - CONTINUED</b>
---

**PART 'B'**

**SPECIFICATIONS FOR FIRE EXTINGUISHER INSPECTION, MAINTENANCE, TESTING AND CERTIFICATION – COUNTY WIDE**

1. **SCOPE:**

Contractor shall provide all services, labor, and equipment required for annual on site fire extinguisher inspection, maintenance, testing and certification in various facilities and buildings owned and/or operated by the County. Each building or group of buildings within a complex, has a designated **Safety Coordinator**. The Safety Coordinator is responsible for monthly fire extinguisher inspection, to verify that the fire extinguisher is in the proper place and that each extinguisher is properly charged. The Safety Coordinator will notify the contractor when a fire extinguisher has been used. The contractor will schedule a time within five (5) working days to go to the location and refill and recharge or replace the used fire extinguisher. The decision of refill and recharge or replacement is the decision of the Safety Coordinator. The Safety Coordinator is also responsible for contacting the Contractor in the event that the annual inspection expires. Upon notification, the contractor will perform the inspection within five (5) calendar days.

2. **MAINTENANCE:**

The facility's Safety Coordinator will be notified of any unit is in need of maintenance by the contractor. Recharging a fire extinguisher will be considered a maintenance item. If a recharge requires that the unit be removed from the premises, a loaner unit will be left by the contractor until such time as the unit is recharged and returned. The contractor will submit a work order for the Safety Coordinator's approval prior to initiating any recharging

**CERTIFICATION:**

The contractor is required to certify all fire extinguishers are in proper operating condition and affix an inspection tag to each unit.

3. **INSPECTION SCHEDULE:**

It shall be the responsibility of the contractor to set up these schedules, transmit a copy of these schedules to the appropriate department safety coordinator and adhere to the same without fail.

Every portable Fire Extinguisher under this contract shall be inspected and tagged on an **ANNUAL** basis per an appropriate schedule.

All stored pressure extinguishers needing the six (6) year Maintenance Check required by law shall be scheduled, for same by the contractor on an "as needed" basis.

The County has, to the best of our knowledge, provided a master list of all fire extinguishers, locations, Safety Coordinator, phone number, size, type, manufacturer, and date of the last annual inspection. This list includes fire extinguishers in County vehicles being used by each department. However, the awarded contractor may discover that some of the information provided may be inaccurate and some locations may have been omitted. The awarded vendor will include in their monthly report discrepancies in the information provided by the County and any additional locations that were not originally listed in the spreadsheets. Regardless, the contractor will perform the required services. This contract allows additional funds for such occurrences. Any changes and /or additions to same during the contract period will be forwarded in writing to the Purchasing Department by the contractor.

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED****4. INSPECTION AND SERVICING:**

All fire extinguishers shall be inspected and serviced strictly adhering to all State, County, and City statutes, NFPA codes and ordinances. Contractor shall label each extinguisher and Automatic Fire Suppression System upon servicing same with a decal or tag as outlined by the STATE FIRE MARSHAL RULES 4A-21, indicating the inspection date, and shall ensure that said extinguisher or is clearly labeled indicating upon which type of fire it may be used (Class A only, Wood Fire, etc; Class B, etc.). Any discrepancies are to be reported immediately to the department's Safety Coordinator

Contractor is not to accept ANY service requests from anyone other than the department Safety Coordinator. Any exception to this will be provided in writing to the Contractor by either the responsible department or by the County Purchasing Department. All requests must be authorized via a Purchase Order or a P-Card before performance.

All fire extinguishers are to be serviced at their respective location premises including extinguishers that are normally housed in County vehicles. Any extinguisher that requires servicing or testing off said premises will be temporarily replaced by the Contractor with a "loaner" of comparable quality until the original is returned to its duty location. Said substitution will be duly reported, in writing, to the responsible department, and will show the extinguisher's serial number, duty location, reason for taking it off premises, and approximate date of return.

**5. INSPECTION RECORD:**

An inspection record on each extinguisher under this contract shall be developed by the contractor, with such record being maintained by same in a current status. Copy of this record is to be forwarded on a MONTHLY basis to the user department Safety Coordinator and the Pinellas County Risk Management Department throughout the contract period.

Any discrepancy between the contractor's inspection record and the County's master inventory (i.e., extinguisher is missing from location or listed serial number is different from existing unit, etc.) is to be noted and forwarded to the responsible department coordinator for investigation.

**6. PINELLAS COUNTY VEHICLES:**

The contractor will schedule inspections through the department's safety coordinator to inspect fire extinguishers in department vehicles in conjunction with inspections for fire extinguishers in the buildings. It is the responsibility of the department's Safety Coordinator to make available all vehicles used by the department that have fire extinguishers at the time that the building fire extinguishers are inspected.

**7. PARTS REPLACEMENT, ETC.:**

This contract includes replacement parts such as o-rings, tabs, mounting brackets, etc. Replacement parts shall be equal to or exceed in quality and workmanship the parts replaced. Replacement parts of a nominal dollar amount will be paid with a County Purchasing Card (P-Card). In the event the extinguisher(s) cannot be repaired, said extinguisher(s) will be disposed of in a proper manner by the contractor.

If any fire extinguisher requires replacement, the contractor will notify the responsible department, and such replacement will be done by the County.

**8. RECEIPT OF SERVICE:**

It shall be the responsibility of the County to assign a safety coordinator at each location to acknowledge the receipt of service. If this option is exercised, an itemized list indicating same will be forwarded to the contractor by the responsible department.

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**9. **WASTE DISPOSAL PERMIT**

The successful bidder must supply the Pinellas County, along with your bid, a copy of the waste disposal permit to dispose of dry chemical powder.

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp.	QTY	Insp./Cert per unit Price	TOTAL Price
Culture, Education & Leisure (CEL)	Taylor Park	Maint. Area #1	1100 8TH AVE SW, LARGO 33770	Roberta Hetzel	727 588-4847	Buckey	ABC	5	Oct.-05	1		
		Maint. Area #2				Amerex	ABC	10	Oct.-05	1		
		Chem. Storage Bldg.				Badger	ABC	10	Oct.-05	1		
		Gas Tank Area				Ansul	AB	10	Oct.-05	1		
		Pump House				Buckeye	ABC	10	Oct.-05	1		
		Ford Pick-up 95423				Amerex	ABC	5	Oct.-05	1		
		Chevy two ton 69120				Amerex	ABC	5	Oct.-05	1		
		GMC Pick-up 90891				Ansul	ABC	2.5	Oct.-05	1		
		GMC Van 95450				Buckeye	ABC	2.5	Oct.-05	1		
		Rear Maint. #1				Kidde	ABC	5	Oct.-05	1		
		Rear Maint. #2				Buckeye	BC	2.5	Oct.-05	1		
		Spares in chem shed				Badger	ABC	2.5	Oct.-05	1		
		Spares in chem shed				Buckeye	ABC	2.5	Oct.-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory	DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
			Spares in chem shed				Amerex	ABC	5	Oct-05	1		
			Spares in chem shed				Amerex	ABC	10	Oct-05	1		
		Walsingham Park - Roving Crew	77257 Ford Super duty 350	12615 - 102nd Avenue North, Largo, FL 33778	Charles Graves	727 549-6146	Badger	ABC	5	Aug-05	1		
			69.34 Dodge Fire Stike Truck				Kidde	BC	2	Aug-05	1		
			69.35 Dodge Fire Stike Truck				Kidde	BC	2	Aug-05	1		
			77344 Ford Super duty 350 Crew Dump				Kidde	ABC	5	Aug-05	1		
			91153 GMC 3500 Fuel Truck				Badger	ABC	5	Aug-05	1		
			91153 GMC 3500 Fuel Truck				Kidde	ABC	5	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		91153 GMC 3500 Fuel Truck				Amerex	ABC	5	Aug-05	1		
		91080 Sterling 12 yrd Dump				Buckeye	ABC	5	Aug-05	1		
		74393 GMC 12 yrd Dump				Ansul Sentry	ABC	5	Aug-05	1		
		75364 International Crane Truck				J.L. Industry	ABC	5	Aug-05	1		
		77230 International 2k Water Truck				Kidde	ABC	5	Aug-05	1		
		75186 John Deere 644G Loader				Badger	ABC	5	Aug-05	1		
		83793 Ford 12 yd Dump				Amerex	ABC	5	Aug-05	1		
		87394 GMC 3500 HD Mason Truck				Fire Master	ABC	5	Aug-05	1		
		83757 GMC 2500 4x4(chuck)				Amerex	ABC	5	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		83824 John Deere 410 Backhoe				Badger	ABC	5	Aug-05	1		
		91132 Caterpillar 446 Backhoe				Badger	ABC	5	Aug-05	1		
		87044 New Holland (sweeper, tractor)				Badger	ABC	5	Aug-05	1		
		77264 JCB Forklift (off road)				Kidde	ABC	5	Aug-05	1		
		108233 Hyundai Forklift (on road)				Buckeye	ABC	5	Aug-05	1		
		70536 John Deere 850 Bulldozer				Badger	ABC	5	Aug-05	1		
		90865 Ingersoll Rand Bobcat				Badger	ABC	5	Aug-05	1		
		87198 Svedala Dynapac Roller				J.L. Industries	ABC	5	Aug-05	1		
		2.5 ton military truck				Badger	ABC	5	Aug-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		75190 Vermeer Trencher				Badger	ABC	5	Aug-05	1		
		Office Door				Buckeye	ABC	5	Aug-05	1		
		Office #4				Amerex	ABC	5	Aug-05	1		
		West Maintenance				J.L. Industries	ABC	5	Aug-05	1		
		Chain Saw Sharpening Area				Fire Master	ABC	5	Aug-05	1		
		Upstairs Supply				Buckeye	ABC	5	Aug-05	1		
		Welding Box				Fire Master	ABC	5	Aug-05	1		
		Inside Chemical Building				Ansul Sentry	ABC	5	Aug-05	1		
		Outside Chemical Building				Buckeye	ABC	5	Aug-05	1		
		Sink Cleaning Area				Amerex	ABC	5	Aug-05	1		
		Work Area West Garage Door				Buckeye	ABC	5	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
	Philippe Park	Office Bay	2525 Philippe Park, Safety Harbor	Ken Helt	727 669-1947	Kiddie	Dry Chem	5	Jul.-05	1		
		Store rm 1				Bickeye	Dry Chem	5	Jul.-05	1		
		Gas Pump				Fire Master	Dry Chem	5	Jul.-05	1		
		Pump Room				Fire Master	Dry Chem	5	Jul.-05	1		
		Bay 1				Fire Master	Dry Chem	5	Jul.-05	1		
		Bay 3				Fire Master	Dry Chem	5	Jul.-05	1		
		Bay 5				Bader Fire Protect.	Dry Chem	5	Jul.-05	1		
		Bay 6				Bader Fire Protect.	Dry Chem	5	Jul.-05	1		
		Bay 7				Fire Master	Dry Chem	5	Jul.-05	1		
		Chem shed				Piper Fire Equip.	Dry Chem	5	Jul.-05	1		
		Break Room				Buckeye	Dry Chem	5	Jul.-05	1		
		Residence				Buckeye	Dry Chem	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Flat bed				Amever x	Dry Chem	5	Jul.-05	1		
		F-150				Buckeye	Dry Chem	5	Jul.-05	1		
		Sonoma				America n LaFranc e	Dry Chem	5	Jul.-05	1		
		Colorado				Amerex	Dry Chem	5	Jul.-05	1		
		Patrol car				Amerex	Dry Chem	5	Jul.-05	1		
		Spares - 1				Buckeye	Dry Chem	5	Jul.-05	1		
		Spares - 2				Amerex	Dry Chem	5	Jul.-05	1		
		Spares - 3				Amerex	Dry Chem	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Spares - 4				Amerex	Dry Chem	5	Jul.-05	1		
		Spares - 5				American LaFrance	Dry Chem	5	Jul.-05	1		
		Spares - 6				Piper	Dry Chem	5	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory	DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
			Spares - 7				Piper	Dry Chem	5	Jul.-05	1		
			Spares - 8				Fire master	Dry Chem	5	Jul.-05	1		
	Wall Springs Park.		Office Trailer-side door	3965 DeSoto Blvd., Palm Harbor, FL 34683	Don Wilson	727 943-4653	Buckeye	ABC	5	Dec-04	1		
			Office Trailer-rear rollup door				Buckeye	ABC	5	Dec-04	1		
			Storage Trailer-rear overhead door				Amerex	ABC	5	Dec-04	1		
			Storage Trailer-side door				Amerex	ABC	5	Dec-04	1		
			Park Restroom #1				Buckeye	ABC	5	Dec-04	1		
			McMullen Property - Office				Buckeye	ABC	5	Dec-04	1		
			McMullen Property - Carpentry shop				Buckeye	ABC	5	Dec-04	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		McMullen Property - Mechanic shop				Buckeye	ABC	5	Dec-04	1		
		McMullen Property - Garage				Buckeye	ABC	5	Dec-04	1		
		Park Restroom #2				Buckeye	ABC	5	Dec-04	1		
		Park Residence - Kitchen area				Buckeye	ABC	5	Dec-04	1		
		1999 GMC 3/4 ton pickup Truck - Asset #LT 87291P				Buckeye	ABC	5	Dec-04	1		
		2002 Chevy Blazer-Asset # LT 95517P				Buckeye	ABC	5	Dec-04	1		
		2001 Ford F550 Flatbed Truck Asset # LT 95435P				Buckeye	ABC	5	Dec-04	1		
		2000 GMC 1/2 Ton Pickup Truck-Asset #LT 91042P				Buckeye	ABC	5	Dec-04	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
	Ridgecrest Park	Pump House	12000 Ulmerton Rd. Largo 33774		727 588-4851	Sentry	2-A:10 BC	5	Oct.-04	4		
		Chemical Building				Sentry	10-A:60BC	5	Oct.-04	5		
		LT 83684				Amerex Model A500	2-A10-BC	5	Oct.-04	8		
		Metal Storage Building				Adger	ABC	5	Oct.-04	9		
		Maintenance Building - North				Buckeye Fire Equip.	ABC	5	Oct.-04	13		
		Maintenance Building - South				Fire Master	10A:60B:C	5	Oct.-04	15		
		LT90904				Amerex	2A:10-BC	5	Oct.-04	16		
		Belleair Boat Ramp Bait house				Fire Master	2A:10-BC	5	Oct.-04	1		
	Fred Howard Park	Maintenance Closet	1700 Sunset Drive, Tarpon Springs 34689		727 398-3792	Kiddle	ABC	5	Oct.-05	1		
		Maintenance Closet				Amerex	ABC	5	Oct.-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Maintenance - Breaker Box				Amerex	ABC	10	Oct.-05	1		
		Maintenance Area - Sink				Buckeye	ABC	10	Oct.-05	1		
		Between Maintenance Doors				Badgor	ABC	5	Oct.-05	1		
		Fuel pumps				Badgor		5	Oct.-05	1		
		Chemical Bldg.				Amerex		10	Oct.-05	1		
		Trailer - Office				Buckeye		5	Oct.-05	1		
		SW Wall - Craftworker Bldg				Buckeye		10	Oct.-05	1		
		SE Wall - Craftworker Bldg				Buckeye		10	Oct.-05	1		
		Chev Blazer #LT91094				Buckeye		10	Oct.-05	1		
		Ford F150 Asset # 108321				Buckeye		2.5	Oct.-05	1		
		Ford Explorer #LT90829				Buckeye		5	Oct.-05	1		
		Residence Garage				Amerex		10	Oct.-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
	John Chesnut Sr. Park	Ford 3/4 ton 75277P	2200 East Lake Rd., Palm Harbor 34685		727 669-1951	Piper	B	5	Nov. -04	1		
		GMC Pick-up LT91061P				Buckeye	Multi-Purp. Dry Chem A,B,C	10	Nov. -04	1		
		Chemical Storage Bldg.				Buckeye	Purple K Dry Chem B&C	20	Nov. -04			
		Maintenance Bldg #1				Buckeye	Multi-Purp. Dry Chem A,B,C	10	No Tag			
		Maintenance Bldg #1				Ansul	Multi-Purp. Dry Chem A,B,C	10	Nov. -04			

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Maintenance Bldg #2				Kidde	Multi-Purp. Dry Chem A,B,C	10	Nov. -04			
		Maintenance Bldg #2				First Alert	Multi-Purp. Dry Chem A,B,C	10	Nov. -04			
		Maintenance Bldg #2				Buckeye	Multi-Purp. Dry Chem A,B,C	10	Nov. -04			
		Fuel Tanks in Maintenance Yard				Buckeye	Multi-Purp. Dry Chem A,B,C	10	Nov. -04			
		Outside Chemical Storage Building				Buckeye	Purple K Dry Chem B&C	20	Nov. -04			

SECTION E – SPECIFICATIONS PART 'B'- CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Ford F150 #LT 87385				Buckeye	Multi-Purp. Dry Chem A,B,C Type A	5	No Tag			
		Boat				FYR-FYTER	Dry Chem B,C	5	No Tag			
		Spare				County Fire Equip.	Multi-Purp. Dry Chem A,B,C	10	Jul-01			
		Spare				PEMAL MFG CO	Multi-Purp. Dry Chem A,B,C	10	Sep-99			
	Sand Key Park	Indian Rocks Beach Main Room	1060 Gulf Blvd, Clearwater 33767	Ronald Swallows	727 588-4852	Kidde	Dry Chem A,B,C	5	Oct.-04	1		
		Main Shop-South Wall Bldg. 1				Badger	Dry Chem A,B,C	5	Oct.-04	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Main Shop- West Wall Bld. 1				Kidde	Dry Chem A,B,C	5	Oct.- 04	1		
		Main Shop- North Wall Bld. 1				Badger	Dry Chem A,B,C	5	Oct.- 04	1		
		Main Bdg. II Southeast Wall				Kidde	Dry Chem A,B,C	5	Oct.- 04	1		
		Main Bdg. II Southwest Wall				Kidde	Dry Chem A,B,C	5	Oct.- 04	1		
		Chemical Storage Bldg. North Wall				Badger	Dry Chem A,B,C	5	Oct.- 04	1		
		Residence- Kitchen				1st Alert	Dry Chem A,B,C	5	Oct.- 04	1		
		Residence- South post				Kidde	Dry Chem A,B,C	5	Oct.- 04	1		
		Storage Room Residence				Amerex	Dry Chem A,B,C	5	Oct.- 04	1		
		Residence- Laundry Room				Kidde	Dry Chem A,B,C	5	Oct.- 04	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Pole barn-North Pole				Kidde	Dry Chem A,B,C	5	Oct.-04	1		
		Fuel Pumps				Ansul Sentry	Dry Chem A,B,C	5	Oct.-04	1		
		Bath House #1-Main Room				Buckeye	Dry Chem A,B,C	5	Oct.-04	1		
		Bath House #2-Main Room				Buckeye	Dry Chem A,B,C	5	Oct.-04	1		
		Restroom by Shelters-Main Room				Buckeye	Dry Chem A,B,C	5	Oct.-04	1		
		Cab-Ford Flatbed Truck-				Badger	Dry Chem A,B,C	5	Oct.-04	1		
		Cab-Chevy Colorado				Buckeye	Dry Chem A,B,C	5	Oct.-04	1		
		Cab-Jeep				Badger	Dry Chem A,B,C	5	Oct.-04	2		
		Cab-Ford F-250				Kidde	Dry Chem A,B,C	5	Oct.-04	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Cab-GMC Pick Up-				Kidde	Dry Chem A,B,C	5	Oct.-04	1		
		Main. Bldg. II Storage Room				Kidde	Dry Chem A,B,C	5	Oct.-04	1		
		Maint Bld II Storage				Buckeye	Dry Chem A,B,C	5	Oct.-04	1		
		Maint Bld II Storage				Kidde	Dry Chem A,B,C	5	Oct.-04	1		
	Lake Seminole Park	Bldg 1 - Break room	10015 74th Ave, North Seminole 33777	Fred Stager/Roger Overly	727 549-6156	Amerex Corp	Dry Chem A,B,C	5	Oct.-05	1		
		Bldg 1 - SW Exterior				Fire master	Dry Chem A,B,C	5	Oct.-05	1		
		Bldg 1-2nd bay- S				Amerex Corp	Dry Chem A,B,C	5	Oct.-05	1		
		Bldg 2- South - interior				Amerex Corp	Dry Chem A,B,C	5	Oct.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Bldg 2-North - interior				Kidde Corp	Dry Chem A,B,C	5	Oct.-05	1		
		Chemical Bldg S-Entrance				Buckeye	Dry Chem A,B,C	5	Oct.-05	1		
		Polebarn-N post				Buckeye	Dry Chem A,B,C	5	Oct.-05	1		
		Ford F150 toolbox-bed (truck)				Buckeye	Dry Chem A,B,C	5	Oct.-05	1		
		GMC 1500 in cab (truck)				Badger	Dry Chem A,B,C	5	Oct.-05	1		
		Ford F700-toolbox (2 ton truck)				Fire master	Dry Chem A,B,C	5	Oct.-05	1		
		Park Residence				Fire master	Dry Chem A,B,C	5	Oct.-05	1		
		Park Residence				Amerex Corp	Dry Chem A,B,C	5	Oct.-05	1		
	Lake Seminole Nursery	Maintenance Bldg West End	10015 74th Ave, Seminole 33777		727 549-6156	Buckeye	Dry Chem A,B,C	5	Aug.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Maintenance Bldg East End				Buckeye	Dry Chem A,B,C	5	Aug. -05	1		
		Maintenance Bldg Office				Amerex	Dry Chem A,B,C	5	Aug. -05	1		
		Maintenance Bldg Meeting Room				Amerex	Dry Chem A,B,C	5	Aug. -05	1		
		Maintenance Bldg Storage Room				Amerex	Dry Chem A,B,C	5	Aug. -05	1		
		Maintenance Bldg Storage Room - Spare Unit				Fire Master	Dry Chem A,B,C	5	Aug. -05	1		
		Pump House				Kidde	Dry Chem A,B,C	5	Aug. -05	1		
		Lindig Bldg				Flag	Dry Chem A,B,C	5	Aug. -05	1		
		Chemical Bldg				Amerex	Dry Chem A,B,C	5	Aug. -05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		OutsideChemical Bldg				Amerex	Dry Chem A,B,C	5	Aug.-05	1		
		International Tree Spade Truck 90899				Fire Master	Dry Chem A,B,C	5	Aug.-05	1		
		International Tree Spade Truck 87244				Amerex	Dry Chem A,B,C	5	Aug.-05	1		
		Ford Chipper Truck 75360				Pemall	Dry Chem A,B,C	5	Aug.-05	1		
		Ford Chipper Truck 75152				Buckeye	Dry Chem A,B,C	5	Aug.-05	1		
		Bucket Truck 90851				Amerex	Dry Chem A,B,C	5	Aug.-05	1		
		GMC 3/4 Ton Utility Truck 87196				Amerex	Dry Chem A,B,C	5	Aug.-05	1		
		Ford 3/4 Ton Pickup Truck 95783				Amerex	Dry Chem A,B,C	5	Aug.-05	1		
		Ford Kingcab Truck 87177				Amerex	Dry Chem A,B,C	5	Aug.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Club Car Carryall 99499				Kidde	Dry Chem B,C	5	Aug. -05	1		
		Cushman Truckster 89721				Kidde	Dry Chem A,B,C	5	Aug. -05	1		
		Toro Mower 76776				Kidde	Dry Chem A,B,C	5	Aug. -05	1		
		Ford Frontend Loader 64709				Kidde	Dry Chem A,B,C	5	Aug. -05	1		
	Ft.DeSoto Park	North Beach, Aid Station	3500 Pinellas Bayway South Tierra Verde 33715	Geno Green/ James Wilson	727 552-1860 727 552-1862	Sentry	A-B-C	10	Oct. -05	1		
		East Beach, Aid Station				Sentry	A-B-C	10	Oct. -05	1		
		Electrical Shop D-10				Amvex	A-B-C	10	Oct. -05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Utility Shop D-17				Sentry	A-B-C	10	Oct.-05	2		
		Land Maint shop D-4				Amvex	A-B-C	10	Oct.-05	1		
		Plumbers Shop D-12				Kide	A-B-C	10	Oct.-05	1		
		Masonry Shop D-24				Badger	A-B-C	10	Oct.-05	1		
		Life Guard Shop D-13				Amvex	A-B-C	10	Oct.-05	3		
		Carpenter Shop D-6				Sentry	A-B-C	10	Oct.-05	1		
		Chemical Shop D-14				Kidde	A-B-C	10	Oct.-05	1		
		Paint Storage				Sentry	A-B-C	10	Oct.-05	2		
		Paint Shop D-25				Amvex	A-B-C	5	Oct.-05	3		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Receiving & Class Room				Sentry	A-B-C	10	Oct.-05	1		
		Rear Meeting Room				Kidde	A-B-C	10	Oct.-05	1		
		Ice Machine Bldg.				Sentry	A-B-C	10	Oct.-05	2		
		Mechanic Bldg.				Sentry	A-B-C	10	Oct.-05	2		
		Gas Shed				Sentry	A-B-C	10	Oct.-05	2		
		Campground Office				Kidde	A-B-C	10	Oct.-05	2		
		Campground Maint. Shop				Amvex	A-B-C	10	Oct.-05	2		
		Park Headquarters				Sentry	A-B-C	10	Oct.-05	2		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Home D-1				Sentry	A-B-C	5 lb/10 lb	Oct.-05	2		
		Home D-2				Amvex	A-B-C	5 lb/10 lb	Oct.-05	2		
		Q.M. Building				Sentry	A-B-C	10	Oct.-05	1		
	Boca Ciega Millennium Park	Maintenance Bldg.	6990 125th St N, Seminole, 33772	Judy Jarosz	727 588-4882	Buckeye	Dry Chem A,B,C	10	Jul.-05	2		
		Chemical Bldg. (Exterior)				Amerex	Purple K-Dry Chem	20	Jul.-05	1		
		Chemical Bldg. (Interior)				Amerex	Purple K-Dry Chem	2.5	Jul.-05	1		
		Restroom A-Storage area				Buckeye	Dry Chem A,B,C	10	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Restroom B-Storage area				Buckeye	Dry Chem A,B,C	10	Jul.-05	1		
		Restroom C-Storage area				Buckeye	Dry Chem A,B,C	10	Jul.-05	1		
		Restroom D-Storage area				Kidde	Dry Chem A,B,C	10	Jul.-05	1		
		Asset # 91046				Kidde	B,C	5	Jul.-05	1		
		Asset # 91133				Kidde	B,C Dry Chem	10	Jul.-05	1		
		Asset # 90857				Kidde	B,C	10	Jul.-05	1		
		Asset # 95777				Kidde	A,B,C	10	Jul.-05	1		
		Asset # 95488				Full Security	B,C	10	Jul.-05	1		
		Asset # 95488				Full Security	B,C	10	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
	Sawgrass Lake Park	EEC Hallway	7400 25th St N, St. Petersburg 33702		727 217-7256	County Fire Eqipt.	A,B,C	5	Jul-05	1		
		EEC Laboratory				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		EEC Class Room				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		Chemical Building				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		Supervisor's Residence				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		Pole Barn				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		Pole Barn				County Fire Eqipt.	A,B,C	5	Jul-05	1		
		Shop Bay Door				County Fire Eqipt.	A,B,C	5	Jul-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Shop Bay Door				County Fire Equipt.	A,B,C	5	Jul-05	1		
		Shop Window				County Fire Equipt.	A,B,C	5	Jul-05	1		
		Eye Wash Station				County Fire Equipt.	A,B,C	5	Jul-05	1		
		GMC 83893 LT				County Fire Equipt.	A,B,C	5	Jul-05	1		
		GMC 83726 LT				County Fire Equipt.	A,B,C	5	Jul-05	1		
		GMC 91049 LT				County Fire Equipt.	A,B,C	5	Jul-05	1		
	Treasure Island Beach access	Restroom storage closet	10460 Gulf Blvd, Treasure Island, FL			Buckeye	A,B,C	5	Sep-05	1		
	Park Blvd. Boat ramp	Restroom storage closet	18651 Gulf Blvd. Indian Shores, FL			Kidde	A,B,C	5	Sep-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		LT-91035 GMC				Kidde	A,B,C	5	Sep-05	1		
		Supervisor's Residence/ Kitchen				Badgers	A,B,C	5	Sep-05	1		
		Next to fuel pumps				Kidde	Combustibles	5	Sep-05	1		
		North/wall maintenance shop				Kidde	A,B,C	5	Sep-05	1		
		East/wall maintenance shop				Kidde	A,B,C	5	Sep-05	1		
		Chemical				Kidde	A,B,C	5	Sep-05	1		
		Irrigation building #1				Badger	A,B,C	5	Sep-05	1		
		Irrigation building #2				Kidde	A,B,C	5	Sep-05	1		
		Pole Shed				Badger	Dry Chem	5	Sep-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
St. Petersburg-Clearwater International Airport	Airport Fire Department	Fire Truck	4660 General Howard Drive Clearwater, FL 33762	Chief Rauscher	727 453-7823	Amerex	D	5	Feb-05.	2		
		Fire Truck				Ansul	D	5	Feb-05.	1		
		Fire Truck				Ansul	BC	5	Feb-05.	1		
		Office				Buckeye	BC	5	Feb-05.	3		
		Fire Department				Kidde	ABC	5	Feb-05.	1		
		Fire Department				Amerex	ABC	5	Feb-05.	1		
St. Petersburg-Clearwater International Airport	Airport Terminal		14700 Terminal Blvd, Ste 221, Clearwater, FL 33762	Chief Rauscher	727 453-7823	Amerex	ABC	5	Feb-05.	27		
						Buckeye	BC	5	Feb-05.	10		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Buckeye	ABC	5	Feb-05.	2		
						Kidde	ABC	5	Feb-05.	12		
						Kidde	ABC	5	Feb-05.	2		
						Buckeye	BC	5	Feb-05.	2 halon		
St. Petersburg-Clearwater International Airport	Airport Facilities	Facilities	14700 Terminal Blvd, Ste 221, Clearwater, FL 33762	Chief Rauscher	727 453-7823	Badger	(CO2 )	5	Feb-05.	2		
		Facilities				Amerex	ABC	5	Feb-05.	2		
		Facilities				Kidde	ABC	5	Feb-05.	1		
		Facilities				Kidde	ABC	5	Feb-05.	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Facilities				Sentry	ABC	5	Feb-05.	1		
		Facilities				Buckeye	BC	5	Feb-05.	1		
		Facilities				Badger	ABC	5	Feb-05.	2		
	(Vehicles)	Facilities	(Vehicles)			Amerex	BC	5	Feb-05.	7		
St. Petersburg-Clearwater International Airport	Flight Services Building	Flight Services	14474 Airport Parkway, Clearwater, FL 33762	Chief Rauscher	727 453-7823	Badger	C02	5	Feb-05.	4		
		Flight Services				Amerex	ABC	5	Feb-05.	2		
		Flight Services				Buckeye	Halon	5	Feb-05.	1		
		Flight Services				Buckeye	ABC	5	Feb-05.	2		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Flight Services				Badger	ABC	5	Feb-05.	2		
Highway	Mosquito Control	Build 1	4100 - 118 Avenue, N., Clearwater, FL 33762	Chief Rauscher	727 464-7503	Buckeye	ABC	5	Dec-05	3		
		Build 1				Amerex	ABC	5	Dec-05	1		
		Guard Shack				Buckeye	ABC	5	Dec-05	1		
		Build 3				Buckeye	ABC	5	Dec-05	3		
		Build 3				Badger	ABC	5	Dec-05	1		
		Build 6				Badger	ABC	5	Dec-05	1		
		Build 6				Buckeye	ABC	5	Dec-05	2		
		Build 6				Buckeye	ABC	5	Dec-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Build 7				Buckeye	ABC	5	Dec-05	3		
		Build 9				Amerex	ABC	5	Dec-05	1		
		Build 9				Buckeye	ABC	5	Dec-05	2		
		Build 9				Buckeye	ABC	5	Dec-05	1		
		Build 9				Badger	ABC	5	Dec-05	1		
		Build 10				Amerex	ABC	5	Dec-05	2		
		Build 10				Amerex	ABC	5	Dec-05	1		
		Build 10				Amerex	ABC	5	Dec-05	3		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Build 11				Buckeye	ABC	5	Dec-05	2		
		Build 11				Amerex	ABC	5	Dec-05	2		
		Build 11				Buckeye	ABC	5	Dec-05	2		
		Build 11				Buckeye	ABC	5	Dec-05	2		
		Hanger				Badger	ABC	5	Dec-05	1		
		Hanger				Kidde	ABC	5	Dec-05	2		
		Hanger				Buckeye	ABC	5	Dec-05	2		
		IT				Buckeye	ABC	5	Dec-05	4		
		Fuel Island				Buckeye	ABC	5	Dec-05	2		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Forklift				Amerex	ABC	5	Dec-05	1		
		Trucks				Buckeye	ABC	5	Dec-05	57		
	Signal Shop	Tech Bench Area Bldg 6	22211 US 19 N, Clearwater, FL 34655 - Bldg 6	Roman Archipowicz	727 464-8987	Amerex	ABC	5	Jan-05	1		
		Back Shop - Side Door Bldg 6				Kidde	ABC	5	Jan-05	1		
		Rear Shop Stockroom Bldg 6				Kidde	ABC	5	Jan-05	1		
		Rear Shop Stockroom Bldg 6				Amerex	ABC	5	Jan-05	2		
		Rear Shop Stockroom Bldg 6				Buckeye	ABC	5	Jan-05	1		
		Rear Shop Stockroom Bldg 6				Sentry	ABC	5	Jan-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Upstairs Warehouse Bldg 6				Sentry	ABC	5	Jan-05	1		
	Signal Shop Vehicles	2004 Chevy P/U (George)				Kidde	ABC	5	Jan-05	1		
		1995 Altec Bucket (T.Topa)				Amerex	ABC	5				
		2000 Chevy Blazer (Jeff)				Kidde	ABC	5				
		1997 Ford Explorer (J.Amiro)				Amerex	ABC	5				
		1996 P/U 4x4 (Shop)				Amerex	ABC	5				
		1998 Int. Lift (T. Castro)				Amerex	ABC	5				
		1998 Int. Lift (Shop)				Amerex	ABC	5				

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		2000 1 Ton Pick-up (Shop)				Buckeye	ABC	5				
		2000 Stand-by (S. Yeatman)				Amerex	ABC	5				
		2000 Int. Bucket (Rupert)				Amerex	ABC	5				
		Enclosed tandem trailer (Shop)				Buckeye	ABC	5				
		2001 Int. 4x4 Bucket (Oswald)				Amerex	ABC	5				
		2001 Ford P/U xlt (John L)				Kidde	ABC	5				
		2003 Ford Bucket Van (Vince)				Amerex	ABC	5				
		2003 Ford Bucket Van (Tyson)				Amerex	ABC	5				

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		2003 Intl/Altec (Dave)				Buckeye	ABC	5				
		2003 Intl/Altec (Klemm)				Buckeye	ABC	5				
	Stormwater	Inside Trailer	4550 126th Ave N. Clearwater, FL 33762	Joanne Benedict	727 464-5916	Fire master	ABC	5	Jul.-05	1		
		On Wall - At end of Bldg.				Fire master	ABC	5	Jul.-05	1		
		On Wall outside breakroom				Fire master	ABC	5	Jul.-05	1		
		West wall of concrete wall by DBI doors				Badger	ABC	5	Jul.-05	1		
		Center Beam - East side of concrete wall.				Buckeye	ABC	5	Jul.-05	1		
		Center Beam - south east side of concrete wall.				Badger	ABC	5	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		S.E. Beam in dump truck bay				Badger	ABC	5	Jul.-05	1		
		Front of wall by fuel tank				Buckeye	ABC	5	Jul.-05	1		
		E. wall in back bldg by overhead door				Buckeye	ABC	5	Jul.-05	1		
		W. wall in back bldg by electric box				Buckeye	ABC	5	Jul.-05	1		
		On Beam in Map Room				Fire master	ABC	5	Jul.-05	1		
		Center Beam, next to AEO desks				Badger	ABC	5	Jul.-05	1		
		Upstairs by closet & copy machine				Fire master	ABC	5	Jul.-05	1		
		On Equip.door in caged area				Buckeye	ABC	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		By upstairs bath room/men				Fire master	ABC	5	Jul.-05	1		
		In HT 83686				Amerex	ABC	5	Jul.-05	1		
		In LT 83732				Amerex	ABC	5	Jul.-05	1		
		In LT 90867				Badger	ABC	5	Jul.-05	1		
		In LT 90868				Kidde	ABC	5	Jul.-05	1		
		In LT 91000				Amerex	ABC	5	Jul.-05	1		
		In LT 83849				Ind.Fire & Safety	ABC	5	Jul.-05	1		
		In LT 83897				Amerex	ABC	5	Jul.-05	1		
		In LT 87003				Ind.Fire & Safety	ABC	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		In LT 90941				Buckeye	ABC	5	Jul.-05	1		
		In LT 90942				Ind.Fire & Safety	ABC	5	Jul.-05	1		
		In LT 90947				Buckeye	ABC	5	Jul.-05	1		
		In LT 75376				Buckeye	ABC	5	Jul.-05	1		
		In HT 77304				Underwriters	ABC	5	Jul.-05	1		
		In HT 77369				Kidde	ABC	5	Jul.-05	1		
		In HT 83792				Sentry	ABC	5	Jul.-05	1		
		In HT 83809				Kidde	ABC	5	Jul.-05	1		
		In HT 90932				Badger	ABC	5	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		In Sweeper 95427				Sentry	ABC	5	Jul.-05	1		
		In Sweeper 95439				Buckeye	ABC	5	Jul.-05	1		
		In Sweeper 95461				Buckeye	ABC	5	Jul.-05	1		
		In Vactor 90971				Buckeye	ABC	5	Jul.-05	1		
		In Vactor 95512				Amerex	ABC	5	Jul.-05	1		
		In Vactor 95513				Badger	ABC	5	Jul.-05	1		
		In LT 95672				Buckeye	ABC	5	Jul.-05	1		
		In LT 87369				Amerex	ABC	5	Jul.-05	1		
		In LT 90812				Amerex	ABC	5	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		In HT 75153				Amerex	ABC	5	Jul.-05	1		
		In LT 95609				Amerex	ABC	5	Jul.-05	1		
		Spare-in metal cabinet				Buckeye	ABC	5	Jul.-05	1		
		In LT108249				Buckeye	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Badger	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Buckeye	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Buckeye	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Sentry	ABC	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Spare in metal cabinet in caged area				Amerex	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Kidde	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Amerex	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Sentry	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Buckeye	ABC	5	Jul.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Spare in metal cabinet in caged area				Sentry	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Kidde	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Amerex	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Firemaster	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Buckeye	ABC	5	Jul.-05	1		
		Spare in metal cabinet in caged area				Fire master	ABC	5	Jul.-05	1		
		In Sweeper 108203				Kidde	ABC	5	Jul.-05	1		
		In Sweeper 108204				Fire master	ABC	5	Jul.-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		In metal cabinet in caged area - Not Using				Flag Fire Equip.	ABC	5	Jul-05	1		
	Stormwater Admin.	Inside front door	4051 118th Ave N, Clearwater, FL 33762	Joanne Benedict	727 464-5916	Firemaster	ABC	5	Jul-05	1		
		Top of the steps				Buckeye	ABC	5	Jul-05	1		
		By back door - west end				Amerex	ABC	5	Jul-05	1		
		File Room				Amerex	ABC	5	Jul-05	1		
		South Garage Door				Buckeye	ABC	5	Jul-05	1		
		Kitchen				Kidde	ABC	5	Jul-05	1		
		Upstairs Hallway				Buckeye	ABC	5	Jul-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
Public Works	Survey & Mapping	Various Survey Vehicles	22211 U.S. Hwy. 19, N. Building #16, Clearwater, FL 33765.	David Miles	727 464-8904	Amerex	ABC	5	May-05	15		
		Building #16 - Survey at the following locations: One at center of building. One at West side entry. One at West side of Garage area. One at East side of garage area.				Amerex	ABC	10	May-05	5		
Environmental Management	Adm.	512 Bldg, & 512 Vehicles Hallway, 1st floor o/s Rm 111	512 S. Ft. Harrison Ave., Clearwater, FL 33756	Jackie Trainer	727 464-4761	Buckeye	ABC	5	Aug-05	1		
		512 Bldg. & 512 Vehicles Stair well, 1st floor west				Buckeye	ABC	5	Aug-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		512 Bldg. & 512 VehiclesHallway, 2nd floor o/s rm 207				Buckeye	ABC	5	Aug-05	1		
		512 Bldg. & 512 VehiclesHallway, 2nd floor near elevator				Buckeye	ABC	5	Aug-05	1		
		512 Bldg. & 512 Vehicles 2nd floor o/s rm 210				Buckeye	ABC	5	Aug-05	1		
	W & N	Blazer LT 91157				Piper	A-II,B-1	5	Aug-05	1		
		Blazer LT 95641				Badger	A-II,B-1	5	Aug-05	1		
		Ford Van LT 77238				Piper	A-II,B-1	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Buckeye	ABC	5	Aug-05	1		
		Code Vehicle				Kidde	ABC	5	Aug-05	1		
		Code Vehicle				Kidde	ABC	5	Aug-05	1		
		Code Vehicle				Kidde	ABC	5	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Code Vehicle				Ansul	ABC	10	Aug-05	1		
		Code Vehicle				Badger	ABC	10	Aug-05	1		
		Explorer LT 108117				Fire master	ABC	5	Aug-05	1		
		Blazer LT 91138				Fire master	ABC	5	Aug-05	1		
	Water Resources - Garage and Vehicles	Garage	300 South Garden Avenue, Clearwater, FL 33756	Kelli Hammer Levy	727 464-4761	Kidde	ABC	5	Aug-05	1		
		Van				Kidde/Buckeye	ABC	2.5	N/A	2		
		Boat-Tunnel Jon				Amerex	ABC	2.5	Oct-05	1		
		Boat-Mako				Kidde	ABC	2.5	N/A	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Truck F350				Kidde	ABC	2.5	N/A	1		
		Truck F150				Ansul	A-II,B,CII	10	Apr-05	1		
		Jeep Cherokee				Fire master	ABC	5	Apr-00	1		
		Blazer				Buckeye	ABC	10	Apr-05	1		
		Boat-Privateer				Kidde	ABC	2.5	N/A	1		
		Van Aerostar #77380				Amerex	ABC	5	Dec-99	1		
	Weedon Isle Preserve	Down stairs kitchen	1500 Weedon Isle Drive NE, St. Petersburg, FL 33702	Keith Thompson	727 453-6515	J.L. Indust.	ABC		Jul.-05			
		Hallway in lobby area				J.L. Indust.	ABC		Jul.-05			

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		In the class room				J.L. Indust.	ABC		Jul.-05			
		Behind Laura's desk				J.L. Industries	ABC		Jul.-05			
		In the server room				Amerex	Halotron		Jul.-05			
		Shop area				Amerex	ABC		Jul.-05			
		Shop break room				Amerex	ABC		Jul.-05			
		On Air compressor door				Buckeye	ABC		Jul.-05			
		In Pole barn area				Buckeye	ABC		Jul.-05			
		Entrance station				Buckeye	ABC		Jul.-05			

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Pier restroom				Buckeye	ABC		Jul.-05			
		House kitchen				Buckeye	ABC		Unk now n			
		House garage				Amerex	ABC		Unk now n			
		GMC Truck				First Alert	BC		Jul.-05			
		Ford Truck				First Alert	BC		Ne eds new one			
		Keith's Jeep				First Alert	BC					
	Brooker Creek Preserve	Hallways in Modular	3940 Keystone Road, Tarpon Springs, FL 34688	Claudia Lewis	727 453-6800	Buckeye	Multi Purp. Dry Chem		Jul.-05	4		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Barn/Tall Pines				Buckeye	Dry Chem		Jul.-05	1		
		Old Fire room/Tall Pines				Buckeye	Dry Chem		Jul.-05	1		
		Little Willy fire truck				Amerex	Dry Chem		Aug.-05	1		
		Kawasaki Mule				Buckeye	Dry Chem		Aug.-05	1		
		Pole Barn Shop				Fire Master	Dry Chem		Aug.-05	1		
		Pole Barn Shop				Amerex	Dry Chem		Aug.-05	1		
		Gas Shed				Buckeye	Dry Chem		Aug.-05	1		
		Research Garage				Amerex	Dry Chem		Aug.-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Research Garage				Buckeye	Dry Chem		Aug. -05	1		
		Research station inside				Buckeye	Dry Chem		Aug. -05	3		
		Jeep 87368				Buckeye	Dry Chem		Aug. -05	1		
		Storage tent				Buckeye	Dry Chem		Aug. -05	1		
		Storage tent				Badger	Dry Chem		Aug. -05	1		
		Bldg 1 Mechanical room				Amerex	Dry Chem		Aug. -05	1		
		Bldg 1 Kitchen				Amerex	Dry Chem		Aug. -05	1		
		Bldg 1 Entrance area				Amerex	Dry Chem		Aug. -05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Bldg 2 Office area				Amerex	Dry Chem		Aug. -05	1		
		Bldg 2 Public entrance				Amerex	Dry Chem		Aug. -05	1		
		Bldg 2 Exhibit hall				Amerex	Dry Chem		Aug. -05	1		
		Bldg 2 Back Mech. room				Amerex	Dry Chem		Aug. -05	1		
		Bldg 3 Mechanical room				Amerex	Dry Chem		Aug. -05	1		
		Bldg 3 Classroom				Amerex	Dry Chem		Aug. -05	2		
		Bldg 3 Entrance way				Amerex	Dry Chem		Aug. -05	1		
		Admin/Scott Coulter office				Buckeye	Dry Chem			1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Admin/Scott Coulter office				Fire Master	Dry Chem			1		
	Air Quality Building	Room 101	300 South Garden Avenue, Clearwater, FL 33756		727 464-4761	Kidde	ABC	5	May-05	1		
		Hall 114				Kidde	ABC	5	May-05	1		
		Room 116				Buckeye	ABC	5	May-05	1		
		Hall 119				Kidde	ABC	5	May-05	1		
		Hall 124				Amerex	ABC	5	May-05	1		
		Hall 132				Kidde	ABC	5	May-05	1		
		Hall 154				Kidde	ABC	5	May-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Hall 165				Amerex	ABC	10	May-05	1		
		Hall 182				Kidde	ABC	5	May-05	1		
	Vehicles	CA 83837				Amerex	ABC	6	Jun-05	1		
		LT 83894				Buckeye	ABC	5	Jun-05	1		
		CA 87153				Buckeye	ABC	5	Jun-05	1		
		CA 87389				Buckeye	ABC	5	Jun-05	1		
		CA 87392				Amerex	ABC	6	Jun-05	1		
		LT 90824				Buckeye	ABC	5	Jun-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		LT 90825				Buckeye	ABC	5	Jun-05	1		
		LT 91040				Amerex	ABC	6	Jun-05	1		
		CA 91098				Amerex	ABC	6	Jun-05	1		
		CA 91100				Amerex	ABC	6	Jun-05	1		
	Air Monitoring Sites	Azalea Park				Kidde	ABC	10	Jun-05	1		
		Clearwater				Kidde	ABC	10	Jun-05	1		
		Curlew				Buckeye	ABC	5	Jun-05	1		
		Derby Lane				Kidde	ABC	10	Jun-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		East Lake				Amerex	ABC	10	Jun-05	1		
		Gateway				Kidde	ABC	10	Jun-05	1		
		Oakwood				Buckeye	ABC	5	Jun-05	1		
		Resource Recovery				Kidde	ABC	10	Jun-05	1		
		Skyview				Amerex	ABC	5	Jun-05	1		
		Tyrone Square				Amerex	ABC	10	Jun-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
Young - Rainey Star Center	100 Building	100 Building	7887 Bryan Dairy Rd. Ste 120, Largo, FL 33777	Jeff Sibbach	727 549-6644	Amerex	CO2	20	Oct-04	1		
						"	CO2	50	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	ABC	20	"	1		
						"	CO2	20	"	1		
						"	WH	150	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	WH	150	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	50	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						SENTRY	ABC	5	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						Sentry	ABC	5	"	1		
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	50	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	50	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	50	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	ABC	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						Sentry	ABC	5	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Sentry	ABC	5	"	1		
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART 'B' - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	ABC	20	"	1		
						"	ABC	20	"	1		
						"	ABC	20	"	1		
						"	ABC	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	ABC	20	"	1		
						"	CO2	20	"	1		
						"	ABC	20	"	1		
						"	ABC	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		
						"	CO2	20	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	CO2	20	"	1		
						"	CO2	20	"	1		
Highway District	Main Complex	Upstairs / Top of Stair Well	22211 US Highway 19 N, Clearwater, FL 33765	Sue Bartlett	727 464-8900	Amerex	ABC	2.5		3		
		Upstairs / Top of Stair Well				Piper	ABC	5		13		
		Upstairs / Conference Room				Amerex	ABC	5		1		
		Operator's Garage Inside on walls				Amerex	ABC	10		4		
		Outside Main Building on Westside					ABC	10		2		
		Inside Main Building by Counter & N - S Exit Doors					ABC	10		3		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Breakroom by Storekeeper's Office				Amerex	ABC	10		1		
		North Hallway inside Office Area at N Exit Door					ABC	10		1		
		Crew Cabs					ABC	10		20		
		Heavy Equipment & Dump Trucks					ABC	5		15		
Highway Dept	Southwest	Vehicle 108245	11650, 131st St N., Seminole, FL 34644	David Benedict	727 593-0205	Fire Buckeye	ABC	5	Jan-05	1		
		108242				"	ABC	5	"	1		
		87374				"	ABC	2	"	1		
		95674				"	ABC	5	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		95727				Buckeye	ABC	5	"	1		
		90980				"	ABC	5	"	1		
		90981				"	ABC	5	"	1		
		90985				"	ABC	5	"	1		
		95723				"	ABC	5	"	1		
		83850				"	ABC	5	"	1		
		75189				"	ABC	2/3	"	1		
		91066				"	ABC	5	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		75378				Buckeye	ABC	5	"	1		
		90969				"	ABC	2/3	"	1		
		74369				"	ABC	5	"	1		
		91078				"	ABC	5	"	1		
		69140				"	ABC	2/3	"	1		
		90931				"	ABC	5	"	1		
		91069				"	ABC	5	"	1		
		61592				"	ABC	5	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		75377				Buckeye	ABC	5	"	1		
		74292				"	ABC	5	"	1		
		74296				"	ABC	5	"	1		
		108140				"	ABC	5	"	1		
		108139				"	ABC	5	"	1		
		75184				"	ABC	5	"	1		
		95415				"	ABC	5	"	1		
		77294				"	ABC	5	"	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Spare				Buckeye	ABC	10_/_5_	"	1		
		"				"	ABC	5_/_1_0	"	1		
	Southwest	Building 1 - Location 1		Ray Daniels	727 593-6161	"	ABC	5	"	1		
		Location 2				"	ABC	5	"	1		
		Location 3				"	ABC	10	"	1		
		Location 4				"	ABC	10	"	1		
		Location 5				"	ABC	10	"	1		
		Location 6				"	ABC	10	"	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Location 7				Buckeye	ABC	10	"	1		
		Location 8				"	ABC	10	"	1		
		Location 9				"	ABC	10	"	1		
		Location 10				"	ABC	5	"	1		
		Location 11				"	ABC	10	"	1		
		Location 12				"	ABC	5	"	1		
		Building 13				"	ABC	5	"	1		
		Building 14				"	ABC	5	"	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
Highway Dept	Walsingham Park	Main Office Building	10601 125th Street North, Largo, FL	Steve Krok	727 549-6142	Amerex	ABC	10	Aug-05	1		
		Main Office Building				Fire Master	ABC	10	Aug-05	1		
		Chemical Shed				Ansul Sentry	ABC	10	Aug-05	1		
		Fuel Pumps				Buckeye	ABC	8	Aug-05	1		
		Wash Rack				Buckeye	ABC	8	Aug-05	1		
		Equipment Shed				Buckeye	ABC	4	Aug-05	1		
		Back Hoe HE-77160				Buckeye	ABC	3	Aug-05	1		
		Equipment Shed				Fire Control	ABC	3	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Equipment Shed				Adger	ABC	5	Aug-05	1		
		Ford LT-95670				Kidde	ABC	3	Aug-05	1		
		Chevy LT-95640				Kidde	BC	3	Aug-05	1		
		GMC LT-83742				Kidde	BC	3	Aug-05	1		
		Ford Slope Mower HE-77203				Kidde	BC	3	Aug-05	1		
		Extra in Steve's Office				Kidde	BC	3	Aug-05	1		
	Southeast District	108248	11650 131st St North, Seminole, FL 34644.	Dennis Grizzell	727 582-7783	Buckeye		10	Aug-05	1		
		95424				Badger		10	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		87122				Buckeye		10	Aug-05	1		
		90809				Badger		10	Aug-05	1		
		83661				Buckeye		5	Aug-05	1		
		108165				Buckeye		5	Aug-05	1		
		87151				Fire Master		5	Aug-05	1		
		83831				Buckeye		5	Aug-05	1		
		83851				Fire Master		5	Aug-05	1		
		87229				Buckeye		1 & 5	Aug-05	2		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		69135				Buckeye & Amerex		1 & 10	Aug-05	2		
		75184				Buckeye		10	Aug-05	1		
		74399				Buckeye		10	Aug-05	1		
		74388				Buckeye		10	Aug-05	1		
		83750				Buckeye		10	Aug-05	1		
		74216				Kidde		5	Aug-05	1		
		83786				Buckeye		10	Aug-05	1		
		90979				Amerex		10	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		90978				Buckeye		5	Aug-05	1		
		95729				Fire Master		10	Aug-05	1		
		83802				Buckeye		5	Aug-05	1		
		75350				Buckeye		5	Aug-05	1		
		91083				Badger		5	Aug-05	1		
		91079				Amerex		5	Aug-05	1		
		91072				Amerex		10	Aug-05	1		
		91068				Buckeye		5	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		90929				Buckeye		5	Aug-05	1		
		95716				Badger		5	Aug-05	1		
		75375				Kidde		5	Aug-05	1		
		Building #A				Buckeye & Amerex		10	Aug-05	3		
		Building #B				Buckeye & Fire Master			Aug-05	2		
		Building #C				Badger		10	Aug-05	1		
		Building #D				Amerex		10	Aug-05	1		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
Highway Dept	Fleet Vehicles		22211 US Highway 19 N, Clearwater, FL 33765	Sue Bartlett	727 464-8900	Buckeye	ABC	5	Dec-02	10		
						Amerex	ABC	5	Dec-02	18		
						Buckeye	ABC	8	Dec-02	7		
						Buckeye	ABC	2.5	Dec-02	3		
						Badger	ABC	15	Dec-02	1		
						Kidde	ABC	5	Dec-02	9		
						Amerex	ABC	10	Dec-02	9		
						Badger	ABC	5	Dec-02	3		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Sentry	ABC	5	Dec-02	4		
						Kidde	ABC	2	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Sentry	ABC	2.5	Dec-02	2		
						Fire master	ABC	8	Dec-02	1		
						Meterol	ABC	5	Dec-02	2		
						Fire master	ABC	5	Dec-02	1		
						Amerex	ABC	3	Dec-02	2		

SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	ABC	8	Dec-02	2		
						Amerex	ABC	10	Dec-02	1		
						Buckeye	ABC	10	Dec-02	1		
Highway Dept Complex Buildings.	Fleet Maint	Fleet Maint. US 19 - Bldg 1	22211 US Highway 19 N, Clearwater, FL 33765	Sue Bartlett	727 464-8900	Kidde	ABC	10	Dec-02	1		
						Buckeye	ABC	10	Dec-02	1		
						Sentry	ABC	10	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Fire master	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
	Warehouse	Warehouse - Bldg 2				Buckeye	ABC	5	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
						Fire master	ABC	5	Dec-02	1		
						Buckeye	ABC	5	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Fire master	ABC	5	Dec-02	1		
						Fire master	ABC	5	Dec-02	1		
		Storage Bldg (N of Admin Bldg 3)	Storage Bldg (N of Admin Bldg 3)			Fire master	ABC	5	Dec-02	1		
			Storage Bldg (N of Admin Bldg 3)			Fire master	ABC	10	Dec-02	1		
		Administration - Bldg 4	Administration - Bldg 4			Amerex	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Kidde	ABC	10	Dec-02	1		
						Sentry	BC	5	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Sentry	ABC	5	Dec-02	1		
		Sign Shop - Bldg 5				Sentry	ABC	5	Dec-02	1		
						Sentry	ABC	5	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Buckeye	ABC	10	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Buckeye	ABC	5	Dec-02	1		
						Sentry	ABC	5	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	ABC	5	Dec-02	1		
		Traffic / Signal - Bldg 6				Amerex	ABC	5	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
						Sentry	ABC	10	Dec-02	1		
						Sentry	ABC	10	Dec-02	1		
		Paint Storage Building 7				Amerex	ABC	5	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Guard Shack / Leonard's Office - Bldg.8				Fire master	ABC	10	Dec-02	1		
						Sentry	ABC	10	Jan-01	1		
		Safety Bldg.#9 - (N of Fleet Building)				Amerex	ABC	10	Nov-01	1		
						Kidde	ABC	10	Oct-92	1		
						Fire master	ABC	10	Nov-01	1		
						Sentry	ABC	5	Oct-01	1		
						Kidde	ABC	10	Nov-01	1		
						Amerex	ABC	10	Nov-01	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Amerex	ABC	10	Nov-01	1		
		Traffic Engineering - Bldg. 10				Kidde	ABC	5	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
						Sentry	BC	5	Dec-02	1		
						Sentry	ABC	10	Dec-02	1		
						Badger	ABC	5	Dec-02	1		
		Break Room - Bldg 15				Fire master	ABC	10	Sep-99	1		
						Badger	ABC	5	Sep-99	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Open Paint Storage - Bldg 17				Kidde	ABC	10	Dec-02	1		
		Fuel Islands - Bldg 18				Amerex	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
		Countywide Mowing Trailers - Bldg 22				Amerex	ABC	5	Dec-02	1		
						Badger	ABC	5	Dec-02	1		
						Badger	ABC	5	Dec-02	1		
						Badger	ABC	5	Dec-02	1		
		West Equipment Bldg CWM - Bldg 21W				Kidde	ABC	5	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Kidde	ABC	5	Dec-02	1		
		East Equipment Bldg CWM - Bldg 21E				Kidde	ABC	5	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
		Warehouse - Bldg. 21 Whs.				Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
						Kidde	ABC	10	Dec-02	1		
						Kidde	ABC	10	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Fire master	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		
						Amerex	ABC	10	Dec-02	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
						Kidde	ABC	5	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
						Kidde	ABC	5	Dec-02	1		
Utilities / Solid Waste	Solid Waste Operations - Scale Houses	Administration , Conference Room, left of entry	3100 114th Avenue North, St. Petersburg, FL 33716	Ken Holdernes	727 464-7732	Amerex	Dry Chem	10	Jan-05	1		
		Break Room - Back wall				Amerex	Dry Chem	5	Jan-05	1		
		Scales # 1& # 2. Rear Door, right of entry				Buckeye	Dry Chem	10	Jan-05	1		
		Scales # 1& # 2. Rear Door, right of entry					Dry Chem	3A:40BC	Jan-05	1		
		Scale # 3. Rear Door, right of entry				Buckeye	Dry Chem	16	Jan-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Scale # 3 Rear Door, right of entry				Buckeye	Dry Chem	5	Jan- 05	1		
		Scale # 4 Rear Door, left of entry				Amerex	Dry Chem	5	Jan- 05	1		
		UPS Room				Buckeye	CO2	5	Jan- 05	1		
		Emergency Generator Room, wall, right of entry				Kidde	Dry Chem	3A:4 0BC	Jan- 05	1		
		Emergency Generator Room, back wall on left					Dry Chem	3A:4 0BC	Jan- 05	1		
		Emergency Generator Room, back wall on right				Kidde	Dry Chem	16	Jan- 05	1		
	Reef Program	Sand Key Office				Buckeye	ABC	3	Jan- 05	1		
		20' C Hawk Boat					ABC	3	Jan- 05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Crane				Kidde	ABC	3	Jan-05	1		
		Tool Shed				Kidde	ABC	3	Jan-05	1		
		Suburban				Amerex	ABC	10	Jan-05	1		
		Pilot House				Kidde	ABC	3	Jan-05	1		
		Crews Qtrs.				Amerex	ABC	20	Jan-05	1		
		Engineering Spaces				Buckeye	ABC	20	Jan-05	1		
		Engineering Spaces				Buckeye	ABC	20	Jan-05	1		
Utilities - Branch Services	Customer Services	Palm Harbor - Back Door	2431 Tampa Rd. Palm Harbor, FL 34683	Vincent Colucci	727 724-1576	Buckeye	ABC	5	Sep-04	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Breakroom				Badger	ABC	5	Sep-04	1		
	Customer Services	Seminole - Office - Drive thru	8202-113th Street - Seminole, Florida 33772	Art Wilson	727 549-6089	Buckeye	Dry Chem	3A4 OBC	Jul-04	1		
		Office - Lobby				Buckeye	Dry Chem	3A4 OBC	Jul-04	1		
Utilities	Fac Mgmt Security	1st floor entrance	14 S. Ft. Harrison, Clearwater, FL 33756	Al Bruno	409-4226	Amerex	ABC	10	Aug-05	1		
		1st floor Pride & Print				Amerex	ABC	10	Aug-05	1		
		1st floor NW Customer Serv.				Amerex	ABC	10	Aug-05	1		
		2nd floor South				Sentry	ABC	10	Aug-05	1		
		2nd floor North				Amerex	Halon	8	Aug-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		3rd floor IT				Amerex	ABC	10	Aug-05	1		
		4th floor lobby				Amerex	ABC	10	Aug-05	1		
		4th floor hallway				Amerex	ABC	10	Aug-05	1		
		4th floor conservation resources				Amerex	ABC	10	Aug-05	1		
		4th floor meeting room				Amerex	ABC	10	Aug-05	1		
		5th floor lobby				Amerex	ABC	10	Aug-05	1		
		5th floor Finance				Amerex	ABC	10	Aug-05	1		
		5th floor Payroll				Amerex	ABC	10	Aug-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		6th floor Lobby				Amerex	ABC	10	Aug-05	1		
		6th floor break room				Amerex	ABC	8	Aug-05	1		
		6th floor Engineering				Amerex	ABC	10	Aug-05	1		
		6th floor N. Hallway				Amerex	ABC	8	Aug-05	1		
		Penthouse Chiller room				Fire master	ABC	10	Aug-05	1		
		Penthouse Elevator room				Amerex	ABC	8	Aug-05	1		
		Penthouse Air Handler room				Buckeye	BC	10	Aug-05	1		
Utilities	South Cross Water Reclaim.	South Cross - general location (I.e., vehicle, office, warehouse	7401 54th Ave. North, St. Petersburg, FL	Jim Delaney	727 580-7000							

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		LT-87001				Amerex	ABC	6	Feb-05	1		
		LT-83899				Amerex	ABC	5				
		LT-69106				Amerex	ABC	10	Feb-05	1		
		HT-90934				Fire master	ABC	10	Feb-05	1		
		HT-61551				Fire master	ABC	10	Feb-05	1		
		HT-61551				Fire master	ABC	10	Feb-05	1		
		HT-90936				Buckeye	ABC	10	Feb-05	1		
		LT-83898				Amerex	ABC	10	Feb-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		LT87002				Amerex	ABC	5	Feb-05	1		
		LT-47944				Fire master	ABC	10	Feb-05	1		
		LT-77200				Amerex	ABC	10	Feb-05	1		
		HT-77297				First Alert	ABC	10	Feb-05	1		
		HT-90938				Kidde	ABC	5	Feb-05	1		
		HT-87046				Amerex	ABC	10	Feb-05	1		
		HT-87045				Kidde	ABC	10	Feb-05	1		
		HT-77320				JL Indust.	ABC	5	Feb-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		HT-90939				Amerex	ABC	5	Feb-05	1		
		HT-47944				Amerex	ABC	10	Feb-05	1		
		HT-70522				Kidde	ABC	10	Feb-05	1		
		HT-70522				Kidde	ABC	10	Feb-05	1		
		HT-70644				Amerex	ABC	10	Feb-05	1		
		HT-70644				C-O-Two	Carb on Dioxide	5	Feb-05	1		
		HT-70644				No label	Carb on Dioxide	5	Feb-05	1		
		HT-77194				Buckeye	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		Maintenance Bldg. Office				Amerex	ABC	5	Feb-05	1		
		Warehouse lock-up				Amerex	ABC	5	Feb-05	1		
		Warehouse				Amerex	ABC	5	Feb-05	1		
		Warehouse				Amerex	ABC	5	Feb-05	1		
		Maintenance Shop				Kidde	ABC	5	Feb-05	1		
		Maintenance Shop				Kidde	ABC	5	Feb-05	1		
		Maintenance Shop				Kidde	ABC	5	Feb-05	1		
		Gen. Building #3 MCC				Amerex	ABC	5	Feb-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Gen. Building #3				Kidde	ABC	5	Feb-05	1		
		Gen. Building #3				Amerex	ABC	5	Feb-05	1		
		OPS Building Lab				Amerex	ABC	5	Feb-05	1		
		OPS Building Hall Backdoor				Amerex	ABC	5	Feb-05	1		
		OPS Building lunch room				Buckeye	Wet Chemical	6 liter	Feb-05	1		
		OPS Building lunch room				Ansul	R-102 Wet Chemical	1.5 tank	Feb-05	1		
		OPS Building Foyer				Amerex	ABC	5	Feb-05	1		
		EDU Building Foyer				Amerex	ABC	5	Feb-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		EDU Building Offices Area				Amerex	ABC	5	Feb-05	1		
		GEN Building #2 MCC Room				Kidde	ABC	5	Feb-05	1		
		GEN Building #2 GEN Room				Amerex	ABC	5	Feb-05	1		
		GEN Building #2 GEN Room				Badger	ABC	5	Feb-05	1		
		Dewatering 1st Floor				Amerex	ABC	10	Feb-05	1		
		Dewatering 1st Floor				Kidde	ABC	10	Feb-05	1		
		Dewatering 1st Floor				JL Indust.	ABC	5	Feb-05	1		
		Dewat Scale Room (missing)				???	ABC	????		1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Dewat 2nd Floor				Badger	ABC	5	Feb-05	1		
		Dewat 2nd Floor				Amerex	ABC	10	Feb-05	1		
		Dewat 3rd floor				JL Indust.	ABC	5	Feb-05	1		
		Dewat 3rd floor				Amerex	ABC	5	Feb-05	1		
		Dewat 3rd floor office				Amerex	ABC	10	Feb-05	1		
		Thicking centrifuge				Amerex	ABC	5	Apr-04	1		
		Sludge Blower Building				Badger	ABC	10	Feb-05	1		
		Sludge Blower Building				JL Indust.	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Sludge Blower Building MCC				JL Indust.	ABC	5	Feb-05	1		
		South Blower Building				Sentry	Halon	5	Feb-05	1		
		South Blower Building				Amerex	ABC	5	Feb-05	1		
		South Blower Building				Kidde	ABC	5	Feb-05	1		
		South Blower Building Tunnel				Kidde	ABC	5	Feb-05	1		
		Pump Sta #1				JL Indust.	ABC	5	Feb-05	1		
		Pump Sta #1				Marine Type (No Name)	ABC	5	Feb-05	1		
		Methanol Storage				Ansulite (foam concentrate)	Concentrate	55 Gal	Jun-04	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Declorination Building				JL Indust.	ABC	5	Feb-05	1		
		Declorination Building				Kidde	ABC	5	Feb-05	1		
		**Declorination Building				JL Indust.	ABC	5	Feb-05	1		
		Declorination Building MCC				Kidde	ABC	5		1		
		Denite Control Room				Kidde	ABC	5	Feb-05	1		
		Denite Blower Room				Amerex	ABC	10	Feb-05	1		
		Gen Building #1				Kidde	ABC	5	Feb-05	1		
		Gen Building #1				Kidde	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Gen Building #4				Kidde	ABC	5	Feb-05	1		
		Gen Building #4				Sentry	ABC	5	Feb-05	1		
		Tech's Office				Sentry	ABC	5	Feb-05	1		
		Tech's Office				Kidde	ABC	5	Feb-05	1		
		S. Train Sludge P.S.				Kidde	ABC	5	Feb-05	1		
		Primary Odor Control				Kidde	Halon	5	Feb-05	1		
		Primary Odor Control				Kidde	Halon	5	Feb-05	1		
		N. Train Blower MCC				Amerex	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		N. Train Blower				Fire master	ABC	5	Feb-05	1		
		Alum Feed Facility				Fire master	ABC	5	Feb-05	1		
		Alum Feed Tunnel				Amerex	ABC	5	Feb-05	1		
		N. Train Sludge P.S.				Kidde	ABC	10	Feb-05	1		
		Clorine Room MCC				Kidde	ABC	5	Feb-05	1		
		Clorine Room				Sentry	ABC	5	Feb-05	1		
		Clorine Room				Amerex	ABC	10	Feb-05	1		
		EQ Blower				Kidde	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
		EQ Blower MCC				Kidde	ABC	5	Feb-05	1		
		Reclaimed Water P.S.				Sentry	ABC	5	Feb-05	1		
		Reclaimed Water P.S.				Amerex	ABC	5	Feb-05	1		
		RCW Control Building				JL Indust.	ABC	5	Feb-05	1		
		RCW Control Building				JL Indust.	ABC	5	Feb-05	1		
		Boiler Building MCC				Kidde	ABC	10	Feb-05	1		
		Digester Foyer				JL Indust.	ABC	5	Feb-05	1		
		Digester Downstairs				JL Indust.	ABC	5	Feb-05	1		
		Digester Downstairs				Buckeye	ABC	5	Feb-05	1		

**SECTION E – SPECIFICATIONS - CONTINUED**

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Boiler Room				Amerex 330	Carb on Dioxide	10	Feb-05	1		
		Break Room by Stove				Kidde	BC	3	Feb-05	1		
		Warehouse Spare				Fire master	ABC	10	????	1		
		Warehouse Spare				Kidde	ABC	5	Feb-05	1		
		Warehouse Spare				Amerex	ABC	5	Feb-05	1		
		Warehouse Spare				Badger	ABC	5	Feb-05	1		
		Warehouse Spare				Kidde	ABC	5	Feb-05	1		
		Warehouse Spare				Buckeye	ABC	5	????	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Warehouse Spare				Amerex	ABC	3	Feb-05	1		
		Warehouse Spare				Amerex	ABC	10	Feb-05	1		
		Warehouse Spare				Badger	ABC	5	Feb-05	1		
		Warehouse Spare				Buckeye	ABC	5	Feb-05	1		
		Warehouse Spare				Fire master	ABC	10	Feb-05	1		
		Fleet Pump Sta. Bldg				JL Indust.	ABC	10	Feb-05	1		
		Fleet Pump Sta. Bldg.				JL Indust.	ABC	10	Feb-05	1		
		P.S. 106				Kidde	ABC	10	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		P.S. 016 Chem. Rm.				Amerex	ABC	10	Feb-05	1		
		P.S. 016 " Storage				Amerex	ABC	10	Feb-05	1		
		P.S. 016 Gen. Room				Amerex	ABC	10	Feb-05	1		
		P.S. 016 Control "				Amerex	ABC	10	Feb-05	1		
		P.S. 168				Fire master	ABC	10	Feb-05	1		
		P.S. 069				Buckeye	ABC	10	Feb-05	1		
		McKay Booster Gen.Rm.				Amerex	ABC	10	Feb-05	1		
		McKay Pump Room				Amerex	ABC	10	Feb-05	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		McKay Control Room				Amerex	ABC	10	Feb-05	1		
		P.S. 071				Buckeye	ABC	10	Feb-05	1		
		P.S. 079 Near Door				Fire master	ABC	5	Feb-05	1		
		P.S. 079 Work Table				Fire master	ABC	5	Feb-05	1		
		P.S. 163 Gen Room				J L Lindust.	ABC	5	Feb-05	1		
		P.S. 163 VFD Room				Buckeye	ABC	10	Feb-05	1		
		P.S. 159				Sentry	ABC	10	Feb-05	1		
		P.S. 114				Fire master	ABC	10	Feb-05	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		Fog East Wall				Kidde	ABC	10	Feb-05	1		
		Fog North Wall				Kidde	ABC	10	Feb-05	1		
		Fog Southeast Wall				Kidde	ABC	10	Feb-05	1		
		Fog Southwest Wall				Kidde	ABC	10	Feb-05	1		
Water Quality Management	Logan Station	LT 87251	1620 Ridge Rd., Largo, FL 33778	Phil Bramalage	727 582-2360		Marine Dry Chemical	8	Jul-02	1		
		LT 83838				Amerex	ABC	5	Apr-04	1		
		LT 83659				Amerex	ABC	10	Sep-02	1		
		LT 70621				Amerex	ABC	5	Jul-02	1		

## SECTION E – SPECIFICATIONS PART 'B' - CONTINUED

Fire Extinguisher Location Inventory												
DEPT	DIV	LOCATION	ADDRESS	CONTACT	PHONE	MFG	TYPE	LB. SIZE	Mth Yr Last Insp	QTY	Insp./Cert per unit Price	TOTAL Price
		LT 77190				Amerex	ABC	5	Jul-02	1		
		LT 95537				Amerex	ABC	5	Sep-03	1		
		LT 75356				Amerex	ABC	5	Jan-02	1		
		LT 77177				Kidde	ABC	5	Sep-03	1		
		LT 74333				Amerex	ABC	2	Apr-02	1		
		LT 108156				Amerex	ABC	5	No Tag	1		
		LT 95675				Amerex	ABC	5	Jul-02	1		
		LT 70629				Amerex	ABC	5	Sep-00	1		

**SECTION E – SPECIFICATIONS PART ‘B’ - CONTINUED**

<b>Fire Extinguisher Location Inventory</b>												
<b>DEPT</b>	<b>DIV</b>	<b>LOCATION</b>	<b>ADDRESS</b>	<b>CONTACT</b>	<b>PHONE</b>	<b>MFG</b>	<b>TYPE</b>	<b>LB. SIZE</b>	<b>Mth Yr Last Insp</b>	<b>QTY</b>	<b>Insp./Cert per unit Price</b>	<b>TOTAL Price</b>
Utilities Operations	Wm. Dunn Facility	West Generator Room	4111 Dunn Rd., Palm Harbor, FL	John Pansula	453-6744	Amerex	ABC	10	Aug-05	1		





**SECTION F - BID SUMMARY PAGE**

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE  
045-789-B (RC)**

**PART 'A'**

**Cost, Group 1**

Months 1 through 12 : \$ \_\_\_\_\_

Months 13 through 24: \$ \_\_\_\_\_

Months 25 through 36: \$ \_\_\_\_\_

**GROUP 1 - TOTAL COST FOR 36 MONTHS: \$ \_\_\_\_\_**

**Cost, Group 2**

Months 1 through 12 : \$ \_\_\_\_\_

Months 13 through 24: \$ \_\_\_\_\_

Months 25 through 36: \$ \_\_\_\_\_

**GROUP 2 - TOTAL COST FOR 36 MONTHS: \$ \_\_\_\_\_**

**Cost, Group 3**

Months 1 through 12 : \$ \_\_\_\_\_

Months 13 through 24: \$ \_\_\_\_\_

Months 25 through 36: \$ \_\_\_\_\_

**GROUP 3 - TOTAL COST FOR 36 MONTHS: \$ \_\_\_\_\_**

**Cost, Group 4**

Months 1 through 12 : \$ \_\_\_\_\_

Months 13 through 24: \$ \_\_\_\_\_

Months 25 through 36: \$ \_\_\_\_\_

**GROUP 4 - TOTAL COST FOR 36 MONTHS: \$ \_\_\_\_\_**

**SECTION F - BID SUMMARY PAGE - CONTINUED**

**Cost, Group 5**

Months 1 through 12 : \$ \_\_\_\_\_

Months 13 through 24: \$ \_\_\_\_\_

Months 25 through 36: \$ \_\_\_\_\_

**GROUP 5 - TOTAL COST FOR 36 MONTHS: \$ \_\_\_\_\_**

**GRAND TOTAL, GROUPS 1 THROUGH 5 FOR 36 MONTHS: \$ \_\_\_\_\_**

Below costing will not be used to determine award. Unspecified work refers to time and materials for additional services, replacements or repairs not listed in this contract that the County determines may be in the County's best interest for the contractor to perform. The purpose of unspecified work is to maintain compliance with safety regulations and maintain all equipment listed in the bid specifications to be functioning in such a manner as not to compromise the safety of citizens or County employees. There is no guarantee that any additional services other than those specified will be required from the Contractor. Unspecified work could include but not be limited to replacement of worn gaskets or seals, replacement of parts used as a condition of inspection, emergency work, and services and parts of a nominal cost. The amount listed for unspecified work is not to be included in your bid total.

Labor rate per hour for Technical Personnel: \$ \_\_\_\_\_

Labor rate per hour for Supervision Personnel: \$ \_\_\_\_\_

Percentage mark up on cost for repair and replacement parts: \$ \_\_\_\_\_

**UNSPECIFIED WORK FOR PART 'A' FOR THIRTY-SIX (36) MONTHS: \$70,000.00**

**SECTION F - BID SUMMARY PAGE - CONTINUED**

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE  
045-789-B (RC)**

**PART 'B'**

**GRAND TOTAL:**            \$ \_\_\_\_\_

Below costing will not be used to determine award. Unspecified work refers to time and materials for additional services not listed in this contract that the County determines may be in the County's best interest to perform. There is no guarantee that any additional services other than those specified will be required from the Contractor.

Some unspecified work could include but not be limited to: Inspection of Fire Hood suppressions systems Automatic Fire Suppression Systems, additional inspections for locations that are not listed in the bid specifications, repairs, replacement parts, labor for repairs and replacements, hydrostatic testing of CO2 fire extinguishers, purchase of replacement fire extinguishers, and disposal of used fire extinguishers.

Labor rate per hour for Technical Personnel: \$ \_\_\_\_\_

Labor rate per hour for Supervision Personnel: \$ \_\_\_\_\_

Percentage mark up on cost for repair and replacement parts: \$ \_\_\_\_\_

Percentage mark up on non-commercial fire extinguishers; \$ \_\_\_\_\_

**UNSPECIFIED WORK FOR PART 'B' FOR THIRTY SIX (36) MONTHS: \$50,000.00**

**SECTION F - BID SUMMARY PAGE - CONTINUED**

**NOTE: BIDS MUST BE SUBMITTED IN DUPLICATE**

**BIDDER MUST COMPLETE FOLLOWING**

**BIDDERS ARE CAUTIONED THAT THE POLICY OF THE BOARD OF COUNTY COMMISSIONERS, PINELLAS COUNTY, IS TO ACCEPT THE LOWEST RESPONSIBLE BID RECEIVED MEETING SPECIFICATIONS. NO CHANGES REQUESTED BY A BIDDER DUE TO AN ERROR IN PRICING WILL BE CONSIDERED AFTER THE BID OPENING DATE AS ADVERTISED. BY SIGNING THIS PROPOSAL FORM BIDDERS ARE ATTESTING TO THEIR AWARENESS OF THIS POLICY.**

PAYMENT TERMS: \_\_\_\_\_% \_\_\_\_\_ DAYS,  
NET \_\_\_\_\_

SALES PERSON TO CONTACT AFTER AWARD:  
\_\_\_\_\_

\_\_\_\_\_  
BIDDER NAME

\_\_\_\_\_  
BID DEPOSIT, WHEN REQUIRED IS ATTACHED  
IN THE AMOUNT OF \$ \_\_\_\_\_

**\*REMIT TO NAME (AS SHOWN ON INVOICE)**

I HEREBY AGREE TO ABIDE BY ALL CONDITIONS  
OF THIS BID AND CERTIFY THAT I AM AUTHORIZED  
TO SIGN THIS BID FOR THE BIDDER.

\_\_\_\_\_  
BIDDER ADDRESS

\_\_\_\_\_  
CITY STATE ZIP

\_\_\_\_\_  
AUTHORIZED SIGNATURE

\_\_\_\_\_  
TELEPHONE FAX

\_\_\_\_\_  
PRINT NAME AND TITLE

**FEDERAL EMPLOYEE ID NO. (FEIN)**

DATE: \_\_\_\_\_

E-MAIL ADDRESS: \_\_\_\_\_  
(ACCOUNT REPRESENTATIVE)

**COMPANY EMAIL ADDRESS:** \_\_\_\_\_  
(REQUIRED FOR FUTURE ELECTRONIC NOTIFICATIONS)

**SECTION G - ADDENDUM ACKNOWLEDGMENT FORM**

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE**

045-789-B (RC)

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDA FOR THIS ITB/RFP BY SIGNING AND DATING BELOW:

ADDENDUM NO.	SIGNATURE/PRINTED NAME	DATE RECEIVED
--------------	------------------------	---------------


**Note:** Prior to submitting the response to this solicitation, it is the responsibility of the firm submitting a response to confirm if any addenda have been issued. If such document(s) has been issued, acknowledge receipt by signature and date in section above. Failure to do so may result in being considered non-responsive or result in lowering the rating of a firm’s proposal.

Information regarding Addenda issued is available on the Purchasing Department section of the County’s website at, [www.pinellascounty.org/purchase](http://www.pinellascounty.org/purchase), listed under category ‘Bid Schedule’.

**SECTION H – STATEMENT OF NO BID**

NOTE: If you do not intend to bid on this requirement, please return this form immediately. **Thank you.**

[Pinellas County Purchasing Department  
400 South Fort Harrison Avenue, 6th Floor  
Clearwater, Florida 33756]

We, the undersigned have declined to submit a bid for No. **045-789-B (RC)** for **SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR FACILITY MANAGEMENT AND COUNTY WIDE**

- Specifications too "tight", i.e., geared toward one brand or manufacturer only (explain below).
- Insufficient time to respond to the Invitation to Bid.
- We do not offer this product or service.
- Our schedule would not permit us to perform.
- Unable to meet specifications.
- Unable to meet Bond requirement.
- Specifications unclear (explain below).
- Unable to Meet Insurance Requirements.
- Remove Us from Your "Notification List" Altogether
- Other (specify below).

REMARKS:

---



---



---



---

We understand that if the "No Bid" letter is not executed and returned our name may be deleted from the Bidders List of Pinellas County.

COMPANY NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

TYPED NAME OF ABOVE: \_\_\_\_\_

TELEPHONE: \_\_\_\_\_

FAX: \_\_\_\_\_

EMAIL: \_\_\_\_\_

**PINELLAS COUNTY PURCHASING  
SIGN IN SHEET**

<b>CONTRACT#</b> 045-789-B (RC)	<b>CONTRACT TITLE:</b> Services, Fire Safety Testing, Inspection for Facility Management and County Wide.	<b>LOCATION(S) OF MEETING:</b> 5 <sup>th</sup> Floor Annex Building – Purchasing Conference Room
<b>DATE &amp; TIME:</b> January 31, 2006 @ 10:00 PM	<b>PURCHASING STAFF:</b> Richard Casamo	

All information must be filled in or you may be disqualified from bidding. If an addendum is issued, it will be mailed or faxed to all attendees to the address/fax # you have entered below. Addendums can also be found on our website at [www.pinellascounty.org/purchase](http://www.pinellascounty.org/purchase)

\*\*\*\*\* PLEASE PRINT \*\*\*\*\*

	NAME OF ATTENDEE * COMPANY REPRESENTED	ADDRESS	TELEPHONE # CELLULAR #	FAX#
1.	Richard C. Casamo, CPPB Pinellas County Purchasing Dept	6 <sup>th</sup> Floor Annex Bldng, 400 So. Ft. Harrison, Cwtr, Fl 33776	(727) 464-3155	(727) 464-3925
2.	Clara Weeks FMA Pinellas Cty Fac. Mgmt Detail	14400 49 <sup>th</sup> St. N. Clearwater, Fl 33762	727-464-6472 727-581-0030	727-464-6015
3.	Ray Kosach Facility Management	14400 49 <sup>th</sup> St. N. Clearwater Fl. 33762	727-464-6821	
4.	RON CARTER PIPER FIRE PROT.	521 S. Commerce Dr LARGO <sup>33770</sup>	727-581-9339	727-581-8332
5.	Tom Lynch Piper Fire Protection	521 Commerce Dr S LARGO <sup>33770</sup>	727-581-9339	727-581-8332
6.	DANIEL M. BEAUCHESSNE AHL FLA FIRE EQ CO	3458 MORRIS ST. N ST. PETE, FL	727-525-5450	727-527-1197
7.	RICHARD C. DALGON FMD-AIR SECTION	10756 LUMKIN RD LARGO FL 33773-3102	(727) 582-6472	(727) 464-4972
8.	KEITH ROYSEER Facility Mgmt. SE	501 1st Ave N. St Pete 33701	582-7738	582-7818

\* NOTE: If you are attending conference on behalf of another party or parties, please list parties on whose behalf you are attending (signin.dot)

**PINELLAS COUNTY PURCHASING  
SIGN IN SHEET**

CONTRACT# 045-789-B (RC)	CONTRACT TITLE: Services, Fire Safety Testing, Inspection for Facility Management and County Wide.	LOCATION(S) OF MEETING: 5 <sup>th</sup> Floor Annex Building – Purchasing Conference Room
DATE & TIME: January 31, 2006 @ 10:00 PM	PURCHASING STAFF: Richard Casamo	

All information must be filled in or you may be disqualified from bidding. If an addendum is issued, it will be mailed or faxed to all attendees to the address/fax # you have entered below. Addendums can also be found on our website at [www.pinellascounty.org/purchase](http://www.pinellascounty.org/purchase)

\*\*\*\*\* PLEASE PRINT \*\*\*\*\*

	NAME OF ATTENDEE * COMPANY REPRESENTED	ADDRESS	TELEPHONE # CELLULAR #	FAX#
1.	Richard C. Casamo, CPPB Pinellas County Purchasing Dept	6 <sup>th</sup> Floor Annex Bldng, 400 So. Ft. Harrison, Cwtr, FL 33776	(727) 464-3155	(727) 464-3925
2.	Robert Shields GENERAL SERVICES	501 1 <sup>ST</sup> AVE N. ST. PETE FL 33701	727-582-7738	727-582-7818
3.	Michelle Ellis Rjs Baker Fire Safety	9203-D King Palm Dr. Tampa 33619	(813) 376-3047	(813) 628-4661
4.	Michael Kneal Rjs Baker Fire Safety	9203-D King Palm Dr. Tampa 33619	(813) 621-6094	(813) 628-4661
5.	Mark Omas SIMPSON GANNETT	4701 OAK FAIR BLVD. TAMPA, FL 33629	(813) 478-6932	(813)-664-1731
6.				
7.				
8.				

\* NOTE: If you are attending conference on behalf of another party or parties, please list parties on whose behalf you are attending (signin.dot)

**BOARD OF COUNTY  
COMMISSIONERS**

KENNETH T. WELCH - CHAIRMAN  
RONNIE DUNCAN - VICE CHAIRMAN  
CALVIN D. HARRIS  
SUSAN LATVALA  
JOHN MORRONI  
KAREN WILLIAMS SEEL  
ROBERT B. STEWART



Joseph Lauro, CPPO/CPPB  
Director

February 13, 2006

TO: ALL INTERESTED PROPOSERS

REQUEST FOR PROPOSAL: Services, Fire Safety Testing Inspection and Certification for Facility Management and County Wide

PROPOSAL NUMBER: 045-789-B (RC)

PROPOSAL SUBMITTAL IS DUE: February 16, 2006 @ 3:00 PM

**ADDENDUM NO. 1**

Following is additional information, clarifications, questions and responses relative to referenced Request for Proposal (RFP):

**Changes**

1. The Bid opening date has been re-scheduled from February 16, 2006 to February 21, 2006.
2. A revised Bid Summary for Sections 'A' and 'B' is attached to this Addendum. Bids that are not submitted on the revised Bid Summary will be considered non-responsive.

**Requests for Changes and Clarifications**

**Request # 1**

Several vendors have requested that the County include repair, recharge, six year maintenance and twelve year hydro testing in the annual fire extinguisher inspections and certification.

PLEASE ADDRESS REPLY TO:  
400 South Ft. Harrison, Sixth Floor  
Clearwater, Florida 33756  
Phone: (727) 464-3311  
FAX: (727) 464-3925  
Website: [www.pinellascounty.org/purchase](http://www.pinellascounty.org/purchase)



## Response

Pinellas County is requiring annual inspection and certification only on fire extinguishers as stated in the specifications.

## **Request # 2**

Several vendors have requested a more accurate count of the number of fire extinguishers and the locations.

## Response

Facility Management maintains their own records on fire extinguishers. The fire extinguishers listed in the Facility Management locations are to be included in Part 'A' of the Bid Summary and **are not** included in or a part of the rest of the extinguishers listed in Part 'B' for the other County locations.

Bidders should base their quote for Fire Extinguisher Inspection and Certification based on the total number that is stated in the **revised** Bid Summary, Part 'B'.

## Questions

### **Question # 1**

Has the scenario ever risen where the "P" card limit was insufficient to cover the cost of repair and if so, what steps will be required, should this happen.

## Response

The County reserves the right to seek competitive pricing on all repairs, including repairs within the "P" card limit.

### **Question # 2**

Can the County provide the awarded contractor the annual service requirements by district?

## Response

One of the several purposes of the information provided in pages 94 through 244 of the bid specifications is to provide the contractor of the date of last inspection at each location. Historically, fire extinguisher inspections have not been performed by district. The purpose of this contract is to ensure that all fire extinguishers are inspected and certified by their expiration date.

### **Question # 3**

What is an acceptable or expected time to respond to a non-emergency service call.

## Response

With the exception of the Jail, an acceptable response time to a non-emergency is 24 hours. The Jail has people in a forced confinement. Bringing in an outside contractor may require moving persons or rescheduling an activity. For that reason, the awarded contractor may be in a situation where a non-emergency at the Jail may require a more prompt response than at other locations.

**Question # 4**

Can Detention process several technicians up front that would be acceptable for a period of one year or more, or does the contractor have to process the technician each time they have to report for service.

**Response**

Yes. Detention would prefer to process a technician for a year.

**Question # 4**

With regards to annual inspection, is a 12 month tag to be provided on each extinguisher for in-house monthly inspections?

**Response**

Yes.

**Question # 5**

Do any of the County facilities require a monthly inspection /"walk through"?

**Response**

Only County employees conduct monthly inspection / "walk throughs".

**Question # 6**

Would it be acceptable to "swap out" extinguishers when the unit is due for hydrostatic testing as long as the unit is "like for like"?

**Response**

Yes.

**Question # 8**

What is an acceptable reporting criteria?

**Response**


Part 'A' and Part 'B' of the bid will require two separate reporting criteria. Part 'A' of this bid will be managed by Facility Management. Part 'B' will be managed by Risk Management. The purpose of reporting criteria is to provide a record that services have been performed, when they were performed, and the evaluation of the inspections.

Prior to commencement of this contract, the awarded vendor will meet with representatives from Facility Management to review the reporting criteria. The vendor is to provide a copy of the report that will be used for Facility Management's approval. Upon completion of each inspection, the technician will give a hard copy of the report to each facility's coordinator and within ten working days send Elena Weeks, Facility Management Coordinator, Detention, a copy of the report in an excel spreadsheet on disc.

Part 'B', Risk Management requires a monthly report of all the extinguishers that have been inspected. Page 244 of the bid documents is a blank sheet that can be used as a template for reporting extinguisher inspections. However, if the awarded contractor has a more precise form for reporting fire extinguisher monthly reports, this will be acceptable. The report must include the department, location, number of extinguishers inspected, type of extinguishers inspected, date of inspection, and evaluation of the inspection. A hard copy of the report will be given to the location's safety coordinator upon completion of work and a copy of the fire extinguisher inspection report will be mailed to James Abaka, Risk Management Specialist, 400 South Fort Harrison Ave., Clearwater, FL. 33756. Unless approved by Mr. Abaka, work orders or "tear sheets" are not acceptable.

All other specifications, terms and conditions remain the same.

Please remember to acknowledge receipt of this Addendum in Section G, Page 249 under Addendum No. 1 and return with completed bid package.

Sincerely,  
  
Joseph Lauro, CPPO/CPPB  
Director of Purchasing

SECTION F - BID SUMMARY PAGE - REVISED

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

Group 1 - South

1. 501 1<sup>st</sup>. Ave. N., St. Petersburg, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Pump (Annually) X 3 = ..... \$ \_\_\_\_\_

Fire Pump (Annually) X 3 = ..... \$ \_\_\_\_\_

Fire Extinguishers (66 Annually) X 3.....\$ \_\_\_\_\_

2. 545 1<sup>st</sup>. Ave. N., St. Petersburg, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Pump (Annually) X 3 = ..... \$ \_\_\_\_\_

Fire Extinguishers ((48 Annually) X 3.....\$ \_\_\_\_\_

3. 1800 66<sup>th</sup> St. N., St. Petersburg, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (17 Annually) X 3.....\$ \_\_\_\_\_

4. 647 Ave. North, St. Petersburg, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (11 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

Group 2 - CJC

1. CJC 14250 49<sup>th</sup> St. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Pump (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (137 Annually) X 3.....\$ \_\_\_\_\_

2. Airport Business Ctr., 14255 49<sup>th</sup> St. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (17 Annually) X 3.....\$ \_\_\_\_\_

3. 5300 Ulmerton Road, Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (15 Annually) X 3.....\$ \_\_\_\_\_

4. Sheriff Tech 1 4801 145<sup>th</sup> Ave. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (10 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

5. Sheriff Tech 2 4707 145<sup>th</sup> Ave. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (14 Annually) X 3.....\$ \_\_\_\_\_

6. Sheriff Tech 3 4645 145<sup>th</sup> Ave. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (10 Annually) X 3.....\$ \_\_\_\_\_

7. Purchasing Warehouse 14390 Roosevelt Blvd., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (11 Annually) X 3.....\$ \_\_\_\_\_

8. 49<sup>th</sup> St. Service Center 13355 49<sup>th</sup> St. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (6 Annually) x 3.....\$ \_\_\_\_\_

9. Records Retention 14155 49<sup>th</sup> St. N., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (6 Annually) X3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

10. Weeden Island Education Center 1800 Weeden Drive, N.E., St. Petersburg, FL

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_

Fire Extinguishers (3 Annually) X3.....\$ \_\_\_\_\_

Group 3 - North

1. 315 Court St., Clearwater, FL

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_

Fire Extinguishers (78 Annually) X 3.....\$ \_\_\_\_\_

2. 400 S. Ft. Harrison, Clearwater, FL

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_

Fire Pump (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (31 Annually) X 3.....\$ \_\_\_\_\_

3. 324 S. Ft. Harrison, Clearwater, FL

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_

Fire Extinguishers (22 Annually) X 3.....\$ \_\_\_\_\_

4. 300 S. Garden St., Clearwater, FL

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

5. 400 Court St., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (15 Annually) X 3..... \$ \_\_\_\_\_

6. 310 Court St., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (5 Annually) X 3 ..... \$ \_\_\_\_\_

7. 510 Bay Ave., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3..... \$ \_\_\_\_\_

8. 512-514 S. Ft. Harrison, Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (6 Annually) X 3 ..... \$ \_\_\_\_\_

9. 520 Oak St., Clearwater, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (2 Annually) X 3 ..... \$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

10. 303 Chestnut St., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (2 Annually) X 3.....\$ \_\_\_\_\_

11. 311 Osceola Ave., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (2 Annually) X 3.....\$ \_\_\_\_\_

12. 201 Rogers St., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (6 Annually) X 3.....\$ \_\_\_\_\_

13. 631 Chestnut St, Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (3 Annually) X 3.....\$ \_\_\_\_\_

14. 305 Osceola Ave., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (1 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

15. 311 Osceola Ave., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (1 Annually) X #.....\$ \_\_\_\_\_

16. 300 S. Ft. Harrison, Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (5 Annually) X 3.....\$ \_\_\_\_\_

17. 509 East Ave. Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (37 Annually) X 3.....\$ \_\_\_\_\_

18. 333 Chestnut St., Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers ((10 Annually) X 3.....\$ \_\_\_\_\_

19. 3611 Fletch Haven, Tarpon Springs

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (6 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

20. 3620 Fletch Haven, Tarpon Springs, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (9 Annually) X 3.....\$ \_\_\_\_\_

21. 29582 US Hwy. 19 N., NCSC, Clearwater, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

22. 29582 US Hwy. 19 N., Maintenance Building, Clearwater, Fl

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (2 Annually) X 3.....\$ \_\_\_\_\_

23. 1425 East Lake Road, Palm Harbor, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (2 Annually) X 3.....\$ \_\_\_\_\_

24. 1500 16<sup>th</sup> St., Palm Harbor, Fl

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (10 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

25. 3940 Keystone Rd., Tarpon Springs, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (25 Annually) X 3..... \$ \_\_\_\_\_

26. 1190 Georgia Ave., Palm Harbor, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (10 Annually) X3..... \$ \_\_\_\_\_

Group 4 - Mid County

1. Facility Management Building, 10756 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (22 Annually) X 3..... \$ \_\_\_\_\_

2. Animal Services, 12450 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (18 Annually) X 3..... \$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

3. PCSO Building 500, 10750 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (3 Annually) X 3.....\$ \_\_\_\_\_

4. PCSO Building 200/300, 10750 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (15 Annually) X 3.....\$ \_\_\_\_\_

5. PCSO Building 400, 10750 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (9 Annually) X 3.....\$ \_\_\_\_\_

6. PCSO Annex/Building 100, 10750 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (23 Annually) X 3.....\$ \_\_\_\_\_

7. Medical Examiner's Building, 10900 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = ..... \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = ..... \$ \_\_\_\_\_

Fire Extinguishers (12 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

8. Co-op Extension, 12175 125<sup>th</sup> St. N., Largo, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (15 Annually) X 3 .....\$ \_\_\_\_\_

9. Fleet Main Shop, 9685 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (82 Annually) x 3 .....\$ \_\_\_\_\_

10. EMS Building, 12490 Ulmerton Rd., Largo, FL

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_

Fire Extinguishers (47 Annually) X 3.....\$ \_\_\_\_\_

Group 5 - Detention

1. A Barracks

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

2. B Barracks

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

3. C Barracks

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Deluge System (B-Annually) X 6 = \$ \_\_\_\_\_

Fire Extinguishers (13 Annually) X 3.....\$ \_\_\_\_\_

4. Central

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Fire Pump (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (10 Annually) X 3.....\$ \_\_\_\_\_

5. FSC

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Deluge System (B-Annually) X 6 = \$ \_\_\_\_\_

Fire Extinguishers (7 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE - REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

6. F Wing

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Deluge System (B-Annually) X 6 = \$ \_\_\_\_\_

Fire Pump (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (42 Annually) X 3.....\$ \_\_\_\_\_

7. Mini I

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

8. Mini II

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = \$ \_\_\_\_\_  
(Includes Tamper and Flows)

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

9. MSC Control

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (8 Annually) X 3.....\$ \_\_\_\_\_

10. MSC Kitchen

Fire Alarm System (Annually) X 3 = \$ \_\_\_\_\_

Fire Extinguishers (7 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

11. MSC Laundry

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (7 Annually) X 3.....\$ \_\_\_\_\_

12. Boot Camp / JAC Center

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (14 Annually) X 3.....\$ \_\_\_\_\_

13. Phase I

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_  
(Includes Tamper and Flows)

Deluge System (B-Annually) X 6 = .....\$ \_\_\_\_\_

Fire Extinguishers (45 Annually) X 3.....\$ \_\_\_\_\_

14. Phase II

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Sprinkler System (Quarterly) X 12 = .....\$ \_\_\_\_\_  
(Includes Tamper and Flows)

Deluge System (B-Annually) X 6 = .....\$ \_\_\_\_\_

Fire Extinguishers ( 26 Annually) X 3.....\$ \_\_\_\_\_

15. Wood Shop

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (5 Annually) X 3.....\$ \_\_\_\_\_

SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)

SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE

045-789-B (RC)

PART 'A'

16. Video Visitation

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (4 Annually) X 3.....\$ \_\_\_\_\_

17. Old JDC

Fire Alarm System (Annually) X 3 = .....\$ \_\_\_\_\_

Fire Extinguishers (18 Annually) X 3.....\$ \_\_\_\_\_

TOTAL 36 MONTH COST FOR INSPECTION,  
TESTING, MAINTENANCE & CERTIFICATION  
OF FIRE ALARM, SPRINKLER SYSTEMS, DELUGE  
SYSTEMS AND FIRE PUMPS.....\$ \_\_\_\_\_

TOTAL 36 MONTH COST FOR ANNUAL  
INSPECTION AND CERTIFICATION OF  
FIRE EXTINGUISHERS LISTED IN PART 'A' (1,231 TOTAL).....\$ \_\_\_\_\_

GRAND TOTAL BID FOR PART 'A': \$ \_\_\_\_\_

Below costing will not be used to determine award. Unspecified work refers to time and materials for additional services, replacements or repairs not listed in this contract that the County determines may be in the County's best interest for the contractor to perform. The purpose of unspecified work is to maintain compliance with safety regulations and maintain all equipment listed in the bid specifications to be functioning in such a manner as not to compromise the safety of citizens or County employees. There is no guarantee that any additional services other than those specified will be required from the Contractor. Unspecified work could include but not be limited to additional locations being added to the contract, replacement of worn gaskets or seals, replacement of parts used as a condition of inspection, emergency work, and services and parts of a nominal cost. The amount listed for unspecified work is not to be included in your bid total.

UNSPECIFIED WORK FOR SECTION 'A':.....\$ 10,000.00

**SECTION F - BID SUMMARY PAGE – REVISED (CONTINUED)**

**SERVICES, FIRE SAFETY TESTING, INSPECTION AND CERTIFICATION FOR  
FACILITY MANAGEMENT AND COUNTY WIDE**

045-789-B (RC)

PART 'B'

**ANNUAL INSPECTION AND CERTIFICATION OF FIRE EXTINGUISHERS –** Quantities do not include fire extinguishers listed in Part 'A'.

<u>Description</u>	<u>Estimated Quantity</u>	<u>Unit of Measure</u>	<u>Unit Cost Per Annual Inspection</u>	<u>Number of Inspections</u>	<u>Total Cost</u>
ABC / BC	1800	Each	\$ _____	X 3 =	\$ _____
CO2	479	Each	\$ _____	X 3 =	\$ _____
'K'	3	Each	\$ _____	X 3 =	\$ _____
Halon	3	Each	\$ _____	X 3 =	\$ _____

**GRAND TOTAL:**           \$ \_\_\_\_\_

Below costing will not be used to determine award. Unspecified work refers to time and materials for additional services not listed in this contract that the County determines may be in the County's best interest to perform. There is no guarantee that any additional services other than those specified will be required from the Contractor.

Some unspecified work could include but not be limited to: Inspection of Fire Hood suppressions systems Automatic Fire Suppression Systems, additional inspections for locations that are not listed in the bid specifications, repairs, replacement parts, labor for repairs and replacements, hydrostatic testing of CO2 fire extinguishers, purchase of replacement fire extinguishers, and disposal of used fire extinguishers.

Labor rate per hour for Technical Personnel: \$ \_\_\_\_\_

Labor rate per hour for Supervision Personnel: \$ \_\_\_\_\_

Percentage mark up on cost for repair and replacement parts: \$ \_\_\_\_\_

Percentage mark up on non-commercial fire extinguishers; \$ \_\_\_\_\_

**UNSPECIFIED WORK FOR PART 'B' FOR THIRTY SIX (36) MONTHS: \$70,000.00**

**NOTE: BIDS MUST BE SUBMITTED IN DUPLICATE**

**BIDDER MUST COMPLETE FOLLOWING**

BIDDERS ARE CAUTIONED THAT THE POLICY OF THE BOARD OF COUNTY COMMISSIONERS, PINELLAS COUNTY, IS TO ACCEPT THE LOWEST RESPONSIBLE BID RECEIVED MEETING SPECIFICATIONS. NO CHANGES REQUESTED BY A BIDDER DUE TO AN ERROR IN PRICING WILL BE CONSIDERED AFTER THE BID OPENING DATE AS ADVERTISED. BY SIGNING THIS PROPOSAL FORM BIDDERS ARE ATTESTING TO THEIR AWARENESS OF THIS POLICY.

---

PAYMENT DISCOUNT TERMS:  
\_\_\_\_\_ % \_\_\_\_\_ DAYS, NET

\_\_\_\_\_  
BIDDER NAME

\_\_\_\_\_  
BIDDER ADDRESS

\_\_\_\_\_  
CITY STATE ZIP

\_\_\_\_\_  
TELEPHONE FAX

**OPTIONAL PAYMENT TERMS:**

PAYMENT BY VISA PURCHASING CARD  
PLEASE STATE YOUR PAYMENT TERMS AND DISCOUNT \_\_\_\_\_ % \_\_\_\_\_ DAYS, NET \_\_\_\_\_  
FOR COUNTY PAYMENT BY VISA PURCHASING CARD

SALES PERSON TO CONTACT AFTER AWARD: \_\_\_\_\_

BID DEPOSIT, WHEN REQUIRED IS ATTACHED  
IN THE AMOUNT OF \$ \_\_\_\_\_

I HEREBY AGREE TO ABIDE BY ALL CONDITIONS  
OF THIS BID AND CERTIFY THAT I AM  
AUTHORIZED TO SIGN THIS BID FOR THE BIDDER.

\_\_\_\_\_  
AUTHORIZED SIGNATURE

\_\_\_\_\_  
PRINT NAME AND TITLE

DATE: \_\_\_\_\_