



271 NW 16th St.
 Pompano Beach, Florida 33060
 (954) 946-6532
 Fax (954) 946-4076

Date 6/27/12

TO WHOM IT MAY CONCERN:

RE: Sheriff Tower Pinellas Co.
10750 Ulmertown Rd
Largo, FL 33778

ON 6/27/12 WEEZER ELECTRIC, INC. PERFORMED A GROUND RESISTANCE TEST ON THE GROUND SYSTEM. THE FOLLOWING CONDITION EXISTED AT THE TIME OF THE TEST.

1. THE TIME OF THE TEST WAS 8.17 min
2. THE AIR TEMPERATURE WAS 78°
3. THE SOIL WAS DAMP
4. THE SKY WAS OVERCAST

THE TEST WAS PERFORMED USING THE AEMC INSTRUMENTS DIGITAL GROUND RESISTANCE TESTER MODEL 4500.

1. THE READING AT THE MAIN GROUNDING ELECTRODE WAS .5 OHMS
2. THE READING AT THE PORT ENTRY WAS NA OHMS
3. THE READING AT THE TOWER WAS .5 OHMS

WEEZER ELECTRIC, INC. CERTIFIES THAT THE GROUNDING SYSTEM AT THE SITE MEETS OR EXCEEDS THE REQUIREMENTS OF THE MOTOROLA R-56 STANDARDS.

SINCERELY,


 THOMAS P. JEFFERS, PRES.