



Joe Lauro, CPPO/CPPB
Director

August 27, 2018

TO: ALL INTERESTED PROPOSERS

REQUEST FOR PROPOSAL: Professional Design Build Services – Dunn Water Reclamation Facility Filtration & Disinfection Improvements

PROPOSAL NUMBER: 178-0407-NC (SS)

PROPOSAL SUBMITTAL IS DUE: September 6, 2018 @ 3:00 P.M.

ADDENDUM NO. 1

Following is additional information, clarifications, questions and responses relative to referenced Request for Proposal (RFP):

CLARIFICATION(S): The Dunn Water Reclamation Facility has an average daily flow of 9.0 million gallons per day and a peak hourly flow of 18.0 million gallons per day. These flows can be located in the permit documents attached with the Request for Proposal.

QUESTION/RESPONSE:

Please confirm the scope outlined in DCP Section 3.7 Facility Screening System shall be included in the project scope as indicated during the 8/15/2018 site visit.

Response: Yes, this is included in the project as described in Section 3.7 of the Design Criteria Package.

All other specifications, terms and conditions remain the same.

Please remember to acknowledge receipt of this Addendum in Section G, Page 30 under Addendum No.1 and return with completed proposal package.

Sincerely,

Joe Lauro CPPB/CPPO
Joseph Lauro, CPPO/CPPB
Director of Purchasing

PLEASE ADDRESS REPLY TO:
400 South Ft. Harrison, Sixth Floor
Clearwater, Florida 33756
Phone: (727) 464-3311
FAX: (727) 464-3925
Website: www.pinellascounty.org/purchase

