

# **Capacity Analysis Report**

**For**

**William E. Dunn Water Reclamation Facility  
4111 Dunn Drive  
Palm Harbor, Florida 34683**

**Florida Department of Environmental Protection  
Facility Identification No. FLA0128775  
Permit No. FLA0128775  
Permit Expiration Date: January 26, 2015**

June 25, 2014

PREPARED FOR:

Pinellas County Department of Environment and Infrastructure  
Water and Sewer Division

PREPARED BY:



8600 Hidden River Parkway  
Suite 550  
Tampa FL 33637  
813.977.6005

## **CERTIFICATIONS**

The undersigned permittee is fully aware of and intends to comply with the recommendations and schedules included in this report.

---

Robert M. Powell  
Director  
Pinellas County Department of Environment and Infrastructure  
Water and Sewer Division  
14 S. Ft. Harrison Avenue  
Clearwater, Florida 33756  
727.582.2300

I certify that the information contained in this report is true and correct to the best of my knowledge, the report was prepared in accordance with sound engineering principles, and that I have discussed any recommendations and schedules contained herein with the permittee or the permittee's delegated representative.

### **PREPARED BY:**

---

Susan G. Martelli  
Florida PE 37940  
Metzger & Willard, Inc.  
8600 Hidden River Parkway  
Suite 550  
Tampa FL 33637  
813.977.6005  
smartelli@metzgerwillard.com

## TABLE OF CONTENTS

1.0	INTRODUCTION .....	1
2.0	EXISTING CONDITIONS .....	2
2.1	Permitted Capacities .....	3
2.2	Monthly Average Daily Flows, Three-month Average Daily Flows, and Annual Average Daily Flows.....	3
2.3	Seasonal Variations in Flow .....	11
2.4	Updated Flow and Loading Information.....	12
3.0	FUTURE CONDITIONS .....	14
3.1	Population Projections.....	14
3.2	Flow Projections .....	14
4.0	SUMMARY AND CONCLUSIONS .....	17
4.1	Time Required to Reach the Permitted Capacity .....	17
4.2	Recommendations for Expansion.....	17

## TABLE OF CONTENTS

### LIST OF FIGURES

Figure 1	Flow Diagram	2
Figure 2	Historical Influent Flow Data, 2003 – 2013	8
Figure 3	Reclaimed Water System Influent Flow	9
Figure 4	Reclaimed Water System Use	10
Figure 5	Seasonal Variation of Influent Flow, 2003 – 2013	12
Figure 6	Population Projection for WED WRF Sewerage System	16

### LIST OF TABLES


Table 1-1	Process Components and Volume of Structure	1
Table 2-1	Flow Monitoring Locations and Type	3
Table 2-2	Flow Data for WED WRF Treatment Facility and Reuse System	4
Table 2-3	Annual Average Daily Flow, 2003 – 2013	11
Table 2-4	Ratio of TMADF to AADF for 2009 – 2013	11
Table 2-5	Design and Current Influent Characteristics	13
Table 3-1	Service Area Population Projections	14
Table 3-2	Projected Flow Summary, 2013 – 2023	15
Table 4-1	Projected Maximum TMADF and Permitted Capacity	17

## 1.0 INTRODUCTION

This Capacity Analysis Report (CAR) supports the operation permit renewal for the William E. Dunn Water Reclamation Facility (WEDWRF) located in Pinellas County, Florida. The facility is currently rated for an annual average daily flow (AADF) of 9 million gallons per day (MGD) and utilizes a 5-stage Bardenpho activated sludge Advanced Wastewater Treatment process to achieve effluent quality requirements. A process schematic and flow diagram for the facility is shown in **Figure 1**. **Table 1-1** lists the major treatment processes and their corresponding volumes.

<b>Table 1-1. Process Components and Volume of Structure</b>	
<b>Component or Treatment Unit / Number of Units</b>	<b>Volume of Structure</b>
Grit Chambers / 3	0.002 MG Each
Fermentation Tanks / 2	0.38 MG Each
First Stage Anoxic Tanks / 2	0.844 MG Each
Oxidation Reactors Nos. 1 and 2	2.263 MG Each
Oxidation Reactor No. 3	1.284 MG
Second Stage Anoxic Tanks / 2	0.941 MG Each
Re-aeration Tanks / 2	0.11 MG Each
Clarifier Nos. 1, 2, 3 and 4	0.60 MG Each
Clarifiers Nos. 5 and 6	0.665 MG Each
Sand Filters / 4	800 SF Each Surface Area
Chlorine Contact Chambers / 2	0.109 MG Each
Aerobic Sludge Holding Tanks / 2	0.22 MG Each
Reject Water Storage Pond / 1	17 MG
Reclaimed Water Storage Pond / 1	64 MG

Preliminary treatment components at the WEDWRF include mechanical bar screening and induced vortex grit recovery units. The biological treatment consists of two parallel Bardenpho trains that include mechanically mixed fermentation tanks, mechanically mixed anoxic tanks, mechanically aerated oxidation channels with internal recycle pumps, mechanically mixed second stage anoxic tanks, re-aeration tanks, final clarifiers and return activated sludge. In addition, a third oxidation train is included to provide additional biological treatment. This third train is interconnected with the two Bardenpho oxidation channels. Final treatment components include automatic backwashing dual media filters, chlorine contact basins, reclaimed water storage, and reclaimed water pumping. Treated wastewater that does not meet reclaimed water standards is discharged to a reject water storage pond to be returned to the treatment plant after the headworks structure and prior to the first anoxic zone for reprocessing. The wasted sludge is currently thickened, dewatered and transported to the Residuals Management Facility in the South Cross Bayou WRF for sludge stabilization and beneficial reuse.



## 2.0 EXISTING CONDITIONS

### 2.1 Permitted Capacities

The WEDWRF has a permitted capacity of 9 MGD AADF. The land application reuse system has a permitted capacity of 9 MGD AADF. The facility is permitted for residuals disposal at the South Cross Bayou facility or in a Class I solid waste landfill. Based on the discharge monitoring reports filed between January 2009 and December 2013, the AADF has not reached the permitted capacity and effluent quality characteristics have consistently met permit conditions.

### 2.2 Monthly Average Daily Flows (MADF), Three-month Average Daily Flows (TMADF), and Annual Average Daily Flows (AADF)

Based on available monthly operating reports from January 2009 to December 2013, the AADF was 6.5 MGD during this reporting period. The highest monthly average daily flow (MADF) reported during the previous three-year period occurred in July 2012 (7.67 MGD) and the maximum three-month average daily flow occurred in August 2012 (7.30 MGD). A maximum daily flow of 12.16 MGD was observed on June 25, 2012, after a 10.28-inch rainfall event.

Flows are monitored at the following locations as listed in the following table.

Table 2-1. Flow Monitoring Locations and Type.		
Location	Designation	Type
Influent	FLW-01	ISCO Uni-Mag Magnetic Flow Meter
Effluent – WED WRF	FLW-02	Siemens SITRANS LUT 400 Ultrasonic Flow Meter
City of Clearwater	FLW-03	Reported by City of Clearwater
City of Oldsmar	FLW-04	Reported by City of Oldsmar
Reuse System	FLW-05	Calculated, FLW-02 + FLW-03 + FLW-04 = FLW-05

Monthly flow data from January 2003 to December 2013 for the WEDWRF is presented in **Table 2-2**. **Figure 2** provides a graphic illustration of influent flows to WED WRF between January 2003 and December 2013. **Figure 3** illustrates the flows from the WED WRF, the City of Clearwater and the City of Oldsmar into the Reclaimed Water System. **Figure 4** illustrates the reclaimed water usage by the connected customers.

The AADF over the period of data ranged from 6.4 to 6.7 MGD. **Table 2-3** presents the annual average daily flow per year between January 2003 and December 2013.

**TABLE 2-2. FLOW DATA FOR WED WRF TREATMENT FACILITY AND REUSE SYSTEM**

YEAR	MONTH	WED INFLUENT FLOW, MGD			EFFLUENT FLOW, MGD			REUSE SYSTEM, MGD		
		MONTHLY AVERAGE,			WED EFFLUENT, FLW-02	CITY OF CLEAR-WATER, FLW-03	CITY OF OLDS-MAR, FLW-04	INFLUENT,		
		FLW-01	TMADF	AAAF				FLW-05	TMADF	AAAF
2003	Jan	6.8			6.8			6.8		
	Feb	6.8			6.8			6.8		
	Mar	6.7	6.8		6.7			6.7	6.8	
	Apr	6.6	6.7		6.6			6.6	6.7	
	May	6.4	6.6		6.4			6.4	6.6	
	Jun	6.6	6.5		6.6			6.6	6.5	
	Jul	6.8	6.6		6.8			6.8	6.6	
	Aug	7.3	6.9		7.3			7.3	6.9	
	Sep	7.2	7.1		7.2			7.2	7.1	
	Oct	7.6	7.4		7.6			7.6	7.4	
	Nov	7.6	7.5		7.6			7.6	7.5	
	Dec	7.6	7.6	7.0	7.6			7.6	7.6	7.0
2004	Jan	7.8	7.7	7.1	7.8			7.8	7.7	7.1
	Feb	8.0	7.8	7.2	8.0			8.0	7.8	7.2
	Mar	7.8	7.9	7.3	7.8			7.8	7.9	7.3
	Apr	7.7	7.8	7.4	7.7			7.7	7.8	7.4
	May	7.3	7.6	7.4	7.3			7.3	7.6	7.4
	Jun	7.2	7.4	7.5	7.2			7.2	7.4	7.5
	Jul	7.5	7.3	7.6	7.5			7.5	7.3	7.6
	Aug	8.0	7.6	7.6	8.0			8.0	7.6	7.6
	Sep	7.8	7.8	7.7	7.8			7.8	7.8	7.7
	Oct	7.7	7.8	7.7	7.7			7.7	7.8	7.7
	Nov	7.4	7.6	7.7	7.4			7.4	7.6	7.7
	Dec	7.5	7.5	7.6	7.1			7.1	7.4	7.6
2005	Jan	7.6	7.5	7.6	8.0			8.0	7.5	7.6
	Feb	7.7	7.6	7.6	8.5			8.5	7.9	7.7
	Mar	7.9	7.7	7.6	7.4			7.4	8.0	7.6
	Apr	7.6	7.7	7.6	8.9			8.9	8.3	7.7
	May	7.2	7.6	7.6	8.4			8.4	8.2	7.8
	Jun	7.5	7.4	7.6	6.3			6.3	7.9	7.8
	Jul	7.8	7.5	7.6	8.9			8.9	7.9	7.9
	Aug	7.5	7.6	7.6	8.0			8.0	7.7	7.9
	Sep	7.1	7.5	7.5	8.6			8.6	8.5	7.9
	Oct	7.2	7.3	7.5	6.8			6.8	7.8	7.9
	Nov	7.2	7.2	7.5	7.4			7.4	7.6	7.9
	Dec	7.2	7.2	7.5	7.0			7.0	7.1	7.9



**TABLE 2-2. FLOW DATA FOR WED WRF TREATMENT FACILITY AND REUSE SYSTEM**


YEAR	MONTH	WED INFLUENT FLOW, MGD			EFFLUENT FLOW, MGD			REUSE SYSTEM, MGD		
		MONTHLY AVERAGE,			WED EFFLUENT,	CITY OF CLEAR-WATER,	CITY OF OLDS-MAR,	INFLUENT,		
		FLW-01	TMADF	AAAF				FLW-02	FLW-03	FLW-04
2006	Jan	7.2	7.2	7.4	7.4			7.4	7.3	7.8
	Feb	7.3	7.2	7.4	6.5			6.5	7.0	7.6
	Mar	7.1	7.2	7.3	8.4			8.4	7.4	7.7
	Apr	6.8	7.1	7.3	7.6			7.6	7.5	7.6
	May	6.3	6.7	7.2	7.0			7.0	7.7	7.5
	Jun	6.1	6.4	7.1	5.8			5.8	6.8	7.5
	Jul	6.2	6.2	6.9	6.8			6.8	6.5	7.3
	Aug	6.5	6.3	6.9	6.8			6.8	6.5	7.2
	Sep	7.2	6.6	6.9	7.2			7.2	6.9	7.1
	Oct	6.5	6.7	6.8	8.2			8.2	7.4	7.2
	Nov	6.5	6.7	6.7	6.5			6.5	7.3	7.1
	Dec	6.4	6.5	6.7	6.9			6.9	7.2	7.1
2007	Jan	6.5	6.5	6.6	8.1			8.1	7.2	7.2
	Feb	6.5	6.5	6.6	8.0			8.0	7.7	7.3
	Mar	6.5	6.5	6.5	8.2			8.2	8.1	7.3
	Apr	6.3	6.4	6.5	7.3			7.3	7.8	7.2
	May	6.0	6.3	6.4	8.1			8.1	7.9	7.3
	Jun	6.1	6.1	6.4	7.3			7.3	7.6	7.5
	Jul	6.0	6.0	6.4	7.7			7.7	7.7	7.5
	Aug	6.5	6.2	6.4	7.2			7.2	7.4	7.6
	Sep	6.2	6.2	6.3	8.5			8.5	7.8	7.7
	Oct	6.2	6.3	6.3	7.6			7.6	7.8	7.6
	Nov	6.2	6.2	6.3	6.9			6.9	7.7	7.7
	Dec	6.3	6.2	6.3	6.2	0.9		7.1	7.2	7.7
2008	Jan	6.4	6.3	6.3	7.5	0.0		7.5	7.2	7.6
	Feb	6.6	6.4	6.3	6.8	0.4		7.2	7.3	7.6
	Mar	6.6	6.5	6.3	7.5	0.0	0.0	7.5	7.4	7.5
	Apr	6.4	6.5	6.3	7.7	1.3	0.1	9.1	7.9	7.6
	May	6.0	6.3	6.3	6.9	2.6	0.1	9.6	8.7	7.8
	Jun	6.0	6.1	6.3	6.8	2.6	0.1	9.5	9.4	8.0
	Jul	6.3	6.1	6.3	7.1	0.6	0.0	7.7	8.9	8.0
	Aug	6.7	6.3	6.3	6.8	0.0	0.0	6.8	8.0	7.9
	Sep	6.4	6.5	6.3	7.1	1.7	0.1	8.9	7.8	8.0
	Oct	6.2	6.4	6.3	6.7	1.9	0.0	8.6	8.1	8.0
	Nov	6.2	6.3	6.3	6.7	0.9	0.0	7.6	8.4	8.1
	Dec	6.2	6.2	6.3	5.5	0.1	0.0	5.6	7.3	8.0


**TABLE 2-2. FLOW DATA FOR WED WRF TREATMENT FACILITY AND REUSE SYSTEM**


YEAR	MONTH	WED INFLUENT FLOW, MGD			EFFLUENT FLOW, MGD			REUSE SYSTEM, MGD		
		MONTHLY AVERAGE, FLW-01	TMADF	AADF	WED EFFLUENT, FLW-02	CITY OF CLEAR-WATER, FLW-03	CITY OF OLDS-MAR, FLW-04	INFLUENT, FLW-05	TMADF	AADF
2009	Jan	6.3	6.2	6.3	6.7	0.0	0.0	6.7	6.6	7.9
	Feb	6.4	6.3	6.3	6.7	0.2	0.0	6.9	6.4	7.9
	Mar	6.4	6.4	6.3	6.4	1.9	0.1	8.4	7.3	8.0
	Apr	6.2	6.3	6.3	6.8	2.0	0.1	8.9	8.1	7.9
	May	6.2	6.3	6.3	6.6	1.6	0.1	8.3	8.6	7.8
	Jun	6.1	6.2	6.3	7.0	3.0	0.3	10.3	9.2	7.9
	Jul	6.9	6.4	6.3	6.7	1.2	0.0	7.9	8.9	7.9
	Aug	6.7	6.6	6.3	6.5	1.4	0.0	7.9	8.7	8.0
	Sep	6.5	6.7	6.4	6.9	0.9	0.0	7.8	7.9	7.9
	Oct	6.3	6.5	6.4	6.7	2.4	0.0	9.1	8.3	8.0
	Nov	6.4	6.4	6.4	6.4	2.6	0.0	9.0	8.6	8.1
	Dec	6.6	6.4	6.4	7.5	0.1	0.0	7.6	8.6	8.3
2010	Jan	6.8	6.6	6.5	6.3	0.0	0.0	6.3	7.6	8.2
	Feb	6.7	6.7	6.5	5.5	0.5	0.1	6.1	6.7	8.2
	Mar	6.9	6.8	6.5	7.0	0.2	0.0	7.3	6.5	8.1
	Apr	6.8	6.8	6.6	7.4	1.5	0.2	9.1	7.5	8.1
	May	6.5	6.7	6.6	7.6	3.5	0.4	11.4	9.3	8.3
	Jun	6.4	6.6	6.6	6.6	4.2	0.5	11.3	10.6	8.4
	Jul	7.0	6.6	6.6	7.2	0.9	0.1	8.2	10.3	8.4
	Aug	7.4	6.9	6.7	6.8	0.5	0.2	7.5	9.0	8.4
	Sep	6.7	7.0	6.7	8.6	1.3	0.2	10.1	8.6	8.6
	Oct	6.3	6.8	6.7	7.3	3.9	0.4	11.6	9.7	8.8
	Nov	6.3	6.4	6.7	6.0	2.7	0.4	9.1	10.3	8.8
	Dec	6.4	6.3	6.7	6.5	1.0	0.3	7.8	9.5	8.8
2011	Jan	6.6	6.4	6.7	5.7	0.4	0.1	6.2	7.7	8.8
	Feb	6.6	6.5	6.7	7.2	0.6	0.0	7.8	7.3	9.0
	Mar	6.6	6.6	6.6	7.1	2.2	0.5	9.8	7.9	9.2
	Apr	6.8	6.7	6.6	7.9	1.4	0.3	9.6	9.1	9.2
	May	6.1	6.5	6.6	7.3	2.6	0.2	10.1	9.8	9.1
	Jun	6.0	6.3	6.6	6.2	2.6	0.2	9.0	9.6	8.9
	Jul	6.5	6.2	6.5	7.4	2.1	0.4	9.9	9.7	9.0
	Aug	6.9	6.4	6.5	6.6	1.7	0.4	8.8	9.2	9.1
	Sep	7.1	6.8	6.5	7.1	0.3	0.0	7.4	8.7	8.9
	Oct	6.5	6.8	6.5	7.3	2.0	0.3	9.6	8.6	8.8
	Nov	6.4	6.7	6.5	6.9	2.2	0.5	9.6	8.9	8.8
	Dec	6.5	6.5	6.5	7.2	1.5	0.2	8.8	9.3	8.9

**TABLE 2-2. FLOW DATA FOR WED WRF TREATMENT FACILITY AND REUSE SYSTEM**

YEAR	MONTH	WED INFLUENT FLOW, MGD			EFFLUENT FLOW, MGD			REUSE SYSTEM, MGD		
		MONTHLY AVERAGE, FLW-01	TMADF	AADF	WED EFFLUENT, FLW-02	CITY OF CLEAR- WATER, FLW-03	CITY OF OLDS- MAR, FLW-04	INFLUENT, FLW-05	TMADF	AADF
2012	Jan	6.5	6.5	6.5	7.2	1.1	0.2	8.4	8.9	9.1
	Feb	6.5	6.5	6.5	7.3	1.1	0.1	8.5	8.6	9.1
	Mar	6.5	6.5	6.5	7.3	2.8	0.4	10.4	9.1	9.2
	Apr	6.4	6.5	6.5	7.1	2.8	0.4	10.3	9.7	9.2
	May	6.2	6.4	6.5	6.3	2.4	0.2	8.9	9.9	9.1
	Jun	7.2	6.6	6.6	6.2	1.1	0.2	7.4	8.8	9.0
	Jul	7.7	7.0	6.7	7.2	0.2	0.0	7.4	7.9	8.8
	Aug	7.1	7.3	6.7	7.5	1.1	0.3	8.9	7.9	8.8
	Sep	7.0	7.2	6.7	8.1	0.7	0.1	8.9	8.4	8.9
	Oct	6.6	6.9	6.7	9.1	1.6	0.3	11.0	9.6	9.0
	Nov	6.3	6.6	6.7	8.9	2.6	0.4	12.0	10.6	9.2
	Dec	6.4	6.4	6.7	6.2	1.5	0.3	8.0	10.3	9.2
2013	Jan	6.5	6.4	6.7	7.0	0.9	0.2	8.0	9.3	9.1
	Feb	6.5	6.5	6.7	7.1	0.9	0.2	8.2	8.1	9.1
	Mar	6.6	6.5	6.7	7.5	0.7	0.1	8.3	8.2	8.9
	Apr	6.4	6.5	6.7	7.4	2.0	0.3	9.7	8.7	8.9
	May	6.2	6.4	6.7	6.9	2.9	0.3	10.1	9.4	9.0
	Jun	6.3	6.3	6.6	6.2	1.4	0.3	7.9	9.2	9.0
	Jul	6.6	6.4	6.5	6.5	0.0	0.0	6.6	8.2	9.0
	Aug	6.8	6.6	6.5	6.3	0.8	0.2	7.4	7.3	8.8
	Sep	6.7	6.7	6.5	6.4	0.8	0.2	7.5	7.1	8.7
	Oct	6.6	6.7	6.5	9.1	1.6	0.3	11.0	8.6	8.7
	Nov	6.3	6.5	6.5	8.9	2.6	0.4	12.0	10.1	8.7
	Dec	6.4	6.4	6.5	6.2	1.5	0.3	8.0	10.3	8.7








Year	Flow, MGD
2003	7.0
2004	7.6
2005	7.5
2006	6.7
2007	6.3
2008	6.3
2009	6.4
2010	6.7
2011	6.5
2012	6.7
2013	6.5

### 2.3 Seasonal Variations in Flow

Some variations in flow were experienced at the facility in March and again in July and August each year. **Figure 5** illustrates the seasonal variations. An average over the study period is provided in the graphic. Variations of flow due to inflow or infiltration (I/I) were only experienced at the facility when rainfall was noted at 10-inches or more. Based on the above AADF and maximum TMADF, the ratios of the maximum TMADF to the AADF have been calculated to range from 1.01 to 1.10 and are summarized in **Table 2-4**.

Year	Max TMADF, MGD	AAFD, MGD	Ratio TMADF / AADF
2009	6.7	6.3	1.06
2010	7.0	6.6	1.06
2011	6.8	6.6	1.04
2012	7.3	6.6	1.10
2013	6.7	6.6	1.01
Maximum			1.10
Minimum			1.01
Average			1.05



Based on monthly operating reports, the maximum TMADF typically occurred between the months of March and April of each year. The average ratio of the maximum TMADF to the AADF for the past five years was calculated to be approximately 1.05.

## 2.4 Updated Flow and Loading Information

The current loadings for the WEDWRF were estimated by using the discharge monitoring reports for 2009 to 2013.

**Table 2-5** summarizes the design and current influent characteristics:



Table 2-5. Design and Current Influent Characteristics		
Parameter	Design Annual Average	Influent Average (2009 – 2013)
CBOD <sub>5</sub> (mg/L)	300	203
TSS (mg/L)	300	223
Total N-NO <sub>3</sub> (mg/L)	50	N/A
Phosphorus (mg/L)	10	N/A
Average Daily Flow (MGD)	9	6.5

The current CBOD<sub>5</sub> loading is approximately 32 percent lower than the loading value predicted by the design. TSS value is approximately 26 percent lower than the loading value predicted by the design. Effluent TSS concentrations are consistently met. Assuming continued proper maintenance and operating procedures as currently, the WEDWRF should effectively operate during the term of the permit.

### 3.0 FUTURE CONDITIONS

#### 3.1 Population Projections

Population projections were provided by Pinellas County and were reported to be determined as follows: Permanent population estimates were derived from the trend analysis of the draft Pinellas County Population Projections for 2010 – 2040. Seasonal and Tourist Populations were determined from the Pinellas County Population Projections for 2006 – 2035. Projections were reported at five-year intervals and interim years were determined by interpolation. **Table 3-1** provides the population projections for the service area on a yearly basis from 2014 to 2023.


<b>Table 3-1. Service Area Population Projection</b>	
<b>Year</b>	<b>Estimated Population</b>
2014	102,666
2015	102,755
2016	102,844
2017	102,933
2018	103,022
2019	103,111
2020	103,200
2021	103,289
2022	103,378
2023	103,467

#### 3.2 Flow Projections

Based on the population projections made by Pinellas County, the service area population is expected to increase by less than one percent by the year 2023. Assuming that wastewater production increases proportionally to the population, the flow to the WEDWRF is expected to increase by approximately 0.1 percent per year. Using the average ratio defined in **Section 2.3**, and the population projections from the Pinellas County Planning Department, the future AADF and yearly maximum TMADF have been estimated for each of the next 10 years and are summarized in **Table 3-2**. Based upon the historical flow of 63 gpcd, the maximum service population is approximately 142,900.

Table 3-2. Projected Flow Summary – 2013 – 2023.		
Year	Projected Maximum TMADF (MGD)	Projected AADF (MGD)
2013	6.67	6.46
2014	6.67	6.47
2015	6.68	6.47
2016	6.68	6.48
2017	6.69	6.48
2018	6.70	6.49
2019	6.70	6.50
2020	6.71	6.50
2021	6.71	6.51
2022	6.72	6.51
2023	6.73	6.52

The AADF by the year 2023 is estimated to be approximate 6.52 MGD which is 28 percent under the WEDWRF permitted capacity. **Figure 6** provides a graphic illustration of the projected AADF and maximum TMADF for the facility.



## 4.0 SUMMARY AND CONCLUSIONS

### 4.1 Time Required to Reach the Permitted Capacity

The existing WEDWRF permitted capacity is based on the annual average daily flow, not on the three-month average daily flow. The annual average daily flow for 2013 was 6.5 MGD. This is within below the facility's permitted capacity of 9 MGD. **Table 4-1** presents a comparison between the permitted capacity and the projected maximum TMADF for the next 10 years.

Year	Maximum TMADF (MGD)	Permitted Capacity (MGD)	Percentage (%)
2013	6.67	9	74.11
2014	6.67	9	74.11
2015	6.68	9	74.22
2016	6.68	9	74.22
2017	6.69	9	74.33
2018	6.70	9	74.44
2019	6.70	9	74.44
2020	6.71	9	74.55
2021	6.71	9	74.55
2022	6.72	9	74.67
2023	6.73	9	74.78

If the estimated flow trends discussed in **Section 3.2**, and **Table 4-1** continue as predicted, the WEDWRF will not exceed the permitted capacity in the next 50 years.

### 4.2 Recommendations for Expansion

As discussed in **Section 3.2** the estimated AADF by the year 2023 will be approximate 6.52 MGD. This is equivalent to 72 percent (%) of the WEDWRF permitted capacity. Given the current annual projected population increase of approximately 0.1% per year, no increase in plant capacity is currently needed. Therefore there are no recommendations or schedule for expansion provided herein.